



6100 Quail Valley Ct.  
Riverside, CA 92507  
Ph: 951.653.3351  
Fx: 951.653.1662  
www.babcocklabs.com


[Log In](#)
[Search](#)
[Help](#)
[Log Out](#)

## Results for A9J0335-01

[Back To:](#)
[Work Order](#)
[Sample Analysis](#)


St. Anthony Mobile  
Home Park  
18375 Ventura Blvd.,  
Suite #777  
Tarzana, CA 91356

Project: No Project  
Project Number: No Project  
Project Manager: Tara Holt

**Reported:**  
2/2/2010 9:24:23 PM

**Well #1 - Pre-Treatment  
A9J0335-01 (Water)  
E.S. Babcock & Sons, Inc.**

## Cations

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
Calcium	7.3	1.0	mg/L	9J07013	10/07/09	10/07/09	EPA 200.7	
Total Hardness	20	3.0	"	"	"	"	SM 3120B	
Magnesium	ND	1.0	"	"	"	"	EPA 200.7	

## Anions

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
Fluoride	1.1	0.1	mg/L	9J07009	10/07/09	10/07/09	SM 4500F C	
Sulfate	43	0.50	"	9J05062	10/05/09	10/06/09	EPA 300.0	

## Aggregate Properties

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
pH	9.0	1.0	pH Units	9J05046	10/05/09	10/05/09	SM 4500H+ B	

## Solids

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
Total Suspended Solids	ND	5 mg/L		9J09038	10/09/09	10/09/09	SM 2540D	

## General Physical

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
Turbidity	ND	0.20	NTU	9J06015	10/06/09	10/06/09	SM 2130 B	

## General Inorganics

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
Dissolved Sulfide	ND	0.10 mg/L		9J05067	10/05/09	10/05/09	SM 4500S2 D	
Sulfide	ND	0.10	"	9J06070	10/06/09	10/06/09	"	

## Nutrients

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
Ortho Phosphate Phosphorus	ND	0.050 mg/L		9J07005	10/07/09	10/07/09	SM 4500P E	

## Metals and Metalloids

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Analysis	Notes
Arsenic	24	2.0 ug/L		9J08007	10/08/09	10/08/09	EPA 200.8	
Iron	ND	100	"	9J07013	10/07/09	10/07/09	EPA 200.7	
Manganese	ND	20	"	9J08007	10/08/09	10/08/09	EPA 200.8	
Total Silica	14	5.0 mg/L		9J07013	10/07/09	10/07/09	EPA 200.7	