

LUMINAIRE SCHEDULE CONTINUED							
TYPE	VOLTAGE	WATTAGE	DESCRIPTION	SIMILAR TO	LAMPS	BALLAST	MOUNTING
9	277	63	6" DIA RECESSED OPEN DOWNLIGHT WITH ADJUSTABLE BASE SOCKET. SPECULAR CLEAR REFLECTOR. WHITE TRIM RING. ENCAPSULATED BALLAST, PREWIRED JUNCTION BOX. ALL COMPONENTS ACCESSIBLE FROM BELOW CEILING. UL LISTED FOR "DAMP LOCATIONS."	CAPRI LIGHTING CM6V50-VIF-TO42Q	(1) 50W ED17 METAL HALIDE	MINUS 20 DEGREES STARTING	RECESSED IN SOFFIT
10	277	4	COMBINATION EMERGENCY EXIT LIGHT: ALL DIE CAST UNIVERSAL SURFACE MOUNTING. UNIVERSAL CHEVRONS, WHITE FINISH "GREEN" LETTERS ON WHITE BACKGROUND. SEALED LEAD CALCIUM BATTERY. SINGLE OR DOUBLE FACE AS SHOWN. SHADED AREA INDICATES LIT FACE. ARROWS AS SHOWN ON PLANS.	CHLORIDE E-G-C2	LED	N/A	UNIVERSAL CEILING OR SURFACE WALL MT ON RECESSED OUTLET BOX. BOTTOM TO BE 4 INCHES ABOVE TOP OF DOOR FRAMING. USE IN ALL NON-PROCESS AREAS
11	277	4	COMBINATION EMERGENCY EXIT LIGHT: ALL DIE CAST UNIVERSAL SURFACE MOUNTING. UNIVERSAL CHEVRONS, WHITE FINISH "GREEN" LETTERS ON WHITE BACKGROUND. SEALED LEAD CALCIUM BATTERY. SINGLE OR DOUBLE FACE AS SHOWN. SHADED AREA INDICATES LIT FACE. ARROWS AS SHOWN ON PLANS. UL LISTED FOR WET LOCATIONS	CHLORIDE N2H-L1-G-TP-W	LED	N/A	UNIVERSAL CEILING OR SURFACE WALL MT ON RECESSED OUTLET BOX. BOTTOM TO BE 4 INCHES ABOVE TOP OF DOOR FRAMING.
11A	277	15	EMERGENCY STANDBY LIGHT: FIBERGLASS HOUSING, UNIVERSAL SURFACE MOUNTING. SEALED LEAD CALCIUM BATTERY. UL LISTED FOR WET LOCATIONS	CHLORIDE CN4X	PAR 36	N/A	UNIVERSAL CEILING OR SURFACE WALL MT ON RECESSED OUTLET BOX. BOTTOM TO BE 8'-0" AFF IN LOCATIONS SHOWN ON THE DRAWINGS.
12	277	36	OUTDOOR WALL-MOUNTED LUMINAIRE. DIE CAST ALUMINUM HOUSING, UL LISTED. WET LOCATIONS.	LITHONIA ASW1-32TRT-SR4SC-277-LPI-DEBT	(1) 32W TRT	ELECTRONIC	WALL-MOUNT AT 10' AFG, UNLESS OTHERWISE NOTED.
13	277	208	SITE LUMINAIRE, FULL CUTOFF, TYPE II DISTRIBUTION WITH 16' SQUARE STRAIGHT STEEL POLE AND INTEGRAL 3" X 5" HAND HOLE, UL LISTED, WET LOCATION	LITHONIA KSF1-175M-R2-480-SP12-SCWA-DF-LPI	(1) 175 W MH	ELECTRONIC	POLE MOUNTED.
14	277	210	INDUSTRIAL HIGH BAY, AL DIE CAST, 22" CLEAR PRISMATIC REFLECTOR, UL LISTED. INSTANT ON/ INSTANT RESTRIKE. CRI:85	US LIGHTING TECH RI-277V-200W-5K-CL-22	(1) 200 W INDUCTION LAMP	ELECTRONIC	PENDANT-MOUNT AT 16' AFF, UNLESS OTHERWISE NOTED.
15	480	310	SITE LUMINAIRE, FULL CUTOFF, TYPE IV DISTRIBUTION WITH 20' SQUARE STRAIGHT STEEL POLE AND INTEGRAL 3" X 5" HAND HOLE, UL LISTED, WET LOCATION	LITHONIA KSF1-250S-R4SC-480-SP12-SCWA-DF-LPI	(1) 250 W HPS	ELECTRONIC	POLE MOUNTED.
16	277	161	INDUSTRIAL AREA LIGHTING WITH LESS THAN 10% THD, UL LISTED, WET LOCATION, COPPER-FREE ALUMINUM BALLAST HOUSING WITH GLOBE AND ANGLE REFLECTOR	COOPER CROUSE-HINDS DMVIG165-TWM2-RA739/277	(1) 165 W INDUCTION LAMP	ELECTRONIC	WALL MOUNT
OC1	24VDC		OCCUPANCY SENSOR WITH POWER PACK AND AUXILIARY RELAY, UL LISTED.	SQUARE D SLSGDS2000	N/A	N/A	CEILING MOUNT DUAL TECH
OC2	277		OCCUPANCY SENSOR, UL LISTED	SQUARE D SLSDDW1277U	N/A	N/A	WALL MOUNT TWO SWITCH, TWO RELAY
OC3	277		MOTION SENSOR, UL LISTED, WET LOCATION	WATTSTOPPER EN-100(WIDE)	N/A	N/A	WALL MOUNT
PC1	24VDC		LIGHT LEVEL SENSOR, UL LISTED	SQUARE D CLIPSAL	N/A	N/A	CEILING MOUNT



SYMBOL	DESCRIPTIONS	DATE	APPROVAL

EASTERN MUNICIPAL WATER DISTRICT
 PERRIS II DESALINATION FACILITY
 PERRIS, CALIFORNIA
LUMINAIRE SCHEDULE 2

DESIGNED BY: A. MATHEWS
 DRAWN BY: J. HAWKER
 CHECKED BY: R. DENON
 U.S. ARMY ENGINEER DISTRICT
 LOS ANGELES
 CORPS OF ENGINEERS
 ART. JUNG, P.E.
 CHIEF, DESIGN BRANCH
 L.A. DISTRICT FILE NO. XXX-XXXX
 SPEC. NO. : NOT APPLICABLE
 CADD FILE NAME: PDFe114.dgn