


- NOTES:**
- FOR ROOF SLOPES AND ROOF DRAINS, SEE DRAWING A-2.
 - FOR METAL DECKING AND STEEL JOISTS NOTES, SEE STRUCTURAL NOTES, DRAWING G-10.
 - FOR PIPE SUPPORTS TO FRAMING, SEE SPECIFICATION 40 05 15, PIPING SUPPORT SYSTEM.
 - FOR DECKING CONNECTIONS USE (4) 5/8" PUDDLE WELDS PER SECTION AT SUPPORTS AND SPACED AT 1'-0" AT SIDE LAPS.
 - SEE ARCHITECTURAL DRAWINGS FOR BUILDING TOP OF WALL ELEVATIONS.
 - CLOSURE PLATE AT JOIST PENETRATION THROUGH WALL, SEE (0558-002) SIM.

- JOISTS NOTES:**
- DL=20 PSF (15 PSF ON TOP CHORD AND 5 PSF ON BOTTOM CHORD, WEIGHT OF JOIST NOT INCLUDED). LL=20 PSF (ON TOP CHORD) UNREDUCED.
 - JOIST MANUFACTURER SHALL DETERMINE THE JOIST BRIDGING REQUIREMENTS.

SEE CONTINUATION ON DWG S-7

- ROOF OPENING LEGEND**
- TRANSLUCENT PANEL SKYLIGHT
 - HVAC UNIT
- REFER TO DWG A-2

ADMIN AREA ROOF FRAMING PLAN
1/8"=1'-0"



EASTERN MUNICIPAL WATER DISTRICT PERRIS II DESALINATION FACILITY PERRIS, CALIFORNIA ADMIN AREA ROOF FRAMING PLAN	DESIGNED BY: T. PAGE	U.S. ARMY ENGINEER DISTRICT LOS ANGELES CORPS OF ENGINEERS	SUBMITTED BY: ART JUNG, P.E. CHIEF, DESIGN BRANCH	L.A. DISTRICT FILE NO. XXX-XXXX SPEC. NO.: NOT APPLICABLE CAD FILE NAME: PDS109d.dgn
	DRAWN BY: A. VARGAS CHECKED BY: M. GOODSON			
REVISIONS SYMBOL DESCRIPTIONS DATE APPROVAL				