


TYPE G

PIPE LADDER UNDER COVER



TYPE H

PIPE LADDER WITH EXTENSION

NOTES:

1. PROVIDE PROTECTION FOR ALUMINUM IN CONTACT WITH CONCRETE AS SPECIFIED.
2. PROVIDE LADDER SAFETY POST AS SPECIFIED, WHERE INDICATED.
3. PROVIDE SAFETY CLIMB RAIL WITH BELT & EXTENSION RAIL AS SPECIFIED WHERE INDICATED.
4. PROVIDE SST CONC ANCHORS WHEN LOCATED BELOW MAXIMUM WATER SURFACE.

PRE-ENGINEERED PIPE LADDER - ALUMINUM

NTS

EASTERN MUNICIPAL WATER DISTRICT
PERRIS II DESALINATION FACILITY

DETAIL 1 OF 2

0551-101