

**NOTES:**

1. RUNGS SHALL BE FABRICATED FROM 3/4" DIA SMOOTH TYPE 316 STAINLESS STEEL BAR.
2. RUNGS SHALL BE EQUALLY SPACED VERTICALLY AT 12" OC MAX.
3. EMBEDDED PORTION OF RUNGS SHALL BE COATED AS PER SPECIFICATIONS.

**INDIVIDUAL RUNG LADDER**

NTS

EASTERN MUNICIPAL WATER DISTRICT  
PERRIS II DESALINATION FACILITY

0551-146