



### NOTES:

1. CONTRACTOR SHALL SUBMIT A REFRIGERANT PIPING DIAGRAM APPROVED BY THE CONDENSING UNIT MANUFACTURER BEFORE PROCEEDING WITH WORK. (REFER TO SPECIFICATIONS FOR REFRIGERANT PIPING INSTALLATION REQUIREMENTS)
2. DELETE ANY VALVES OR MATERIALS THAT ARE FURNISHED WITH UNIT.
3. REFRIGERANT PIPING SHALL BE SIZED PER MANUFACTURER OPTIMUM PERFORMANCE RATING.

## REFRIGERANT PIPING

NTS

© CH2M HILL

2323-184