

**NOTES:**

1. ALL HARDWARE SHALL BE STAINLESS STEEL.
2. THIS DETAIL SHALL BE USED FOR TERMINATION OF ALL MANUFACTURER SUPPLIED CABLES (MSC) EXITING A WET WELL IF NO OTHER DETAIL IS CALLED OUT ON THE DRAWINGS.
3. FILL CONDUIT SLEEVE WITH EXPANDABLE SEALING COMPOUND.

**MSC CABLE TERMINATION**

NTS

© CH2M HILL