



NOTES:

1. OD = OUTSIDE DIAMETER OF CONDUIT.
2. "S" = CLEAR SPACE BETWEEN REINFORCING.
3. MAX OD = SMALLER OF "T"/4 OR "S"-1/2".
4. CONDUITS IN SLAB WHICH IS PARALLEL TO BEAMS AND WALLS SUPPORTING THE SLAB SHALL NOT BE PLACED CLOSER THAN 4 x "T" FROM THE FACE OF THE BEAMS OR WALLS.
5. CONDUITS CROSSING SUPPORTING BEAMS SHALL BE INSTALLED PERPENDICULAR TO THE BEAM.
6. METAL CONDUITS SHALL BE ISOLATED WITH 3 WRAPS OF 10 MIL PVC TAPE AT THE POINT OF CONTACT WITH REINFORCING.

CONDUITS EMBEDDED IN ELEVATED CONCRETE SLAB/WALL

NTS

© CH2M HILL

2605-803