



NOTES:

1. VALVE SIZE, TYPE, AND MATERIAL TO MATCH FEED LINE SIZE AND TYPE AS SPECIFIED FOR SERVICE. GAS SERVICE CHECK VALVES SHALL BE INSTALLED FOR VERTICAL UPFLOW ONLY.
2. BRANCH NOZZLE 1 1/2" AND SMALLER MAY BE CONNECTED TO DUCTILE IRON PIPE WITH A SERVICE SADDLE.

CHEMICAL INJECTOR

NTS