

**NOTES:**

1. MOUNT TRANSMITTER BELOW OR LEVEL WITH BOTTOM LEVEL CONNECTION.
2. PROVIDE WETTED PARTS COMPATIBLE WITH TANK LIQUID.

PDT INSTALLATION FOR
VENTED TANK LEVEL MEASUREMENT**NTS**

© CH2M HILL

4091-240