

**NOTES:**

1. LOCATE BOTTOM OF TRANSDUCER NOT LESS THAN MANUFACTURER'S RECOMMENDED DISTANCE FROM MAX LIQUID LEVEL.
2. LOCATE AWAY FROM WALLS AND OBSTRUCTIONS PER MANUFACTURER'S RECOMMENDATIONS.
3. ROUND OFF ALL EXPOSED EDGES AND CORNERS.
4. PAINT ALUMINUM IN CONTACT WITH CONCRETE ACCORDING TO SPECIFICATIONS.
5. COMPONENTS DESIGNATED BY \* ARE SUPPLIED BY INSTRUMENT MANUFACTURER.

## ULTRASONIC LEVEL ELEMENT INSTALLATION - OPEN TANK/CHANNEL

NTS

EASTERN MUNICIPAL WATER DISTRICT  
PERRIS II DESALINATION FACILITY

4091-254