

DEPARTMENT OF WATER RESOURCES

1416 NINTH STREET, P.O. BOX 942836
SACRAMENTO, CA 94236-0001
(916) 653-5791



June 9, 2014

Ms. Tammy Rudock
General Manager
Mid-Peninsula Water District
3 Dairy Lane
Belmont, California 94002

Dear Ms. Rudock:

The Department of Water Resources (DWR) has reviewed the Mid-Peninsula Water District's (District) 2010 Urban Water Management Plan (UWMP) received August 1, 2011. The California Water Code (CWC) directs DWR to report to the legislature once every five years on the status of submitted plans. In meeting this legislative reporting requirement, DWR reviews all submitted plans.

DWR's review of the District's 2010 UWMP has found that the plan has generally addressed the requirements of the CWC.

DWR recommends that when updating this plan in 2015, the District:

- Include a citation of the source used to determine the population of the service area during the baseline period. Water Code Section 10608.2 (e) and (f).
- Adjust the interim (2015) target to be the midpoint between the baseline GPCD (130) and the 2020 target GPCD (119). The UWMP reported the interim target as 137 GPCD, but should have been reported as 125 GPCD. Water Code Section 10608.12 (j)

By including this data in future UWMPs, the District will better meet the requirements of the Water Code.


DWR's review of plans is limited to assessing whether suppliers have addressed the required legislative elements. In its review, DWR does not evaluate or analyze the supplier's UWMP

Ms. Tammy Rudock
June 9, 2014
Page 2

data, projections, or water management strategies. This letter is meant to acknowledge that the District's 2010 UWMP has addressed these requirements. The results of the review will also be provided to DWR's Financial Assistance Branch.

If you have any questions regarding the review of the plan or urban water management planning, please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Peter Brostrom', with a long horizontal flourish extending to the right.

Peter Brostrom
UWMP Program Manager
brostrom@water.ca.gov
(916) 651-7034

cc: Kim Rosmaier
DWR North Central Regional Office

Gwen Huff
DWR Headquarters Office