





TC 324  
C2  
A2 1S  
No. 211  
APPENDIX

PHYSICAL SCI. LIB.

UNIVERSITY OF CALIFORNIA  
DAVIS

JUN 17 1981

CALIF. DEPOS.  
GC<sup>1</sup> DOCS. - LIBRARY

State of California  
The Resources Agency

Department of  
Water Resources



## Small Hydroelectric Potential at Existing Hydraulic Structures in California

Bulletin 211  
April 1981



Bulletin 211 was partially funded by a cooperative agreement (No. DE-FC-49-80-R9-10019.000) with the U.S. Department of Energy.

This Bulletin responds to Chapter 933, Statutes of 1978:

" . . . It is in the best interests of the state that the existing dams and hydraulic structures identified in the Department of Water Resources' previous surveys be further studied to determine the feasibility and cost-effectiveness of equipping these dams and hydraulic structures with electric power-generating facilities . . ."

The legislation, Senate Bill 1834, was authored by Senator Alfred Alquist.



**ON THE COVER:** Turlock Lake Powerhouse, located on the Turlock Main Canal in Stanislaus County, is owned by the Turlock Irrigation District. This 3 300-kilowatt hydroelectric power plant generates 122 million kilowatthours of electricity annually. This amount of energy is equivalent to burning 20,000 barrels of oil annually in a fossil fuel plant.

Photo courtesy of Turlock Irrigation District.

**Department of  
Water Resources  
Bulletin 211**

# **Small Hydroelectric Potential at Existing Hydraulic Structures in California**

**Appendixes: Data and Guidelines for Development**

**April 1981**

**Huey D. Johnson**  
Secretary for Resources

**The Resources  
Agency**

**Edmund G. Brown Jr.**  
Governor

**State of  
California**

**Ronald B. Robie**  
Director

**Department of  
Water Resources**



CONTENTS

| <u>APPENDIX</u> | <u>TITLE</u>  | <u>PAGE</u> |
|-----------------|---|-------------|
| A               | Lists of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities                            | 1           |
| B               | Field Investigations Conducted by Department of Water Resources   | 49          |
| C               | Preliminary Feasibility Studies for 28 Representative Facilities, Prepared by Department of Water Resources | 65          |
| D               | Feasibility Studies for 42 Facilities, Prepared by Others   | 253         |
| E               | Capacity, Energy, and Cost Data on Facilities Grouped into Six Categories                                   | 305         |
| F               | Permits, Licenses, Certificates, and Other Approvals  | 325         |
| G               | Utility Purchase Prices for Hydroelectric Generation  | 447         |
| H               | Financing Small Hydroelectric Projects  | 471         |
| I               | Hydroelectric Equipment   | 487         |
| J               | Manufacturers of Small Hydroelectric Equipment  | 495         |

Copies of these appendixes at \$10  
and the main text at \$5.00  
may be ordered from:

State of California  
Department of Water Resources  
P.O. Box 388  
Sacramento, CA 95802

Make Checks payable to:  
DEPARTMENT OF WATER RESOURCES  
California residents add 6% sales tax.



APPENDIX A

Lists of Potential Small Hydroelectric Projects At Existing  
Hydraulic Facilities in California

Section A-1: Alphabetical Listing, by Owner

Section A-2: Alphabetical Listing, by Facility Name

Section A-3: Alphabetical Listing, by County

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California

(Alphabetical by Owner)

| Owner and Facility   | County                       | Estimated Capacity (kW)  | Estimated Energy (GWh/yr) |
|--|------------------------------|--------------------------|---------------------------|
| Adamson Companies<br>Rindge Dam  | Los Angeles                  | 600                      | 0.9                       |
| Amador County Water Agency<br>Central Amador Water Project<br>Jackson-Sutter Creek<br>Outfall Pipeline   | Amador<br>Amador             | 250<br>60                | 0.7<br>0.2                |
| Anderson-Cottonwood Irrigation District<br>Anderson Flume Diversion<br>Lake Redding<br>(ACID Diversion Dam)<br>Parkview Station (Canal)  | Shasta<br>Shasta<br>Shasta   | 50<br>9 000<br>150       | 0.2<br>50.0<br>0.5        |
| Arrowhead Lake Association<br>Lake Arrowhead Dam   | San Bernardino               | 75                       | 0.3                       |
| Bakersfield, City of & Kern Delta Water District & North Kern Water District<br>Beardsley Canal Control Structure<br>Beardsley Diversion Structure (Canal)<br>Kern Island Canal Control Structure<br>Rocky Point Diversion Structure (Canal) | Kern<br>Kern<br>Kern<br>Kern | 260<br>500<br>700<br>300 | 1.1<br>1.7<br>3.1<br>0.7  |
| Browns Valley Irrigation District<br>Harding Canal<br>Merle Collins Reservoir (Virginia Ranch Dam)<br>Upper Main Canal   | Yuba<br>Yuba<br>Yuba         | 1 000<br>900<br>200      | 6.6<br>5.6<br>0.9         |
| Calaveras County Water District<br>White Pines Dam   | Calaveras                    | 100                      | 0.4                       |
| Calaveras Public Utility District<br>Schaads Reservoir (Middle Fork Dam)   | Calaveras                    | 75                       | 0.4                       |
| California-American Water Company<br>Los Padres Dam  | Monterey                     | 75                       | 0.3                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility   | County         | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|----------------|-------------------------|---------------------------|
| California Department of Finance<br>Rector Creek Dam                 | Napa           | 100                     | 0.5                       |
| California Department of Water Resources                             |                |                         |                           |
| Antelope Dam   | Plumas         | 450                     | 1.4                       |
| Castaic Outlet (Dam)   | Los Angeles    | 275                     | 1.4                       |
| Cottonwood No. 1 (Canal)   | Los Angeles    | 17 000                  | 115.0                     |
| Cottonwood No. 2 (Canal)   | Los Angeles    | 12 000                  | 90.0                      |
| Del Valle Stream Release (Dam)                                       | Alameda        | 400                     | 1.1                       |
| Frenchman Dam  | Plumas         | 450                     | 1.0                       |
| Lake Davis (Grizzly Valley Dam)                                      | Plumas         | 510                     | 1.5                       |
| Las Flores Turnout (Pipeline)  | San Bernardino | 210                     | 0.7                       |
| Mojave Siphon No. 1<br>(Silverwood Lake Inlet, Pipeline)             | San Bernardino | 6 000                   | 47.0                      |
| Mojave Siphon No. 2<br>(Silverwood Lake Inlet, Pipeline)             | San Bernardino | 10 000                  | 78.0                      |
| Palermo Canal Release (Dam)  | Butte          | 400                     | 1.5                       |
| Pyramid Stream Release (Dam)   | Los Angeles    | 1 000                   | 4.0                       |
| Thermalito Afterbay River<br>Outlet (Dam)                            | Butte          | 13 000                  | 42.6                      |
| Thermalito Diversion Dam   | Butte          | 3 500                   | 23.0                      |
| Calleguas Municipal Water District<br>Conejo Pump Station (Pipeline) | Ventura        | 600                     | 3.0                       |
| Chowchilla Water District  |                |                         |                           |
| Ash Main Canal   | Madera         | 150                     | 0.7                       |
| Califa Canal   | Madera         | 200                     | 0.9                       |
| Chowchilla Main Canal  |                |                         |                           |
| Station 0+00   | Madera         | 250                     | 1.1                       |
| Station 101+80   | Madera         | 250                     | 1.1                       |
| Station 175+00   | Madera         | 250                     | 1.1                       |
| Contra Costa County Water District<br>Mallard Reservoir (Pipeline)   | Contra Costa   | 200                     | 0.9                       |
| Cucamonga County Water District<br>Deer Creek Collection Pipeline    | San Bernardino | 200                     | 1.0                       |
| Desert Water Agency  |                |                         |                           |
| Snow Creek (Pipeline)  | Riverside      | 300                     | 1.7                       |
| Whitewater River (Pipeline)  | Riverside      | 300                     | 2.4                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility   | County      | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|-------------|-------------------------|---------------------------|
| East Bay Municipal Utility District<br>Camanche Dam<br>(Lower Mokelumne River Project)               | San Joaquin | 10 680                  | 35.0                      |
| El Dorado Irrigation District<br>El Dorado Distribution System<br>(Pipelines)                        |             |                         |                           |
| Reservoir A  | El Dorado   | 730                     | 3.2                       |
| Reservoir 2  | El Dorado   | 50                      | 0.2                       |
| Reservoir 2A   | El Dorado   | 480                     | 2.1                       |
| Reservoir 2A-3   | El Dorado   | 360                     | 1.6                       |
| Reservoir 3  | El Dorado   | 200                     | 0.9                       |
|  |             |                         | 0.3                       |
| Reservoir 5  | El Dorado   | 60                      | 0.3                       |
| Reservoir 6  | El Dorado   | 80                      | 0.3                       |
| Reservoir 8  | El Dorado   | 175                     | 0.8                       |
| Reservoir 9A   | El Dorado   | 175                     | 0.8                       |
| Reservoir 9B   | El Dorado   | 90                      | 0.4                       |
| Reservoir 10A  | El Dorado   | 175                     | 0.8                       |
| Reservoir 10B  | El Dorado   | 60                      | 0.3                       |
| Webber Dam   | El Dorado   | 75                      | 0.3                       |
| El Segundo, City of<br>El Segundo Distribution<br>System (Pipeline)                                  | Los Angeles | 500                     | 3.9                       |
| Escondido Mutual Water Company<br>Bear Valley Powerplant<br>Rehabilitation<br>(At Lake Wohlford Dam) | San Diego   | 700                     | 3.7                       |
| Fresno Irrigation District<br>Fresno Main Canal  |             |                         |                           |
| Headworks  | Fresno      | 650                     | 2.6                       |
| Boos Check   | Fresno      | 650                     | 2.6                       |
| Dresser Check  | Fresno      | 650                     | 2.6                       |
| Gould Weir Diversion Dam   | Fresno      | 850                     | 3.5                       |
| George Costa<br>Del Loma Tunnel  | Trinity     | 250                     | 1.9                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility                           | County        | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|---------------|-------------------------|---------------------------|
| Georgetown Divide Public Utility District    |               |                         |                           |
| Buckeye Conduit                              | El Dorado     | 350                     | 2.4                       |
| Buffalo Hill Siphon (Pipeline)               | El Dorado     | 160                     | 0.5                       |
| Kaiser Pipeline                              | El Dorado     | 120                     | 0.3                       |
| Stumpy Meadows Reservoir (Mark Edson Dam)    | El Dorado     | 325                     | 2.2                       |
| Glendale, City of                            |               |                         |                           |
| Glendale Distribution System (Pipeline)      | Los Angeles   | 400                     | 2.0                       |
| Goleta County Water District                 |               |                         |                           |
| Carneros Power Project (Pipeline)            | Santa Barbara | 700                     | 1.6                       |
| Hidden Valley Lake Association               |               |                         |                           |
| Coyote Creek (Dam)                           | Lake          | 90                      | 0.4                       |
| Hot Springs Valley Irrigation District       |               |                         |                           |
| Big Sage Dam                                 | Modoc         | 175                     | 0.7                       |
| Humboldt Bay Municipal Water District        |               |                         |                           |
| Ruth Reservoir (Robert W. Matthews Dam)      | Trinity       | 4 000                   | 14.2                      |
| Imperial Irrigation District                 |               |                         |                           |
| Alamo Drop 3A (Canal)                        | Imperial      | 1 200                   | 6.7                       |
| Dahlia Drop (Canal)                          | Imperial      | 225                     | 1.0                       |
| East Highline Canal Turnout                  | Imperial      | 1 800                   | 10.0                      |
| Newside Drop (Canal)                         | Imperial      | 200                     | 0.9                       |
| No. 8 Heading (Canal)                        | Imperial      | 750                     | 3.9                       |
| Tuberose Check (Canal)                       | Imperial      | 200                     | 1.3                       |
| Vail Heading (Canal)                         | Imperial      | 225                     | 1.0                       |
| Irvine Ranch Water District                  |               |                         |                           |
| Irvine Lake Pipeline (Rattlesnake Reservoir) | Orange        | 500                     | 1.0                       |
| Jack and Thomas Swickward                    |               |                         |                           |
| Round Valley Dam                             | Lassen        | 90                      | 0.4                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility  | County      | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|---|-------------|-------------------------|---------------------------|
| Jackson Valley Irrigation District<br>Lake Amador (Jackson Creek Dam)                                 | Amador      | 350                     | 2.5                       |
| La Habra, City of<br>Orange County (OC) 45 (Pipeline)   | Orange      | 100                     | <u>1</u> /                |
| Lake Hemet Municipal Water District<br>Lake Hemet Dam   | Riverside   | 75                      | 0.1                       |
| Lake Wildwood Association<br>Anthony House Dam  | Nevada      | 50                      | 0.2                       |
| Lassen Irrigation Company<br>McCoy Flat Dam   | Lassen      | 50                      | 0.2                       |
| Lockheed Missiles & Space Company, Inc.<br>Big Creek Hydroelectric Plant<br>Rehabilitation (Pipeline) | Santa Cruz  | 800                     | 3.0                       |
| Los Angeles, City of<br>Franklin Inlet (Pipeline)   | Los Angeles | 800                     | 6.8                       |
| Grant Lake (Dam)  | Mono        | 1 500                   | 3.0                       |
| Los Angeles Distribution System<br>(Pipeline)   |             |                         |                           |
| Location 1  | Los Angeles | 610                     | 3.3                       |
| Location 2  | Los Angeles | 270                     | 2.2                       |
| Location 3  | Los Angeles | 420                     | 2.1                       |
| Location 4  | Los Angeles | 270                     | 1.8                       |
| Location 5  | Los Angeles | 140                     | 1.2                       |
| Location 6  | Los Angeles | 190                     | 1.1                       |
| Location 7  | Los Angeles | 120                     | 1.0                       |
| Location 8  | Los Angeles | 130                     | 0.8                       |
| Location 9  | Los Angeles | 70                      | 0.6                       |
| Location 10   | Los Angeles | 100                     | 0.6                       |
| Location 11   | Los Angeles | 70                      | 0.6                       |
| Location 12   | Los Angeles | 100                     | 0.6                       |
| Location 13   | Los Angeles | 60                      | 0.5                       |
| Location 14   | Los Angeles | 60                      | 0.5                       |
| Location 15   | Los Angeles | 1 000                   | 8.2                       |
| Location 16   | Los Angeles | 1 800                   | 9.0                       |
| Los Angeles Reservoir (Dam)   | Los Angeles | 6 200                   | 37.0                      |
| Stone Canyon Dam  | Los Angeles | 300                     | 2.0                       |
| Tinemaha Dam  | Inyo        | 1 600                   | 8.3                       |
| Van Owen Regulating (Pipeline)  | Los Angeles | 600                     | 5.0                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility                              | County         | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|---|----------------|-------------------------|---------------------------|
| Oakdale and South San Joan Irrigation Districts |                |                         |                           |
| Goodwin Dam                                     | Calaveras      | 970                     | 5.0                       |
| Sand Bar Project (Dam)                          | Tuolumne       | 12 000                  | 70.0                      |
| Orange Cove Irrigation District                 |                |                         |                           |
| Dodge Ave Check (Canal)                         | Tulare         | 475                     | 2.4                       |
| Sand Creek Check (Canal)                        | Tulare         | 200                     | 1.5                       |
| Orange County Water District                    |                |                         |                           |
| OC 28 (Pipeline)                                | Orange         | 6 300                   | 12.0                      |
| OC 59 (Pipeline)                                | San Bernardino | 5 000                   | 9.4                       |
| Oroville-Wyandotte Irrigation District          |                |                         |                           |
| Little Grass Valley Dam                         | Plumas         | 2 600                   | 6.5                       |
| Ponderosa Diversion Dam                         | Butte          | 3 300                   | 14.0                      |
| Sly Creek Dam                                   | Butte          | 13 200                  | 48.2                      |
| Pacheco Pass Water District                     |                |                         |                           |
| Pacheco Lake (North Fork Dam)                   | Santa Clara    | 60                      | 0.3                       |
| Pacific Gas and Electric Company                |                |                         |                           |
| Bucks Lake (Bucks Storage Dam)                  | Plumas         | 740                     | 3.2                       |
| Lake Fordyce Dam                                | Nevada         | 900                     | 4.0                       |
| Lake Pillsbury (Scott Dam)                      | Lake           | 5 000                   | 15.0                      |
| Lake Valley Dam                                 | Placer         | 75                      | 0.3                       |
| Lyons Dam                                       | Tuolumne       | 300                     | 1.5                       |
| McCloud Dam                                     | Shasta         | 1 200                   | 5.4                       |
| South Canal                                     | Placer         | 8 000                   | 37.0                      |
| Spicers Meadows Dam                             | Tuolumne       | 750                     | 3.3                       |
| Volta No. 2 Powerhouse (Canal)                  | Shasta         | 1 000                   | 5.0                       |
| Palmdale Water District                         |                |                         |                           |
| Littlerock Dam                                  | Los Angeles    | 50                      | 0.2                       |
| Paradise Irrigation District                    |                |                         |                           |
| Paradise Dam                                    | Butte          | 300                     | 1.2                       |
| People's Ditch Company                          |                |                         |                           |
| People's Weir (Canal)                           | Tulare         | 2 200                   | 3.5                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility   | County          | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|-----------------|-------------------------|---------------------------|
| San Luis Obispo County Flood Control & Water Conservation District |                 |                         |                           |
| Lopez Dam  | San Luis Obispo | 50                      | 0.4                       |
| Terminal Reservoir Inlet (Pipeline)                                | San Luis Obispo | 75                      | 0.6                       |
| Santa Barbara, City of<br>Gibraltar Dam                            | Santa Barbara   | 1 500                   | 4.0                       |
| Santa Clara Valley Water District                                  |                 |                         |                           |
| Anderson Lake<br>(Leroy Anderson Dam)                              | Santa Clara     | 500                     | 2.2                       |
| Calero Dam   | Santa Clara     | 100                     | 0.5                       |
| Coyote Dam   | Santa Clara     | 600                     | 1.3                       |
| Guadalupe Dam  | Santa Clara     | 60                      | 0.3                       |
| Lexington Dam  | Santa Clara     | 500                     | 2.9                       |
| Stevens Creek Dam  | Santa Clara     | 75                      | 0.3                       |
| Santa Monica, City of<br>Mount Olivette (Pipeline)                 | Los Angeles     | 150                     | 1.1                       |
| Semitropic Water Storage District<br>Semitropic Intake Canal       | Kern            | <u>1/</u>               | <u>1/</u>                 |
| Siskiyou County Flood Control & Water Conservation District        |                 |                         |                           |
| Lake Siskiyou (Box Canyon Dam)                                     | Siskiyou        | 6 000                   | 21.9                      |
| South Bay Irrigation District                                      |                 |                         |                           |
| Lake Loveland Dam  | San Diego       | 100                     | 0.5                       |
| Southern California Edison   |                 |                         |                           |
| Cardinal Power House   | Mono            | 2 500                   | 10.3                      |
| Lake Thomas A. Edison<br>(Vermillion Valley Dam)                   | Fresno          | 2 000                   | 8.6                       |
| Mono Creek Diversion Dam   | Fresno          | <u>1/</u>               | <u>1/</u>                 |
| South Fork Pit River Irrigation District                           |                 |                         |                           |
| West Valley Dam  | Modoc           | 900                     | 3.8                       |
| South San Joaquin Irrigation District                              |                 |                         |                           |
| Frankenheimer Drop (Canal)   | Stanislaus      | 4 700                   | 18.7                      |
| Parker Drop (Canal)  | San Joaquin     | 300                     | 0.8                       |
| Woodward Dam   | Stanislaus      | 2 300                   | 6.9                       |

1/ Insufficient data received

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility                                 | County      | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|-------------|-------------------------|---------------------------|
| Los Angeles County Flood Control District          |             |                         |                           |
| Alamitos Barrier (Dam)                             | Los Angeles | 300                     | 1.0                       |
| Big Dalton Dam                                     | Los Angeles | 50                      | 0.1                       |
| Big Tujunga No. 1 Dam                              | Los Angeles | 300                     | 1.3                       |
| Cogswell Dam                                       | Los Angeles | 500                     | 3.0                       |
| Dominguez Gap Barrier (Pipeline)                   | Los Angeles | 500                     | 2.0                       |
| Pacoima Dam  | Los Angeles | 400                     | 1.0                       |
| San Dimas Dam                                      | Los Angeles | 100                     | 0.3                       |
| San Gabriel Dam                                    | Los Angeles | 500                     | 3.0                       |
| Santa Anita Dam                                    | Los Angeles | 300                     | 0.7                       |
| West Coast Basin Barrier (Pipeline)                | Los Angeles | 500                     | 4.2                       |
| Lost Hills Water District                          |             |                         |                           |
| Eastside Pipeline                                  | Kern        | 1 000                   | 3.0                       |
| Mammoth County Water District                      |             |                         |                           |
| Lake Mary & Twin Lakes Open Diversion (Pipeline)   | Mono        | 300                     | 0.8                       |
| Marin Municipal Water District                     |             |                         |                           |
| Kent Lake (Peters Dam)                             | Marin       | 150                     | 0.4                       |
| Nicasio Dam  | Marin       | 400                     | 1.7                       |
| Merced Irrigation District                         |             |                         |                           |
| Buhach Drop (Canal)                                | Merced      | 60                      | 0.3                       |
| Canal Creek  | Merced      | 940                     | 3.6                       |
| Escaladian Headworks (Canal)                       | Merced      | 300                     | 1.2                       |
| Fairfield Drop (Canal)                             | Merced      | 900                     | 3.6                       |
| Fisher Drop (Canal)                                | Merced      | 75                      | 0.3                       |
| Lake Yosemite Dam                                  | Merced      | 1 200                   | 2.3                       |
| Richard B. Parker (on Main Canal)                  | Merced      | 2 800                   | 9.2                       |
| Youd Drop (Canal)                                  | Merced      | 100                     | 0.5                       |
| Metropolitan Water District of Southern California |             |                         |                           |
| Balboa (Pipeline)                                  | Orange      | 1 200                   | 9.1                       |
| Corona (Pipeline)                                  | Riverside   | 2 800                   | 18.0                      |
| Covina (Pipeline)                                  | Los Angeles | 2 500                   | 16.9                      |
| Coyote Creek (Pipeline)                            | Orange      | 2 900                   | 19.6                      |
| Perris Power Project (Pipeline)                    | Riverside   | 7 900                   | 40.3                      |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility   | County         | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|----------------|-------------------------|---------------------------|
| Metropolitan Water District of Southern California (Continued) |                |                         |                           |
| Rio Hondo (Pipeline)   | Los Angeles    | 2 000                   | 12.3                      |
| Robert A. Skinner Dam  | Riverside      | 1 400                   | 6.3                       |
| San Dimas (Pipeline)   | Los Angeles    | 9 900                   | 68.2                      |
| Santiago Creek (Pipeline)                                      | Orange         | 3 000                   | 15.6                      |
| Sepulveda Canyon (Pipeline)                                    | Los Angeles    | 8 600                   | 56.2                      |
| Temescal (Pipeline)  | Riverside      | 2 800                   | 18.0                      |
| Valley View (Pipeline)   | Orange         | 2 400                   | 14.2                      |
| Venice (Pipeline)  | Los Angeles    | 10 100                  | 60.0                      |
| Yorba Linda Feeder (Pipeline)                                  | Orange         | 5 100                   | 33.5                      |
| Modesto Irrigation District                                    |                |                         |                           |
| Canyon Creek Diversion Dam                                     | Trinity        | 1 060                   | 9.3                       |
| Modesto Reservoir (Dam)  | Stanislaus     | 1 000                   | 3.4                       |
| Stone Drop (Canal)   | Stanislaus     | 1 000                   | 4.0                       |
| Montague Water Conservation District                           |                |                         |                           |
| Lake Shastina (Shasta River Dam)                               | Siskiyou       | 200                     | 0.7                       |
| Pumping Plant Lower (Canal)                                    | Siskiyou       | 65                      | 0.2                       |
| Monte Vista County Water District                              |                |                         |                           |
| Benson Feeder Pipeline   | San Bernardino | <u>1/</u>               | <u>1/</u>                 |
| Montecito County Water District                                |                |                         |                           |
| Jameson Lake (Juncal Dam)                                      | Santa Barbara  | 60                      | 0.4                       |
| South Portal Doulton Tunnel                                    | Santa Barbara  | 200                     | 0.5                       |
| Monterey County Flood Control & Water Conservation District    |                |                         |                           |
| San Antonio Dam  | Monterey       | 6 000                   | 25.6                      |
| Napa, City of  |                |                         |                           |
| Lake Hennessey (Conn Creek Dam)                                | Napa           | 500                     | 2.3                       |
| Nevada Irrigation District                                     |                |                         |                           |
| Bowman Dam   | Nevada         | 3 000                   | 14.7                      |
| Combie Dam   | Nevada         | 1 000                   | 4.0                       |
| French Lake (Dam)  | Nevada         | 200                     | 0.8                       |
| Jackson Meadows Dam  | Nevada         | 4 000                   | 8.9                       |
| Scotts Flat Dam  | Nevada         | 1 300                   | 5.5                       |

1/ Insufficient data received

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility   | County         | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|----------------|-------------------------|---------------------------|
| Petan Company<br>Alisal Creek Dam  | Santa Barbara  | 50                      | 0.2                       |
| Placer County Water Agency<br>Hell Hole Reservoir<br>(Lower Hell Hole Dam)               | Placer         | 550                     | 3.0                       |
| Plumas County Flood Control & Water Conservation District<br>Lake Davis-Portola Pipeline | Plumas         | 60                      | 0.3                       |
| Rancho California Water District<br>Vail Dam   | Riverside      | 200                     | 0.9                       |
| Redlands, City of<br>Highland Avenue Pumping Plant<br>(Pipeline)                         | San Bernardino | 600                     | 2.6                       |
| Redlands Water Treatment Plant<br>(Pipeline)   | San Bernardino | 200                     | 0.9                       |
| Rock Creek Water District<br>Salt Spring Valley Reservoir (Dam)                          | Amador         | 90                      | 0.4                       |
| R. W. Akers<br>Tule Lake (Dam)   | Lassen         | 75                      | 0.3                       |
| Sacramento Municipal Utility District<br>Ice House Reservoir (Dam)                       | El Dorado      | 10 000                  | 22.0                      |
| Slab Creek Dam   | El Dorado      | 400                     | 3.0                       |
| San Bernardino Valley Municipal Water District<br>City Creek Turnout (Pipeline)          | San Bernardino | 2 000                   | 3.0                       |
| Lytle Creek Turnout (Pipeline)   | San Bernardino | 1 300                   | 7.8                       |
| Santa Ana Low Turnout (Pipeline)   | San Bernardino | 1 400                   | 3.8                       |
| Sweetwater Turnout (Pipeline)  | San Bernardino | 875                     | 2.2                       |
| Waterman Canyon Turnout (Pipeline)   | San Bernardino | 4 000                   | 7.0                       |
| San Diego, City of<br>Alvarado Treatment Plant<br>(Pipeline)                             | San Diego      | 1 700                   | 8.4                       |
| Barrett Dam  | San Diego      | 60                      | 0.2                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility   | County      | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|-------------|-------------------------|---------------------------|
| San Diego, City of (Continued)                             |             |                         |                           |
| Lake Hodges Dam  | San Diego   | 270                     | 1.2                       |
| Miramar Treatment Plant (Pipeline)                         | San Diego   | 1 300                   | 5.7                       |
| Point Loma Wastewater Treatment Plant (Pipeline)           | San Diego   | 1 200                   | 8.0                       |
| San Diego County Water Authority                           |             |                         |                           |
| San Vicente Reservoir (Pipeline)                           | San Diego   | 850                     | 3.4                       |
| San Dieguito Water District & Santa Fe Irrigation District |             |                         |                           |
| San Dieguito Treatment Plant (Pipeline)                    | San Diego   | 1 000                   | 4.5                       |
| Sweetwater Treatment Plant (Pipeline)                      | San Diego   | 1 400                   | 6.3                       |
| San Francisco, City and County of                          |             |                         |                           |
| Calaveras Dam  | Alameda     | 700                     | 3.2                       |
| Early Intake Dam   | Tuolumne    | 1 300                   | 8.7                       |
| Hetch Hetchy Reservoir (O'Shaughnessy Dam)                 | Tuolumne    | 1 600                   | 6.0                       |
| Lake Eleanor Dam   | Tuolumne    | 60                      | 0.3                       |
| Moccasin Lower Dam   | Tuolumne    | 1 600                   | 7.0                       |
| Pilarcitos Dam   | San Mateo   | 200                     | 0.8                       |
| San Gabriel Valley Municipal Water District                |             |                         |                           |
| Azusa Flow Control Structure (Pipeline)                    | Los Angeles | 740                     | 3.2                       |
| Big Dalton Pressure Reducing Station (Pipeline)            | Los Angeles | 280                     | 1.2                       |
| Emerald Pressure Reducing Station (Pipeline)               | Los Angeles | 340                     | 1.5                       |
| Etiwanda Pressure Reducing Station (Pipeline)              | Los Angeles | 250                     | 1.1                       |
| San Juan Suburban Water District                           |             |                         |                           |
| Sidney N. Peterson Water Treatment Plant (Pipeline)        | Placer      | 175                     | 0.4                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility  | County      | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|---|-------------|-------------------------|---------------------------|
| South Santa Clara Valley Water Conservation District                |             |                         |                           |
| Chesbro Reservoir (Elmer J. Chesbro Dam)                            | Santa Clara | 100                     | 0.2                       |
| Uvas Dam  | Santa Clara | 300                     | 1.0                       |
| South Sutter Water District   |             |                         |                           |
| Camp Far West Dam   | Placer      | 6 800                   | 26.9                      |
| South Tahoe Public Utility District                                 |             |                         |                           |
| Indian Creek Dam  | Alpine      | 50                      | 0.1                       |
| Thermalito Irrigation District & Table Mountain Irrigation District |             |                         |                           |
| Concow Dam  | Butte       | 130                     | 0.4                       |
| Tulare Lake Basin Water Storage District                            |             |                         |                           |
| Lateral A (Chute)   | Kings       | 1 600                   | 7.0                       |
| Lateral B (Chute)   | Kings       | 900                     | 4.0                       |
| Turlock Irrigation District   |             |                         |                           |
| Turlock Main Canal  |             |                         |                           |
| Canal Drop No. 2  | Stanislaus  | 700                     | 2.1                       |
| Canal Drop No. 6  | Stanislaus  | 900                     | 2.9                       |
| Canal Drop No. 7  | Stanislaus  | 700                     | 2.1                       |
| Ceres Spillway (Canal)  | Stanislaus  | 2 100                   | 4.5                       |
| Hickman Spillway (Canal)  | Stanislaus  | 2 100                   | 4.5                       |
| Upper Dawson Power Plant (Canal)                                    | Stanislaus  | 4 000                   | 15.9                      |
| United Water Conservation District                                  |             |                         |                           |
| Lake Piru (Santa Felicia Dam)                                       | Ventura     | 3 600                   | 7.8                       |
| U.S. Army Corps of Engineers  |             |                         |                           |
| Black Butte Dam   | Tehama      | 9 200                   | 31.3                      |
| Farmington Dam  | San Joaquin | 400                     | 2.0                       |
| Hensley Lake (Hidden Dam)   | Madera      | 1 300                   | 4.0                       |
| H. V. Eastman Lake (Buchanan Dam)                                   | Madera      | 3 000                   | 9.0                       |
| Isabella Dam  | Kern        | 8 000                   | 18.5                      |
| Lake Clementine (North Fork Dam)                                    | Placer      | 12 000                  | 63.5                      |
| Lake Kaweah (Terminus Dam)  | Tulare      | 4 000                   | 20.0                      |
| Lake Mendocino (Coyote Dam)   | Mendocino   | 4 000                   | 21.0                      |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility                       | County        | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|---------------|-------------------------|---------------------------|
| U.S. Army Corps of Engineers (Continued) |               |                         |                           |
| Lemoncove Ditch (At Terminus Dam)        | Tulare        | 650                     | 3.5                       |
| Martis Creek (Dam)                       | Nevada        | 250                     | 1.1                       |
| New Hogan Dam                            | Calaveras     | 2 250                   | 9.5                       |
| Success Dam                              | Tulare        | 4 000                   | 12.0                      |
| Warm Springs Dam                         | Sonoma        | 3 000                   | 15.0                      |
| U.S. Fish and Wildlife Service           |               |                         |                           |
| Doris Dam                                | Modoc         | 50                      | 0.1                       |
| U.S. Forest Service                      |               |                         |                           |
| Hume Lake (Dam)                          | Fresno        | 1 050                   | 4.6                       |
| Lost Creek Diversion Dam                 | Shasta        | 1 800                   | 10.0                      |
| U.S. Water and Power Resources Service   |               |                         |                           |
| All American Canal Drop No. 1            | Imperial      | 4 700                   | 27.0                      |
| All American Canal Drop No. 5            | Imperial      | 5 000                   | 24.0                      |
| Boca Dam                                 | Nevada        | 2 000                   | 5.6                       |
| Casitas Dam                              | Ventura       | 700                     | 2.0                       |
| Clear Lake (Dam)                         | Modoc         | 430                     | 1.9                       |
| East Park Dam                            | Colusa        | 900                     | 2.0                       |
| Folsom Lake Pipeline                     | Placer        | 500                     | 2.4                       |
| Jenkinson Lake (Sly Park Dam)            | El Dorado     | 650                     | 1.8                       |
| Lake Berryessa (Monticello Dam)          | Napa          | 16 000                  | 43.0                      |
| Los Banos Detention Dam                  | Merced        | 100                     | 0.5                       |
| Madera Canal                             |               |                         |                           |
| Station 980+65                           | Madera        | 2 000                   | 5.5                       |
| Station 1064+67                          | Madera        | 560                     | 1.9                       |
| Station 1910+60                          | Madera        | 650                     | 2.6                       |
| Millerton Lake (Friant Dam)              |               |                         |                           |
| Friant-Kern Canal                        | Fresno        | 15 000                  | 68.0                      |
| Madera Canal                             | Fresno        | 5 000                   | 23.0                      |
| San Joaquin River                        | Fresno        | 2 700                   | 10.0                      |
| New Siphon Drop (Canal)                  | Imperial      | 1 410                   | 11.3                      |
| North Portal Tecolote Tunnel             | Santa Barbara | 175                     | 0.7                       |
| Palo Verde Diversion Dam                 | Riverside     | 8 700                   | 65.0                      |
| Prosser Creek Dam                        | Nevada        | 1 000                   | 3.5                       |
| Red Bluff Diversion Dam                  | Tehama        | 14 000                  | 70.0                      |
| Stampede Dam                             | Sierra        | 3 000                   | 17.0                      |
| Stony Gorge Dam                          | Glenn         | 6 000                   | 18.0                      |
| Whiskeytown Dam                          | Shasta        | 3 000                   | 12.5                      |
| Vallejo, City of                         |               |                         |                           |
| Cache Slough (Pipeline)                  | Napa          | 600                     | 4.1                       |
| Lake Curry (Pipeline)                    | Napa          | 50                      | 0.3                       |

## Section A-1

Table A-1. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Owner and Facility   | County    | Estimated Capacity (kW) | Estimated Energy (GWh/yr) |
|--|-----------|-------------------------|---------------------------|
| Ventura County Flood Control District<br>Matilija Dam                                    | Ventura   | 700                     | 2.0                       |
| Vista Irrigation District<br>Henshaw Dam   | San Diego | 200                     | 1.0                       |
| Whitewater Canyon Mutual Water Company<br>Whitewater Canyon Irrigation System (Pipeline) | Riverside | 400                     | 2.5                       |
| Yolo County Flood Control & Water Conservation District                                  |           |                         |                           |
| Clear Lake Impounding Dam  | Lake      | 2 000                   | 7.5                       |
| Indian Valley Dam  | Lake      | 3 200                   | 7.2                       |
| Yuba County Water Agency<br>Hour House Dam   | Nevada    | 100                     | 0.3                       |



SECTION A-2

(Table A-2)

## Section A-2

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California

(Alphabetical by Facility Name)

| Facility                                | Owner  | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head  |      | Flow  |       |
|---|--|-----------------------|---------------|-----------------|-------|------|-------|-------|
|   |  |                       |               |                 | (m)   | (ft) | (cms) | (cfs) |
| ACID Diversion Dam                      | (See Lake Redding)                                 |                       |               |                 |       |      |       |       |
| Alamo Drop 3A (Canal)                   | Imperial Irrigation District                       | 2                     | 1 200         | 6.7             | 4.6   | 15   | 31.2  | 1,100 |
| Alamitos Barrier (Dam)                  | Los Angeles County Flood Control District          | 1                     | 300           | 1.0             | 73.2  | 240  | 0.5   | 17    |
| Allisal Creek Dam                       | Petan Company                                      | 1                     | 50            | 0.2             | 25.9  | 85   | 0.2   | 8     |
| All-American Canal Drop No. 1           | U. S. Water and Power Resources Service            | 2                     | 4 700         | 27.0            | 3.4   | 11   | 169.9 | 6,000 |
| All-American Canal Drop No. 5           | U. S. Water and Power Resources Service            | 2                     | 5 000         | 24.0            | 7.0   | 23   | 85.0  | 3,000 |
| Alvarado Treatment Plant (Pipeline)     | City of San Diego                                  | 2                     | 1 700         | 8.4             | 48.8  | 160  | 4.2   | 150   |
| Anderson Flume Diversion (Canal)        | Anderson-Corttonwood Irrigation District           | 2                     | 50            | 0.2             | 7.0   | 23   | 1.0   | 35    |
| Anderson Lake (Leroy Anderson Dam)      | Santa Clara Valley Water District                  | 2                     | 500           | 2.2             | 38.1  | 125  | 1.4   | 50    |
| Antelope Dam                            | California Department of Water Resources           | 2                     | 450           | 1.4             | 22.9  | 75   | 2.4   | 85    |
| Anthony House Dam                       | Lake Wildwood Association                          | 1                     | 50            | 0.2             | 21.3  | 70   | 0.3   | 10    |
| Ash Main Canal                          | Chowchilla Water District                          | 1                     | 150           | 0.7             | 2.4   | 8    | 7.4   | 260   |
| Azusa Flow Control Structure (Pipeline) | San Gabriel Valley Municipal Water District        | 2                     | 740           | 3.2             | 91.4  | 300  | 1.0   | 35    |
| Balboa (Pipeline)                       | Metropolitan Water District of Southern California | 2,5                   | 1 200         | 9.1             | 6.7   | 22   | 19.8  | 700   |
| Barret Dam                              | City of San Diego                                  | 1                     | 60            | 0.2             | 21.3  | 70   | 0.3   | 12    |
| Bear Valley Powerplant (Rehabilitation) | Escondido Mutual Water Company                     | 2,5                   | 700           | 3.7             | 146.3 | 480  | 0.7   | 25    |
| Bearslley Canal Control Structure       | City of Bakersfield, et al                         | 3                     | 260           | 1.1             | 1.8   | 6    | 17.0  | 600   |
| Bearslley Diversion Structure (Canal)   | City of Bakersfield, et al                         | 2,3                   | 500           | 1.7             | 1.5   | 5    | 42.5  | 1,500 |

1. Status Unknown
2. Appraisal or Feasibility Study Completed
3. Application Filed for FERC Preliminary Permit
4. FERC Preliminary Permit Issued
5. Application Filed for FERC Exemption or License
6. FERC Exemption or License Issued
7. Under Construction
8. Insufficient Data Received

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility  | Owner   | Status of Development | Capacity (kw) | Energy (GWh/yr) | Head  |      | Flow (cfs) |
|---|---|-----------------------|---------------|-----------------|-------|------|------------|
|   |   |                       |               |                 | (m)   | (ft) |            |
| Benson Feeder Pipeline                          | Monte Vista County Water District                           | 1                     | 8/            | 8/              | 8/    | 8/   | 8/         |
| Big Creek Hydraulic Plant (Rehabilitation)      | Lockhead Missiles and Space Company, Inc.                   | 2                     | 800           | 3.0             | 298.7 | 980  | 0.3 12     |
| Big Dalton Dam                                  | Los Angeles County Flood Control District                   | 1                     | 50            | 0.1             | 25.9  | 85   | 1.0 8      |
| Big Dalton Pressure Reducing Station (Pipeline) | San Gabriel Valley Municipal Water District                 | 2                     | 280           | 1.2             | 35.1  | 115  | 1.0 35     |
| Big Sage Dam                                    | Hot Springs Valley Irrigation District                      | 1                     | 175           | 0.7             | 13.7  | 45   | 1.5 52     |
| Big Tujunga No. 1 Dam                           | Los Angeles County Flood Control District                   | 1                     | 300           | 1.3             | 39.6  | 130  | 0.8 30     |
| Black Butte Dam                                 | U. S. Army Corps of Engineers                               | 2,4                   | 9 200         | 31.3            | 24.4  | 80   | 45.3 1,600 |
| Boca Dam  | U. S. Water and Power Resources Service (See Lake Siskiyou) | 2,4                   | 2 000         | 5.6             | 27.4  | 90   | 8.8 310    |
| Box Canyon Dam                                  | Nevada Irrigation District                                  | 2                     | 3 000         | 14.7            | 40.8  | 134  | 8.5 300    |
| Bowman Dam                                      | Georgetown Divide Public Utility District                   | 2                     | 350           | 2.4             | 54.9  | 180  | 0.8 27     |
| Buckeye Conduit                                 | Pacific Gas and Electric Company                            | 1                     | 740           | 3.2             | 30.5  | 100  | 2.8 100    |
| Bucks Lake (Bucks Storage Dam)                  | Georgetown Divide Public Utility District                   | 1                     | 160           | 0.5             | 33.5  | 110  | 0.6 20     |
| Burrito Hill Siphon (Pipeline)                  | Merced Irrigation District                                  | 1                     | 60            | 0.3             | 0.9   | 3    | 8.5 300    |
| Buhach Drop (Canal)                             | (See H.V. Eastman Lake)                                     |                       |               |                 |       |      |            |
| Buchanan Dam                                    | (See Bucks Lake)  |                       |               |                 |       |      |            |
| Bucks Storage Dam                               | City of Vallejo   | 1                     | 600           | 4.1             | 85.3  | 280  | 0.8 30     |
| Cache Slough (Pipeline)                         | City and County of San Francisco                            | 1                     | 700           | 3.2             | 45.7  | 150  | 1.8 65     |
| Calaveras Dam                                   | Santa Clara Valley Water District                           | 1                     | 100           | 0.5             | 27.4  | 90   | 0.4 15     |
| Calero Dam                                      | Chowchilla Water District                                   | 1                     | 200           | 0.9             | 4.6   | 15   | 5.2 185    |
| Califa Canal                                    | East Bay Municipal Utility District                         | 5                     | 10 680        | 35.0            | 45.7  | 150  | 28.3 1,000 |
| Camanche Dam (Lower Mokelumne River Project)    | South Surter Water District                                 | 5                     | 6 800         | 26.9            | 41.1  | 135  | 19.8 700   |
| Camp Far West Dam                               | Merced Irrigation District (See Turlock Main Canal)         | 2,6                   | 940           | 3.6             | 9.8   | 32   | 10.8 380   |
| Canal Creek                                     | Modesto Irrigation District                                 | 3                     | 1 060         | 9.3             | 167.6 | 550  | 0.8 27     |
| Canyon Creek Diversion Dam                      | Goleta County Water District                                | 1                     | 700           | 1.6             | 109.7 | 360  | 0.8 27     |
| Carneros Power Project (Pipeline)               | Southern California Edison                                  | 2                     | 2 500         | 10.3            | 8/    |      |            |
| Cardinal Power House                            | (See Rocky Point Diversion Dam)                             |                       |               |                 |       |      |            |
| Carrier Canal Project                           | U. S. Water and Power Resources Service                     | 1                     | 700           | 2.0             | 76.2  | 250  | 1.1 40     |
| Casitas Dam                                     | California Department of Water Resources                    | 2                     | 275           | 1.4             | 91.4  | 300  | 0.4 15     |
| Casitas Dam                                     |   |                       |               |                 |       |      |            |

See footnotes on first page

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility                                    | Owner   | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head  |       | Flow  |       |
|---|---|-----------------------|---------------|-----------------|-------|-------|-------|-------|
|   |   |                       |               |                 | (m)   | (ft)  | (cms) | (cfs) |
| Central Amador Water Project                | Amador County Water Agency  | 2                     | 250           | 0.7             | 365.8 | 1,200 | 0.1   | 3     |
| Ceres Spillway (Canal)                      | Turlock Irrigation District   | 1                     | 2 100         | 4.5             | 13.7  | 45    | 19.8  | 700   |
| Chesbro Reservoir<br>(Elmer J. Chesbro Dam) | South Santa Clara Valley Water<br>and Conservation District                   | 2                     | 100           | 0.2             | 18.3  | 60    | 0.7   | 25    |
| Chowchilla Main Canal<br>Station 0+00       | Chowchilla Water District   | 2                     | 250           | 1.1             | 2.1   | 7     | 14.2  | 500   |
| Station 101+80                              | Chowchilla Water District   | 2                     | 250           | 1.1             | 3.0   | 10    | 9.9   | 350   |
| Station 175+00                              | Chowchilla Water District   | 2                     | 250           | 1.1             | 3.0   | 10    | 9.9   | 350   |
| City Creek Turnout (Pipeline)               | San Bernardino Valley Municipal<br>Water District                             | 1                     | 2 000         | 3.0             | 137.2 | 450   | 1.8   | 63    |
| Clear Lake Dam                              | U. S. Water and Power Resources Service                                       | 1                     | 430           | 1.9             | 8.2   | 27    | 6.2   | 220   |
| Clear Lake Impounding Dam                   | Yolo County Flood Control<br>and Water Conservation District                  | 2                     | 2 000         | 7.5             | 9.1   | 30    | 26.9  | 950   |
| Cogswell Dam                                | Los Angeles County Flood Control District                                     | 1                     | 500           | 3.0             | 54.9  | 180   | 1.1   | 40    |
| Combe Dam                                   | Nevada Irrigation District  | 2,4                   | 1 000         | 4.0             | 21.3  | 70    | 5.7   | 200   |
| Concow Dam                                  | Thermalito Irrigation District  |                       |               |                 |       |       |       |       |
| Conejo Pump Station (Pipeline)              | and Table Mountain Irrigation District  | 1                     | 130           | 0.5             | 25.9  | 85    | 0.6   | 21    |
| Conn Creek Dam                              | Calleguas Municipal Water District  | 2                     | 600           | 3.0             | 51.8  | 170   | 1.4   | 50    |
| Corona (Pipeline)                           | (See Lake Hennessey)<br>Metropolitan Water District of<br>Southern California | 2,5                   | 2 800         | 18.0            | 41.1  | 135   | 8.5   | 300   |
| Cottonwood No. 1 (Canal)                    | California Department of Water Resources                                      | 2,7                   | 17 000        | 115.0           | 41.1  | 135   | 48.1  | 1,700 |
| Cottonwood No. 2 (Canal)                    | California Department of Water Resources                                      | 2                     | 12 000        | 90.0            | 38.1  | 125   | 36.8  | 1,300 |
| Covina (Pipeline)                           | Metropolitan Water District of<br>Southern California                         | 2,5                   | 2 500         | 16.9            | 61.0  | 200   | 5.0   | 175   |
| Coyote Creek (Dam)                          | Hidden Valley Lake Association  | 1                     | 90            | 0.4             | 25.9  | 85    | 0.4   | 15    |
| Coyote Creek (Pipeline)                     | Metropolitan Water District of<br>Southern California                         | 2,5                   | 2 900         | 19.6            | 67.1  | 220   | 5.0   | 175   |
| Coyote Dam                                  | (See Lake Mendocino)  |                       |               |                 |       |       |       |       |
| Coyote Dam                                  | Santa Clara Valley Water District   | 2                     | 600           | 1.3             | 30.5  | 100   | 2.3   | 80    |
| Dahilla Drop (Canal)                        | Imperial Irrigation District  | 1                     | 225           | 1.0             | 2.7   | 9     | 9.9   | 350   |
| Deer Creek Collection Pipeline              | Cucamonga County Water District   | 1                     | 200           | 1.0             | 213.4 | 700   | 0.1   | 4     |

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility                                     | Owner                                       | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head (m) | Head (ft) | Flow (cms) | Flow (cfs) |
|--|---|-----------------------|---------------|-----------------|----------|-----------|------------|------------|
| Del Loma (Trinity) Tunnel                    | George Costa                                | 2,3                   | 250           | 1.9             | 3.4      | 11        | 8.5        | 300        |
| Del Valle Stream Release (Dam)               | California Department of Water Resources    | 2                     | 400           | 1.1             | 36.6     | 120       | 1.4        | 50         |
| Dodge Ave Check (Canal)                      | Orange Cove Irrigation District             | 2                     | 475           | 2.4             | 1.8      | 6         | 42.5       | 1,500      |
| Dominguez Gap Barrier (Pipeline)             | Los Angeles County Flood Control District   | 1                     | 500           | 2.0             | 103.6    | 340       | 0.6        | 20         |
| Doris Dam                                    | U. S. Fish and Wildlife Service             | 1                     | 50            | 0.1             | 6.7      | 22        | 0.9        | 32         |
| Earlly Intake Dam                            | City and County of San Francisco            | 1                     | 1 300         | 8.7             | 15.2     | 50        | 10.6       | 375        |
| East Highline Canal Turnout                  | Imperial Irrigation District                | 1                     | 1 800         | 10.0            | 3.4      | 11        | 66.1       | 2,335      |
| East Park Dam                                | U. S. Water and Power Resources Service     | 3                     | 900           | 2.0             | 19.8     | 65        | 5.4        | 190        |
| Eastside Pipeline                            | Lost Hills Water District                   | 1                     | 1 000         | 3.0             | 15.2     | 50        | 8.5        | 300        |
| El Dorado Distribution System (Pipelines)    |   |                       |               |                 |          |           |            |            |
| Reservoir A                                  | El Dorado Irrigation District               | 1                     | 750           | 3.2             | 45.7     | 150       | 1.9        | 68         |
| Reservoir B                                  | El Dorado Irrigation District               | 2                     | 50            | 0.2             | 36.6     | 120       | 0.2        | 6          |
| Reservoir 2A                                 | El Dorado Irrigation District               | 1                     | 480           | 2.1             | 51.8     | 170       | 1.1        | 40         |
| Reservoir 2A-3                               | El Dorado Irrigation District               | 2                     | 360           | 1.6             | 36.6     | 120       | 1.2        | 42         |
| Reservoir 3                                  | El Dorado Irrigation District               | 1                     | 200           | 0.9             | 36.6     | 120       | 0.7        | 23         |
| Reservoir 4                                  | El Dorado Irrigation District               | 1                     | 70            | 0.3             | 36.6     | 120       | 0.2        | 8          |
| Reservoir 5                                  | El Dorado Irrigation District               | 1                     | 60            | 0.3             | 36.6     | 120       | 0.2        | 7          |
| Reservoir 6                                  | El Dorado Irrigation District               | 1                     | 80            | 0.3             | 36.6     | 120       | 0.3        | 9          |
| Reservoir 8                                  | El Dorado Irrigation District               | 1                     | 175           | 0.8             | 36.6     | 120       | 0.6        | 20         |
| Reservoir 9A                                 | El Dorado Irrigation District               | 1                     | 175           | 0.8             | 36.6     | 120       | 0.6        | 20         |
| Reservoir 9B                                 | El Dorado Irrigation District               | 1                     | 90            | 0.4             | 36.6     | 120       | 0.3        | 10         |
| Reservoir 10A                                | El Dorado Irrigation District               | 1                     | 175           | 0.8             | 36.6     | 120       | 0.6        | 20         |
| Reservoir 10B                                | El Dorado Irrigation District               | 1                     | 60            | 0.3             | 36.6     | 120       | 0.2        | 7          |
| El Segundo Distribution System (Pipeline)    | City of El Segundo                          | 2                     | 500           | 3.9             | 76.2     | 250       | 0.8        | 28         |
| Emerald Pressure Reducing Station (Pipeline) | San Gabriel Valley Municipal Water District | 2                     | 340           | 1.5             | 42.7     | 140       | 1.0        | 35         |
| Elmer J. Chesbro Dam                         | (See Chesbro Reservoir)                     |                       |               |                 |          |           |            |            |
| Escalante Headworks (Canal)                  | Merced Irrigation District                  | 2,6                   | 300           | 1.2             | 4.6      | 15        | 7.9        | 280        |
| Erlanda Pressure Reducing Station (Pipeline) | San Gabriel Valley Municipal Water District | 2                     | 250           | 1.1             | 30.5     | 100       | 1.0        | 35         |

## Section A-2

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Facility                                   | Owner  | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head (m) | Head (ft) | Flow (cms) | Flow (cfs) |
|--|--|-----------------------|---------------|-----------------|----------|-----------|------------|------------|
| Fairfield Drop (Canal)                     | Merced Irrigation District                       | 2, 6                  | 900           | 3.6             | 9.4      | 31        | 11.9       | 420        |
| Farmington Dam                             | U. S. Army Corps of Engineers                    | 1                     | 400           | 2.0             | 16.8     | 55        | 2.8        | 100        |
| Fisher Drop (Canal)                        | Merced Irrigation District                       | 1                     | 75            | 0.3             | 1.2      | 4         | 7.4        | 260        |
| Folsom Lake Pipeline                       | U. S. Water and Power Resources Service          | 2, 4                  | 500           | 2.4             | 7.6      | 25        | 7.9        | 280        |
| Frankenhelm Drop (Canal)                   | South San Joaquin Irrigation District            | 2, 5                  | 4             | 18.7            | 23.8     | 78        | 25.5       | 900        |
| Franklin Inlet (Pipeline)                  | City of Los Angeles                              | 1                     | 800           | 6.8             | 30.5     | 100       | 3.1        | 110        |
| French Lake (Dam)                          | Nevada Irrigation District                       | 1                     | 200           | 0.8             | 22.9     | 75        | 1.1        | 40         |
| Frenchman Dam                              | California Department of Water Resources         | 2                     | 450           | 1.0             | 31.7     | 104       | 1.8        | 65         |
| Fresno Main Canal                          |  |                       |               |                 |          |           |            |            |
| Headworks                                  | Fresno Irrigation District                       | 1                     | 650           | 2.6             | 3.0      | 10        | 25.5       | 900        |
| Boos Check                                 | Fresno Irrigation District                       | 1                     | 650           | 2.6             | 3.0      | 10        | 25.5       | 900        |
| Dresser Check                              | Fresno Irrigation District                       | 1                     | 650           | 2.6             | 3.0      | 10        | 25.5       | 900        |
| Friant Dam                                 | (See Millerton Lake)                             |                       |               |                 |          |           |            |            |
| Gibraltar Dam                              | City of Santa Barbara                            | 3                     | 1 500         | 4.0             | 42.7     | 140       | 4.2        | 150        |
| Glendale Distribution System (Pipeline)    | City of Glendale                                 | 2                     | 400           | 2.0             | 61.0     | 200       | 0.8        | 28         |
| Goodwin Dam                                | Okdale and South San Joaquin Irrigation District | 2, 3                  | 970           | 5.0             | 3.0      | 10        | 34.0       | 1,200      |
| Gould Weir Diversion Dam                   | Fresno Irrigation District                       | 2                     | 850           | 3.5             | 1.8      | 6         | 56.6       | 2,000      |
| Grant Lake (Dam)                           | City of Los Angeles                              | 1                     | 1 500         | 3.0             | 19.2     | 63        | 9.9        | 350        |
| Grizzly Valley Dam                         | (See Lake Davis)                                 |                       |               |                 |          |           |            |            |
| Guadalupe Dam                              | Santa Clara Valley Water District                | 1                     | 60            | 0.3             | 33.5     | 110       | 0.2        | 8          |
| Harding Canal                              | Browns Valley Irrigation District                | 2, 4                  | 1 000         | 6.6             | 91.4     | 300       | 1.4        | 50         |
| Hell Hole Reservoir (Lower Hell Hole Dam)  | Placer County Water District                     | 2, 5                  | 550           | 3.0             | 91.4     | 300       | 0.7        | 25         |
| Henshaw Dam                                | Vista Irrigation District                        | 1                     | 200           | 1.0             | 33.5     | 110       | 0.1        | 25         |
| Hensley Lake (Hidden Dam)                  | U. S. Army Corps of Engineers                    | 4                     | 1 300         | 4.0             | 30.5     | 100       | 5.9        | 210        |
| Hetch Hetchy Reservoir (O'Shaughnessy Dam) | City and County of San Francisco                 | 2                     | 1 600         | 6.0             | 91.4     | 300       | 2.1        | 75         |
| Hickman Spillway                           | Turlock Irrigation District                      | 1                     | 2 100         | 4.5             | 13.7     | 45        | 19.8       | 700        |
| Hidden Dam                                 | (See Hensley Lake)                               |                       |               |                 |          |           |            |            |
| Highland Avenue Pumping Plant (Pipeline)   | City of Redlands                                 | 2                     | 600           | 2.6             | 152.4    | 500       | 0.5        | 17         |

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility                            | Owner   | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head  |      | Flow  |       |
|-------------------------------------|---|-----------------------|---------------|-----------------|-------|------|-------|-------|
|                                     |   |                       |               |                 | (m)   | (ft) | (cms) | (cfs) |
| Hour House Dam                      | Yuba County Water Agency                                    | 1                     | 100           | 0.3             | 9.1   | 30   | 1.4   | 50    |
| Hume Lake (Dam)                     | U. S. Forest Service  | 4                     | 1 050         | 4.6             | B/    |      |       | B/    |
| H.V. Eastman Lake (Buchanan Dam)    | U. S. Army Corps of Engineers                               | 4                     | 3 000         | 9.0             | 41.1  | 135  | 8.8   | 310   |
| Ice House Reservoir (Dam)           | Sacramento Municipal Utility District                       | 2                     | 10 000        | 22.0            | 167.6 | 550  | 6.8   | 240   |
| Indian Creek Dam                    | South Tahoe Public Utility District                         | 1                     | 50            | 0.1             | 6.1   | 20   | 1.1   | 40    |
| Indian Valley Dam                   | Yolo County Flood Control & Water Conservation District     | 2                     | 3 200         | 7.2             | 17.1  | 56   | 22.5  | 795   |
| Irvine Lake Pipeline                | Irving Ranch Water District                                 | 2                     | 500           | 1.0             | 67.1  | 220  | 0.8   | 30    |
| Isabella Dam                        | U. S. Army Corps of Engineers                               | 3                     | 13 000        | 45.0            | 39.6  | 130  | 39.6  | 1,400 |
| Jackson Creek Dam                   | (See Lake Anador)   |                       |               |                 |       |      |       |       |
| Jackson Meadows Dam                 | Nevada Irrigation District                                  | 2                     | 4 000         | 8.9             | 51.8  | 170  | 8.5   | 300   |
| Jackson-Sutter Creek                | Anador County Water Agency                                  | 1                     | 60            | 0.2             | 85.3  | 280  | 0.1   | 3     |
| Outfall Pipeline                    |   |                       |               |                 |       |      |       |       |
| Jameson Lake (Juncal Dam)           | Montecito County Water District                             | 1                     | 60            | 0.4             | 85.3  | 280  | 0.1   | 3     |
| Jankinson Lake (Sly Park Dam)       | U. S. Water and Power Resources Service                     | 2,3                   | 650           | 1.8             | 44.2  | 145  | 1.8   | 65    |
| Juncal Dam                          | (See Jameson Lake)  |                       |               |                 |       |      |       |       |
| Kaiser Pipeline                     | Georgetown Divide Public Utility District                   | 1                     | 120           | 0.3             | 33.8  | 111  | 0.4   | 15    |
| Kent Lake (Peters Dam)              | Marin Municipal Water District                              | 1                     | 150           | 0.4             | 64.0  | 210  | 3.0   | 10    |
| Kern Island Canal Control Structure | City of Bakersfield, et al                                  | 1                     | 700           | 3.1             | 2.4   | 8    | 34.0  | 1,200 |
| Lake Anador (Jackson Creek Dam)     | Jackson Valley Irrigation District                          | 2                     | 350           | 2.5             | 51.2  | 168  | 0.8   | 30    |
| Lake Arrowhead Dam                  | Arrowhead Lake Association                                  | 1                     | 75            | 0.3             | 54.9  | 180  | 0.2   | 6     |
| Lake Berryessa (Monticello Dam)     | U. S. Water and Power Resources Service                     | 2,5                   | 16 000        | 43.0            | 61.0  | 200  | 31.1  | 1,100 |
| Lake Clementine (North Fork Dam)    | U. S. Army Corps of Engineers                               | 3                     | 11 000        | 60.0            | 36.6  | 120  | 36.0  | 1,275 |
| Lake Curry (Pipeline)               | City of Vallejo   | 1                     | 50            | 0.3             | 76.2  | 250  | 0.2   | 3     |
| Lake Davis (Grizzly Valley Dam)     | California Department of Water Resources                    | 2                     | 510           | 1.5             | 33.5  | 110  | 1.8   | 65    |
| Lake Davis - Portola Pipeline       | Plumas County Flood Control and Water Conservation District | 1                     | 60            | 0.3             | 152.4 | 500  | 0.1   | 2     |
| Lake Eleanor Dam                    | City of San Francisco                                       | 1                     | 60            | 0.3             | 16.8  | 55   | 0.4   | 15    |
| Lake Fordyce Dam                    | Pacific Gas and Electric Company                            | 1                     | 900           | 4.0             | 36.6  | 120  | 3.0   | 105   |
| Lake Hemet Dam                      | Lake Hemet Municipal Water District                         | 1                     | 75            | 0.1             | 25.9  | 85   | 0.3   | 12    |

See footnotes on first page

## Section A-2

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility   | Owner  | Status of Development | Capacity (kw) | Energy (GWh/yr) | Head (m) (ft) | Flow (cms) (cfs) |
|--|--|-----------------------|---------------|-----------------|---------------|------------------|
| Lake Hennessey (Conn Creek Dam)                    | City of Napa   | 1                     | 500           | 2.3             | 33.5 110      | 1.8 65           |
| Lake Hodges Dam                                    | City of San Diego  | 1                     | 270           | 1.2             | 18.6 61       | 1.7 61           |
| Lake Kaweah (Terminus Dam)                         | U. S. Army Corps of Engineers  | 1                     | 4 000         | 20.0            | 48.8 160      | 9.9 350          |
| Lake Loveland Dam                                  | South Bay Irrigation District  | 1                     | 100           | 0.5             | 43.6 143      | 0.3 10           |
| Lake Mary and Twin Lakes Open Diversion (Pipeline) | Mammoth County Water District  | 1                     | 300           | 0.8             | 304.8 1,000   | 0.1 5            |
| Lake Mendocino (Coyote Dam)                        | U. S. Army Corps of Engineers  | 2, 4                  | 4 000         | 21.0            | 33.5 110      | 14.2 500         |
| Lake Pillsbury (Scott Dam)                         | Pacific Gas and Electric Company                                     | 3                     | 5 000         | 15.0            | 35.1 115      | 9.6 340          |
| Lake Piru (Santa Felicia Dam)                      | United Water Conservation District                                   | 3                     | 3 600         | 7.8             | 57.9 190      | 7.5 285          |
| Lake Redding (ACID Diversions Dam)                 | Anderson-Cottonwood Irrigation District                              | 2, 4                  | 14 500        | 79.0            | 4.3 14        | 424.8 15,000     |
| Lake Shastina (Shasta River Dam)                   | Montague Water Conservation District                                 | 2                     | 200           | 0.7             | 15.2 50       | 1.7 60           |
| Lake Siskiyou (Box Canyon Dam)                     | Siskiyou County Flood Control and Water Conservation District        | 2, 4                  | 6 000         | 21.9            | 56.4 185      | 12.7 450         |
| Lake Thomas A. Edison (Vermillion Valley Dam)      | Southern California Edison   | 1                     | 2 000         | 9.6             | 42.7 140      | 5.7 200          |
| Lake Valley Dam                                    | Pacific Gas and Electric Company                                     | 1                     | 75            | 0.3             | 19.8 65       | 0.5 16           |
| Lake Yosemite Dam                                  | Merced Irrigation District   | 1                     | 1 200         | 2.3             | 12.2 40       | 12.2 430         |
| Las Flores Turnout (Pipeline)                      | California Department of Water Resources                             | 2                     | 210           | 0.7             | 67.1 220      | 0.4 13           |
| Lateral A (Chute)                                  | Tulare Lake Basin Water Storage District                             | 1                     | 1 600         | 7.0             | 16.8 55       | 11.3 400         |
| Lateral B (Chute)                                  | Tulare Lake Basin Water Storage District                             | 1                     | 900           | 4.0             | 9.8 32        | 11.3 400         |
| Lemoncove Ditch (At Terminus Dam)                  | U. S. Army Corps of Engineers (See Anderson Lake)                    | 2                     | 650           | 3.5             | 48.8 160      | 1.6 57           |
| Leroy Anderson Dam                                 | Santa Clara Valley Water District                                    | 1                     | 500           | 2.9             | 45.7 150      | 1.3 45           |
| Lexington Dam                                      | Palmdele Water District  | 1                     | 50            | 0.2             | 32.0 105      | 0.2 7            |
| Littlerock Dam                                     | San Luis Obispo County Flood Control and Water Conservation District | 1                     | 50            | 0.4             | 38.1 125      | 0.2 6            |
| Lopez Dam  |  |                       |               |                 |               |                  |
| Los Angeles Distribution System (Pipelines)        |  |                       |               |                 |               |                  |
| Location 1   | City of Los Angeles  | 1                     | 610           | 3.3             | 106.7 350     | 0.7 24           |
| Location 2   | City of Los Angeles  | 1                     | 270           | 2.2             | 39.6 130      | 0.8 29           |

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility                       | Owner  | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head  |      | Flow  |       |
|--------------------------------|--|-----------------------|---------------|-----------------|-------|------|-------|-------|
|                                |  |                       |               |                 | (m)   | (ft) | (cms) | (cfs) |
| Location 3                     | City of Los Angeles                            | 1                     | 420           | 2.1             | 36.6  | 120  | 1.4   | 49    |
| Location 4                     | City of Los Angeles                            | 1                     | 270           | 1.8             | 61.0  | 200  | 0.5   | 19    |
| Location 5                     | City of Los Angeles                            | 1                     | 140           | 1.2             | 39.6  | 130  | 0.4   | 15    |
| Location 6                     | City of Los Angeles                            | 1                     | 190           | 1.1             | 91.4  | 300  | 0.3   | 9     |
| Location 7                     | City of Los Angeles                            | 1                     | 120           | 1.0             | 48.8  | 160  | 0.3   | 10    |
| Location 8                     | City of Los Angeles                            | 1                     | 130           | 0.8             | 38.1  | 125  | 0.4   | 14    |
| Location 9                     | City of Los Angeles                            | 1                     | 70            | 0.6             | 64.0  | 210  | 0.1   | 5     |
| Location 10                    | City of Los Angeles                            | 1                     | 100           | 0.6             | 48.8  | 160  | 0.3   | 9     |
| Location 11                    | City of Los Angeles                            | 1                     | 70            | 0.6             | 21.3  | 70   | 0.4   | 14    |
| Location 12                    | City of Los Angeles                            | 1                     | 100           | 0.6             | 73.2  | 240  | 0.2   | 6     |
| Location 13                    | City of Los Angeles                            | 1                     | 60            | 0.5             | 27.4  | 90   | 0.3   | 9     |
| Location 14                    | City of Los Angeles                            | 1                     | 60            | 0.5             | 30.5  | 100  | 0.2   | 8     |
| Location 15                    | City of Los Angeles                            | 1                     | 1 000         | 8.2             | 11.9  | 39   | 10.2  | 360   |
| Location 16                    | City of Los Angeles                            | 1                     | 1 800         | 9.0             | 29.6  | 97   | 7.4   | 260   |
| Los Angeles Reservoir (Dam)    | City of Los Angeles                            | 1                     | 6 200         | 37.0            | 33.5  | 110  | 22.7  | 800   |
| Los Banos Detention Dam        | U. S. Water and Power Resources Service        | 1                     | 100           | 0.5             | 38.7  | 127  | 0.3   | 12    |
| Los Padres Dam                 | California American Water Company              | 1                     | 75            | 0.3             | 39.6  | 130  | 0.2   | 8     |
| Lost Creek Diversion Dam       | U. S. Forest Service                           | 3                     | 1 800         | 10.0            | 94.5  | 310  | 2.3   | 81    |
| Lower Hell Hole Dam            | (See Hell Hole Reservoir)                      |                       |               |                 |       |      |       |       |
| Lower Mokelumne River Project  | (See Camanche Dam)                             |                       |               |                 |       |      |       |       |
| Lyons Dam                      | Pacific Gas and Electric Company               | 2                     | 300           | 1.5             | 29.0  | 95   | 1.3   | 45    |
| Lytle Creek Turnout (Pipeline) | San Bernardino Valley Municipal Water District | 2,4                   | 1 300         | 7.8             | 100.6 | 330  | 1.5   | 55    |
| Madera Canal                   |  |                       |               |                 |       |      |       |       |
| Station 980+65                 | U. S. Water and Power Resources Service        | 2                     | 2 000         | 5.5             | 8.5   | 28   | 28.3  | 1,000 |
| Station 1064+67                | U. S. Water and Power Resources Service        | 2                     | 560           | 1.9             | 30.4  | 10   | 22.7  | 800   |
| Station 1910+60                | U. S. Water and Power Resources Service        | 2                     | 690           | 2.6             | 7.0   | 23   | 11.3  | 400   |
| Maillard Reservoir (Pipeline)  | Contra Costa County Water District             | 1                     | 200           | 0.9             | 18.3  | 60   | 1.3   | 45    |
| Mark Edison Dam                | (See Stumpy Meadows Reservoir)                 |                       |               |                 |       |      |       |       |
| Martillo Dam                   | Ventura County Flood Control District          | 1                     | 700           | 2.0             | 35.1  | 115  | 2.4   | 85    |
| Martis Creek Dam               | U. S. Army Corps of Engineers                  | 1                     | 250           | 1.1             | 32.0  | 105  | 0.9   | 33    |
| McCloud Dam                    | Pacific Gas and Electric Company               | 1                     | 1 200         | 5.4             | 59.4  | 195  | 2.4   | 85    |
| McCoy Flat Dam                 | Lessen Irrigation Company                      | 1                     | 50            | 0.2             | 4.6   | 15   | 1.3   | 46    |

See footnotes on first page

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility   | Owner   | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head (m)  | Head (ft) | Flow (cms) | Flow (cfs) |
|--|---|-----------------------|---------------|-----------------|-----------|-----------|------------|------------|
| Merle Collins Reservoir<br>(Virginia Ranch Dam)<br>Middle Fork Dam | Brown Valley Irrigation District  | 2,4                   | 900           | 5.6             | 32.0      | 105       | 3.4        | 120        |
| Millerton Lake<br>Frisant-Kern Canal                               | (See Schadds Reservoir)   |                       |               |                 |           |           |            |            |
| Madera Canal   | U. S. Water and Power Resources Service                                       | 2,4                   | 15 000        | 68.0            | 26.5      | 87        | 68.0       | 2,400      |
| San Joaquin River  | U. S. Water and Power Resources Service                                       | 2,4                   | 5 000         | 23.0            | 32.6      | 107       | 18.4       | 650        |
| Miramar Treatment Plant<br>(Pipeline)                              | U. S. Water and Power Resources Service<br>City of San Diego                  | 2,4                   | 2 700         | 10.0            | 71.0      | 233       | 4.5        | 160        |
|  |   | 2                     | 1 300         | 5.7             | 30.5      | 100       | 5.1        | 180        |
| Mocasin Lower Dam<br>Modesto Reservoir (Dam)                       | City of San Francisco   | 2                     | 1 600         | 7.0             | 13.7      | 45        | 15.9       | 560        |
| Mojave Siphon No. 1<br>(Silverwood Lake Inlet,<br>Pipeline)        | Modesto Irrigation District<br>California Department of Water Resources       | 2                     | 1 000         | 3.4             | 5.5       | 18        | 243.8      | 800        |
|  |   | 2                     | 6 000         | 47.4            | 20.4      | 67        | 31.1       | 1,100      |
| Mojave Siphon No. 2<br>(Silverwood Lake Inlet,<br>Pipeline)        | California Department of Water Resources                                      | 2                     | 10 000        | 78.0            | 20.4      | 67        | 62.2       | 2,200      |
| Mono Creek Diversion Dam<br>Monticello Dam                         | Southern California Edison<br>(See Lake Berryessa)                            | 1                     | <u>B/</u>     | <u>B/</u>       | <u>B/</u> | <u>B/</u> | <u>B/</u>  | <u>B/</u>  |
| Mount Olive (Pipeline)   | City of Santa Monica  | 2                     | 150           | 1.1             | 61.0      | 200       | 0.4        | 14         |
| New Hogan Dam  | U. S. Army Corps of Engineers   | 2,4                   | 2 250         | 9.5             | 41.1      | 135       | 6.5        | 230        |
| Newside Drop (Canal)   | Imperial Irrigation District  | 1                     | 200           | 0.9             | 2.7       | 9         | 8.8        | 310        |
| New Siphon Drop<br>(Yuma Main Canal)                               | U. S. Water and Power Resources Service                                       | 2,3                   | 1 410         | 11.3            | 9.8       | 32        | 17.2       | 610        |
| Nicasio Dam<br>North Fork Dam<br>North Fork Dam                    | Marin Municipal Water District<br>(See Pacheco Lake)<br>(See Lake Clementine) | 1                     | 400           | 1.7             | 25.9      | 85        | 1.8        | 65         |
| No. 8 Heading (Canal)  | Imperial Irrigation District  | 2                     | 750           | 3.9             | 4.6       | 15        | 21.9       | 775        |
| North Portal Tacolote Tunnel                                       | U. S. Water and Power Resources Service                                       | 2                     | 175           | 0.7             | 25.9      | 85        | 0.8        | 30         |
| Orange County (OC) 28 (Pipeline)                                   | Orange County Water District  | 1                     | 6 300         | 12.0            | 106.7     | 350       | 7.1        | 250        |
| Orange County (OC) 45 (Pipeline)                                   | City of La Habra  | 1                     | 100           | <u>B/</u>       | <u>B/</u> | <u>B/</u> | <u>B/</u>  | <u>B/</u>  |
| Orange County (OC) 59 (Pipeline)                                   | Orange County Water District  | 1                     | 5 000         | 9.0             | 85.3      | 280       | 7.1        | 250        |
| O'Shaughnessy Dam  | (See Hatch Hatchy Reservoir)  |                       |               |                 |           |           |            |            |
| Pacheco Lake (North Fork Dam)                                      | Pacheco Pass Water District   | 1                     | 60            | 0.3             | 24.4      | 80        | 0.3        | 10         |

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Facility  | Owner  | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head (m) | Head (ft) | Flow  |        |
|---|--|-----------------------|---------------|-----------------|----------|-----------|-------|--------|
|   |  |                       |               |                 |          |           | (cms) | (cfs)  |
| Pacifica Dam  | Los Angeles County Flood Control District          | 1                     | 400           | 1.0             | 61.0     | 200       | 0.8   | 30     |
| Palermo Canal Release                                   | California Department of Water Resources           | 2                     | 400           | 1.5             | 91.4     | 300       | 0.5   | 19     |
| Palo Verde Diversion Dam                                | U. S. Water and Power Resources Service            | 2,3                   | 8 700         | 65.0            | 4.6      | 15        | 229.4 | 8,100  |
| Paradise Dam  | Paradise Irrigation District                       | 2                     | 300           | 1.2             | 45.7     | 150       | 0.8   | 30     |
| Parker Drop (Canal)                                     | South San Joaquin Irrigation District              | 1                     | 300           | 0.8             | 30.5     | 10        | 11.3  | 400    |
| Parkview Station (Canal)                                | Anderson-Cottonwood Irrigation District            | 2                     | 150           | 0.5             | 4.6      | 15        | 4.2   | 150    |
| People's Weir (Canal)                                   | People's Ditch Company                             | 1                     | 2 200         | 3.5             | 3.0      | 10        | 85.0  | 3,000  |
| Perris Power Project (Pipeline)                         | Metropolitan Water District of Southern California | 2,5                   | 7 900         | 40.3            | 48.8     | 160       | 18.4  | 650    |
| Peters Dam  | (See Kent Lake)                                    |                       |               |                 |          |           |       |        |
| Pilarcitos Dam  | City of San Francisco                              | 1                     | 200           | 0.8             | 85.3     | 280       | 0.3   | 10     |
| Point Loma Wastewater Treatment Plant (Pipeline)        | City of San Diego                                  | 1                     | 1 200         | 8.0             | 23.2     | 76        | 6.2   | 220    |
| Ponderosa Diversion Dam                                 | Oroville-Wyandotte Irrigation District             | 1                     | 3 300         | 14.0            | 18.3     | 60        | 21.5  | 760    |
| Prosser Creek Dam                                       | U. S. Water and Power Resources Service            | 2,4                   | 1 000         | 3.5             | 28.7     | 94        | 4.2   | 150    |
| Pumping Plant Lower (Canal)                             | Montague Water Conservation District               | 2                     | 65            | 0.2             | 12.2     | 40        | 0.7   | 25     |
| Pyramid Stream Release (Dam)                            | California Department of Water Resources           | 2                     | 1 000         | 4.0             | 91.4     | 300       | 1.3   | 46     |
| Rector Creek Dam  | California Department of Finance                   | 1                     | 100           | 0.5             | 45.7     | 150       | 0.3   | 10     |
| Red Bluff Diversion Dam                                 | U. S. Water and Power Resources Service            | 2,4                   | 14 000        | 70.0            | 4.0      | 13        | 424.8 | 15,000 |
| Redlands Water Treatment Plant (Pipeline)               | City of Redlands                                   | 2                     | 200           | 0.9             | 22.9     | 75        | 1.0   | 37     |
| Richard B. Parker (On Main Canal)                       | Merced Irrigation District                         | 2,6                   | 2 800         | 9.2             | 6.1      | 20        | 53.8  | 1,900  |
| Rindge Dam  | Adams Companies                                    | 1                     | 600           | 0.9             | 30.4     | 100       | 2.3   | 80     |
| Rio Hondo (Pipeline)                                    | Metropolitan Water District of Southern California | 2,5                   | 2 000         | 12.3            | 67.1     | 220       | 3.1   | 110    |
| Robert A. Skinner Dam                                   | Metropolitan Water District of Southern California | 1                     | 1 400         | 6.3             | 24.4     | 80        | 6.8   | 240    |
| Robert W. Matthews Dam                                  | (See Ruth Reservoir)                               |                       |               |                 |          |           |       |        |
| Rocky Point Diversion Structure (Carrier Canal Project) | City of Bakersfield, et al                         | 2,3                   | 300           | 0.7             | 3.0      | 10        | 14.2  | 500    |
| Round Valley Dam  | Jack and Thomas Swickard                           | 2                     | 90            | 0.4             | 12.2     | 40        | 1.0   | 35     |

See footnotes on first page

## Section A-2

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility   | Owner   | Status of Development | Capacity (kw) | Energy (GWh/yr) | Head  |      | Flow  |       |
|--|---|-----------------------|---------------|-----------------|-------|------|-------|-------|
|  |   |                       |               |                 | (m)   | (ft) | (cms) | (cfs) |
| Ruth Reservoir<br>(Robert W. Matthews Dam)             | Humboldt Bay Municipal Water District                         | 2,4                   | 4 000         | 14.2            | 41.1  | 135  | 11.6  | 410   |
| Salt Spring Valley Reservoir<br>(Dam)                  | Rock Creek Water District                                     | 1                     | 90            | 0.4             | 7.6   | 25   | 1.4   | 50    |
| San Antonio Dam  | Monterey County Flood Control and Water Conservation District | 2,4                   | 6 000         | 25.6            | 51.8  | 170  | 15.3  | 540   |
| Sand Creek Check (Canal)                               | Orange Cove Irrigation District                               | 1                     | 200           | 1.5             | 1.8   | 6    | 14.2  | 500   |
| Sand Bar Project (Dam)                                 | Oakdale and South San Joaquin Irrigation Districts            | 4                     | 12 000        | 70.0            | 118.9 | 390  | 12.2  | 430   |
| San Dieguito Treatment Plant<br>(Pipeline)             | San Dieguito Water District and Santa Fe Irrigation District  | 2                     | 1 000         | 4.5             | 128.0 | 420  | 1.0   | 34    |
| San Dimas Dam  | Los Angeles County Flood Control District                     | 1                     | 100           | 0.3             | 25.9  | 85   | 0.5   | 16    |
| San Dimas (Pipeline)                                   | Metropolitan Water District of Southern California            | 2,7                   | 9 900         | 68.2            | 121.9 | 400  | 8.5   | 300   |
| San Gabriel Dam  | Los Angeles County Flood Control District                     | 2                     | 500           | 3.0             | 61.0  | 200  | 1.3   | 45    |
| Santa Ana Low Turnout (Pipeline)                       | San Bernardino Valley Municipal Water District                | 2,4                   | 1 400         | 3.8             | 67.1  | 220  | 2.8   | 100   |
| Santa Anita Dam  | Los Angeles County Flood Control District                     | 1                     | 300           | 0.7             | 33.5  | 110  | 1.1   | 38    |
| Santa Felicia Dam                                      | (See Lake Pirou)  |                       |               |                 |       |      |       |       |
| Santiago Creek (Pipeline)                              | Metropolitan Water District of Southern California            | 2,3                   | 3 000         | 15.6            | 68.6  | 225  | 5.1   | 180   |
| San Vicente Reservoir (Pipeline)                       | San Diego County Water Authority                              | 2                     | 850           | 3.4             | 45.7  | 150  | 2.3   | 80    |
| Schaads Reservoir (Middle Fork Dam)                    | Calaveras Public Utility District                             | 1                     | 75            | 0.4             | 21.3  | 70   | 0.4   | 15    |
| Scotts Flat Dam  | Nevada Irrigation District                                    | 1                     | 1 300         | 5.5             | 45.7  | 150  | 3.4   | 120   |
| Scott Dam  | (See Lake Pillsbury)  |                       |               |                 |       |      |       |       |
| Semitropic Intake Canal                                | Semitropic Water Storage District                             | 1                     | 8/            | 8/              | 8/    | 8/   | 8/    | 8/    |
| Sepulveda Canyon (Pipeline)                            | Metropolitan Water District of Southern California            | 2,5,7                 | 8 600         | 56.2            | 91.4  | 300  | 13.5  | 475   |
| Sidney N. Peterson Water<br>Treatment Plant (Pipeline) | San Juan Suburban Water District                              | 2                     | 175           | 0.4             | 7.6   | 25   | 2.8   | 100   |
| Slab Creek Dam   | Sacramento Municipal Utility District                         | 6                     | 400           | 3.0             | 61.0  | 200  | 0.8   | 30    |

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities in California (Continued)

| Facility                                  | Owner  | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head         |            | Flow       |           |
|---|--|-----------------------|---------------|-----------------|--------------|------------|------------|-----------|
|   |  |                       |               |                 | (m)          | (ft)       | (cms)      | (cfs)     |
| Sly Creek Dam                             | Orville-Wyandotte Irrigation District  | 2, 5                  | 13 200        | 48.2            | 68.6         | 225        | 23.1       | 815       |
| Sly Park Dam                              | (See Jenkinson Lake)   |                       |               |                 |              |            |            |           |
| South Creek (Pipeline)                    | Desert Water Agency  | 1                     | 300           | 1.7             | 22.9         | 750        | 0.1        | 5         |
| South Canal                               | Pacific Gas and Electric Company   | 2                     | 8 000         | 37.0            | 91.4         | 300        | 10.5       | 370       |
| South Portal Doulton Tunnel               | Montecito County Water District  | 1                     | 200           | 0.5             | 213.4        | 700        | 0.1        | 4         |
| Spicers Meadows Dam                       | Pacific Gas and Electric Company   | 1                     | 750           | 3.3             | 14.6         | 48         | 6.2        | 220       |
| Stampede Dam                              | U. S. Water and Power Resources Service  | 2, 3                  | 3 000         | 17.0            | 64.0         | 210        | 5.7        | 200       |
| Stevens Creek Dam                         | Santa Clara Valley Water District  | 1                     | 75            | 0.3             | 32.0         | 105        | 0.3        | 10        |
| Stone Canyon Dam                          | City of Los Angeles  | 2                     | 300           | 2.0             | 19.8         | 65         | 1.8        | 64        |
| Stone Drop (Canal)                        | Modesto Irrigation District  | 4                     | 1 000         | 4.0             | 5.5          | 18         | 22.7       | 800       |
| Stony Gorge Dam                           | U. S. Water and Power Resources Service  | 4                     | 6 000         | 18.0            | 30.5         | 100        | 24.1       | 850       |
| Stumpy Meadows Reservoir (Mark Edson Dam) | Georgetown Divide Public Utility District  | 2                     | 325           | 2.2             | 45.7         | 150        | 0.8        | 30        |
| Success Dam                               | U. S. Army Corps of Engineers  | 4                     | 4 000         | 12.0            | 36.6         | 120        | 13.0       | 460       |
| Sweetwater Treatment Plant (Pipeline)     | San Dieguito Water District and Santa Fe Irrigation District                           | 2                     | 1 400         | 6.3             | 121.9        | 400        | 1.4        | 50        |
| Sweetwater Turnout (Pipeline)             | San Bernardino Valley Municipal Water District of Southern California                  | 2, 4<br>2, 5          | 875<br>2 800  | 2.2<br>18.0     | 61.0<br>41.1 | 200<br>135 | 2.4<br>8.5 | 85<br>300 |
| Tenescal (Pipeline)                       | Metropolitan Water District of Southern California                                     |                       |               |                 |              |            |            |           |
| Terminal Reservoir Inlet (Pipeline)       | San Luis Obispo County Flood Control and Water Conservation District (See Lake Kaweah) | 2                     | 75            | 0.6             | 57.9         | 190        | 0.2        | 6         |
| Terminus Dam                              | California Department of Water Resources   | 2, 6                  | 13 000        | 42.6            | 9.1          | 30         | 184.1      | 6, 500    |
| Thermalito Afterbay River Outlet (Dam)    | California Department of Water Resources   |                       |               |                 |              |            |            |           |
| Thermalito Diversion Dam                  | California Department of Water Resources   | 2, 6                  | 3 500         | 23.0            | 21.3         | 70         | 19.8       | 700       |
| Tinemaha Dam                              | City of Los Angeles  | 2                     | 1 600         | 8.3             | 8.8          | 29         | 22.7       | 800       |
| Tr-Inity Tunnel                           | (See Del Loma Tunnel)  |                       |               |                 |              |            |            |           |
| Tuberoso Check (Canal)                    | Imperial Irrigation District   | 1                     | 200           | 1.3             | 3.0          | 10         | 7.9        | 280       |
| Tule Lake (Dam)                           | R. W. Akers  | 1                     | 75            | 0.3             | 4.3          | 14         | 2.3        | 80        |
| Turlock Main Canal                        | Turlock Irrigation District  | 2                     | 700           | 2.1             | 1.8          | 6          | 48.1       | 1, 700    |
| Drop No. 2                                | Turlock Irrigation District  | 2, 5                  | 900           | 2.9             | 2.4          | 8          | 48.1       | 1, 700    |
| Drop No. 6                                |  |                       |               |                 |              |            |            |           |

See footnotes on first page

## Section A-2

Table A-2. List of Potential Small Hydroelectric Projects At Existing Hydraulic Facilities In California (Continued)

| Facility                                       | Owner  | Status of Development | Capacity (kW) | Energy (GWh/yr) | Head  |      | Flow  |       |
|--|--|-----------------------|---------------|-----------------|-------|------|-------|-------|
|  |  |                       |               |                 | (m)   | (ft) | (cms) | (cfs) |
| Drop No. 7                                     | Turlock Irrigation District                          | 2                     | 700           | 2.1             | 2.4   | 8    | 36.8  | 1,300 |
| Upper Dawson Powerplant (Canal)                | Turlock Irrigation District                          | 5                     | 4 000         | 15.9            | 8.5   | 28   | 56.6  | 2,000 |
| Upper Main Canal                               | Browns Valley Irrigation District                    | 1                     | 200           | 0.9             | 91.4  | 300  | 0.3   | 10    |
| Uvas Dam                                       | South Santa Clara Valley Water Conservation District | 2                     | 300           | 1.0             | 22.9  | 75   | 1.7   | 60    |
| Vall Dam                                       | Rancho California Water District                     | 1                     | 200           | 0.9             | 36.6  | 120  | 0.7   | 25    |
| Vall Heading (Canal)                           | Imperial Irrigation District                         | 2                     | 225           | 1.0             | 4.9   | 16   | 5.7   | 200   |
| Valley View (Pipeline)                         | Metropolitan Water District of Southern California   | 2,5                   | 2 400         | 14.2            | 119.5 | 392  | 2.4   | 84    |
| Van Owen Regulating (Pipeline)                 | City of Los Angeles                                  | 1                     | 600           | 5.0             | 36.6  | 120  | 2.0   | 70    |
| Venice (Pipeline)                              | Metropolitan Water District of Southern California   | 2,7                   | 10 100        | 60.0            | 85.3  | 280  | 13.5  | 475   |
| Vermillion Valley Dam                          | (See Lake Thomas A. Edison)                          |                       |               |                 |       |      |       |       |
| Volta No. 2 Powerhouse (Canal)                 | Pacific Gas and Electric Company                     | 7                     | 1 000         | 5.0             | 36.6  | 120  | 3.3   | 115   |
| Warm Springs Dam                               | U. S. Army Corps of Engineers                        | 2,3                   | 3 000         | 15.0            | 54.9  | 180  | 6.5   | 230   |
| Waterman Canyon Turnout (Pipeline)             | San Bernardino Valley Municipal Water District       | 2,4                   | 4 000         | 7.0             | 153.9 | 505  | 3.3   | 115   |
| Webber Dam                                     | El Dorado Irrigation District                        | 1                     | 75            | 0.3             | 27.4  | 90   | 0.3   | 12    |
| West Coast Basin Barrier (Pipeline)            | Los Angeles County Flood Control District            | 2                     | 500           | 4.2             | 56.4  | 185  | 1.1   | 40    |
| West Valley Dam                                | South Fork Pit River Irrigation District             | 1                     | 900           | 3.8             | 73.2  | 240  | 1.4   | 50    |
| Whale Rock Dam                                 | California Department of Finance                     | 1                     | 250           | 1.0             | 53.3  | 175  | 0.6   | 20    |
| Whiskeytown Dam                                | U. S. Water and Power Resources Service              | 2,4                   | 3 000         | 12.5            | 76.2  | 250  | 4.7   | 165   |
| White Pines Dam                                | Calaveras County Water District                      | 1                     | 100           | 0.4             | 18.3  | 60   | 0.7   | 25    |
| Whitewater Canyon Irrigation System (Pipeline) | Whitewater Canyon Mutual Water Company               | 2                     | 400           | 2.5             | 182.9 | 600  | 0.3   | 9     |
| Whitewater River (Pipeline)                    | Desert Water Agency                                  | 1                     | 400           | 2.4             | 18.3  | 60   | 2.8   | 100   |
| Woodward Dam                                   | South San Joaquin Irrigation District                | 2,6                   | 2 300         | 6.9             | 12.5  | 41   | 22.7  | 800   |
| Yorba Linda Feeder (Pipeline)                  | Metropolitan Water District of Southern California   | 2,7                   | 5 100         | 33.5            | 61.0  | 200  | 9.6   | 340   |
| Youd Drop (Canal)                              | Merced Irrigation District                           | 1                     | 100           | 0.5             | 2.1   | 7    | 6.5   | 230   |
| Yuma Main Canal                                | (See New Siphon Drop)                                |                       |               |                 |       |      |       |       |

SECTION A-3

(Table A-3)

## Section A-3

Table A-3 List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California

| County/Facility                           | Owner                                  | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                            |
|---|--|------------------|--------------------|----------------------------|----------------------------|
|   |  |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| (Alphabetical by County)                  |  |                  |                    |                            |                            |
| <b>Alameda</b>                            |  |                  |                    |                            |                            |
| Calaveras Dam                             | City & County of San Francisco         | 700              | 3.2                | 7.7                        |                            |
| Del Valle Stream Release (Dam)            | California Dept. of Water Resources    | 400              | 1.1                | 16.9                       |                            |
| <b>Alpine</b>                             |  |                  |                    |                            |                            |
| Indian Creek Dam                          | South Tahoe Public Utility District    | 50               | 0.1                | 54.6                       |                            |
| <b>Anador</b>                             |  |                  |                    |                            |                            |
| Central Anador Water Project              | Anador County Water Agency             | 250              | 0.7                | 20.3                       |                            |
| Jackson-Sutter Creek Outfall<br>Pipeline  | Anador County Water Agency             | 60               | 0.2                | 31.6                       |                            |
| Lake Anador (Jackson Creek Dam)           | Jackson Valley Irrigation District     | 350              | 2.5                | 5.1                        |                            |
| Salt Spring Valley Reservoir (Dam)        | Rock Creek Water District              | 90               | 0.4                | 18.4                       |                            |
| <b>Butte</b>                              |  |                  |                    |                            |                            |
| Concow Dam                                | Thermalito I.D. & Table Mt. I.D.       | 130              | 0.4                | 24.0                       |                            |
| Palermo Canal Release (Dam)               | California Dept. of Water Resources    | 400              | 1.5                | 14.5                       |                            |
| Paradise Dam                              | Paradise Irrigation District           | 300              | 1.2                | 10.7                       |                            |
| Ponderosa Diversions Dam                  | Oroville-Wyandotte Irrigation District | 3 300            | 14.0               | 5.0                        |                            |
| Sly Creek Dam                             | Oroville-Wyandotte Irrigation District | 13 200           | 48.2               | 4.5                        |                            |
| Thermalito Afterbay River Outlet<br>(Dam) | California Dept. of Water Resources    | 13 000           | 42.6               | 12.1                       |                            |
| Thermalito Diversions Dam                 | California Dept. of Water Resources    | 3 500            | 23.0               | 5.1                        |                            |
| <b>Calaveras</b>                          |  |                  |                    |                            |                            |
| Goodwin Dam                               | Oakdale & So. San Joaquin I.D.         | 970              | 4.7                | 4.6                        |                            |
| New Hogan Dam                             | U.S. Army Corps of Engineers           | 2 250            | 9.5                | 5.7                        |                            |
| Schaeds Reservoir (Middle Fork Dam)       | Calaveras Public Utility District      | 75               | 0.4                | 16.0                       |                            |
| White Pines Dam                           | Calaveras County Water District        | 100              | 0.4                | 20.4                       |                            |

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                              | Owner                                     | Capacity<br>(kW) | Energy<br>(GMH/yr) | 1984                       |                            |
|--|---|------------------|--------------------|----------------------------|----------------------------|
|  |   |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| Colusa<br>East Park Dam                      | U.S. Water & Power Resources Service      | 900              | 2.0                | 13.5                       |                            |
| Contra Costa<br>Mallard Reservoir (Pipeline) | Contra Costa County Water District        | 200              | 0.9                | 14.0                       |                            |
| El Dorado<br>Buckeye Conduit                 | Georgetown Divide Public Utility District | 350              | 2.4                | 5.4                        |                            |
| Buffalo Hill Siphon                          | Georgetown Divide Public Utility District | 160              | 0.5                | 20.3                       |                            |
| El Dorado Distribution System                | El Dorado Irrigation District             |                  |                    |                            |                            |
| Reservoir A                                  |   | 730              | 3.2                | 7.9                        |                            |
| Reservoir 2                                  |   | 50               | 0.2                | 27.3                       |                            |
| Reservoir 2A                                 |   | 480              | 2.1                | 9.9                        |                            |
| Reservoir 2A-3                               |   | 360              | 1.6                | 11.1                       |                            |
| Reservoir 3                                  |   | 200              | 0.9                | 14.0                       |                            |
| Reservoir 5                                  |   | 60               | 0.3                | 21.8                       |                            |
| Reservoir 6                                  |   | 80               | 0.3                | 22.7                       |                            |
| Reservoir 8                                  |   | 175              | 0.8                | 14.4                       |                            |
| Reservoir 9A                                 |   | 175              | 0.8                | 14.4                       |                            |
| Reservoir 9B                                 |   | 90               | 0.4                | 18.4                       |                            |
| Reservoir 10A                                |   | 175              | 0.8                | 14.4                       |                            |
| Reservoir 10B                                |   | 60               | 0.3                | 21.8                       |                            |
| Ice House Reservoir (Dam)                    | Sacramento Municipal Utility District     | 10 000           | 22.0               | --                         |                            |
| Jenkinson Lake (Sly Park Dam)                | U.S. Water & Power Resources Service      | 650              | 1.8                | 10.9                       |                            |
| Kaiser Pipeline                              | Georgetown Divide Public Utility District | 120              | 0.3                | 29.1                       |                            |
| Slab Creek Dam                               | Sacramento Municipal Utility District     | 400              | 3.0                | 6.2                        |                            |
| Stumpy Meadows Reservoir<br>(Mark Edson Dam) | Georgetown Divide Public Utility          | 325              | 2.2                | 8.5                        |                            |
| Webber Dam                                   | El Dorado Irrigation District             | 75               | 0.3                | 24.1                       |                            |

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility               | Owner                                | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |  |
|-------------------------------|--------------------------------------|------------------|--------------------|----------------------------|--|
|                               |                                      |                  |                    | Energy<br>Cost<br>(\$/kWh) |  |
| Fresno                        |                                      |                  |                    |                            |  |
| Fresno Main Canal             | Fresno Irrigation District           | 650              | 2.6                | 9.1                        |  |
| Headworks                     |                                      | 650              | 2.6                | 9.1                        |  |
| Boos Check                    |                                      | 650              | 2.6                | 9.1                        |  |
| Dresser Check                 |                                      | 850              | 3.5                | 23.7                       |  |
| Gould Weir Diversion Dam      | Fresno Irrigation District           | 2 000            | 9.6                | 4.9                        |  |
| Lake Thomas A. Edison         | Southern California Edison           |                  |                    |                            |  |
| (Yermillion Valley Dam)       |                                      |                  |                    |                            |  |
| Millerton Lake (Friant Dam)   | U.S. Water & Power Resources Service | 15 000           | 68.0               | 3.7                        |  |
| Friant-Kern Canal             |                                      | 5 000            | 23.0               | 4.0                        |  |
| Madera Canal                  |                                      | 2 700            | 10.0               | 5.9                        |  |
| San Joaquin River             |                                      | 1/               | 1/                 | --                         |  |
| Mono Creek Diversion Dam      | Southern California Edison           |                  |                    |                            |  |
| Glenn                         |                                      |                  |                    |                            |  |
| Stony Gorge Dam               | U.S. Water & Power Resources Service | 6 000            | 18.0               | 6.4                        |  |
| Imperial                      |                                      |                  |                    |                            |  |
| All-American Canal Drop No. 1 | U.S. Water & Power Resources Service | 4 700            | 27.0               | 3.3                        |  |
| All-American Canal Drop No. 5 | U.S. Water & Power Resources Service | 5 000            | 24.0               | 4.0                        |  |
| Alamo Drop 3A (Canal)         | Imperial Irrigation District         | 1 200            | 6.7                | 6.4                        |  |
| Dahilla Drop (Canal)          | Imperial Irrigation District         | 225              | 1.0                | 13.2                       |  |
| East Highline Canal Turnout   | Imperial Irrigation District         | 1 800            | 10.0               | 4.4                        |  |
| Newside Drop (Canal)          | Imperial Irrigation District         | 200              | 0.9                | 14.0                       |  |
| No. 8 Heading (Canal)         | Imperial Irrigation District         | 750              | 3.9                | 10.4                       |  |
| Tuberosse Check (Canal)       | Imperial Irrigation District         | 200              | 1.3                | 10.0                       |  |
| Vall Heading (Canal)          | Imperial Irrigation District         | 225              | 1.0                | 17.8                       |  |
| Inyo                          |                                      |                  |                    |                            |  |
| Tiameha Dam                   | City of Los Angeles                  | 1 600            | 8.3                | 5.0                        |  |

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility | Owner                                      | Capacity<br>(KW)  | Energy<br>(GWh/yr) | 1984                       |                            |  |
|-----------------|--|-------------------|--------------------|----------------------------|----------------------------|--|
|                 |  |                   |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |  |
| Kern            | Beardsley Canal Control Structure          | 260               | 1.1                | 13.4                       |                            |  |
|                 | Beardsley Diversion Structure<br>(Canal)   | 500               | 1.7                | 31.5                       |                            |  |
|                 | Eastside Pipeline                          | 1 000             | 3.0                | 9.3                        |                            |  |
|                 | Isabella Dam                               | 8 000             | 18.5               | 8.0                        |                            |  |
|                 | Kern Island Canal Control Structure        | 700               | 3.1                | 7.9                        |                            |  |
|                 | Rocky Point Diversion Structure<br>(Canal) | 300               | 0.7                | 24.8                       |                            |  |
|                 | Semitropic Intake Canal                    | 1/                | 1/                 | --                         |                            |  |
|                 | Kings                                      | Lateral A (Chute) | 1 600              | 7.0                        | 5.9                        |  |
|                 |  | Lateral B (Chute) | 900                | 4.0                        | 6.7                        |  |
|                 |  |                   |                    |                            |                            |  |
| Lake            | Clear Lake Impounding Dam                  | 2 000             | 7.5                | 8.2                        |                            |  |
|                 | Coyote Creek (Dam)                         | 90                | 0.4                | 18.3                       |                            |  |
|                 | Indian Valley Dam                          | 3 200             | 7.2                | 10.5                       |                            |  |
|                 | Lake Pillsbury (Scott Dam)                 | 5 000             | 15.0               | 6.4                        |                            |  |
|                 |  |                   |                    |                            |                            |  |
| Lassen          | McCoy Flat Dam                             | 50                | 0.2                | 27.3                       |                            |  |
|                 | Round Valley Dam                           | 90                | 0.4                | 18.4                       |                            |  |
|                 | Tule Lake (Dam)                            | 75                | 0.3                | 24.1                       |                            |  |
| Los Angeles     | Alamitos Barrier (Dam)                     | 300               | 1.0                | 15.8                       |                            |  |
|                 | Azusa Flow Control Structure<br>(Pipeline) | 740               | 3.2                | 7.7                        |                            |  |
|                 |  |                   |                    |                            |                            |  |
| Tulare          | Tulare Lake Basin Water Storage District   | 1 600             | 7.0                | 5.9                        |                            |  |
|                 | Tulare Lake Basin Water Storage District   | 900               | 4.0                | 6.7                        |                            |  |
|                 |  |                   |                    |                            |                            |  |
|                 | Yolo County F.C.&W.C.-D                    | 2 000             | 7.5                | 8.2                        |                            |  |
|                 | Hidden Valley Lake Association             | 90                | 0.4                | 18.3                       |                            |  |
| Yolo            | Yolo County F.C.&W.C.-D                    | 3 200             | 7.2                | 10.5                       |                            |  |
|                 | Pacific Gas & Electric Company             | 5 000             | 15.0               | 6.4                        |                            |  |
|                 |  |                   |                    |                            |                            |  |
| Lassen          | Lassen Irrigation Company                  | 50                | 0.2                | 27.3                       |                            |  |
|                 | Jack & Thomas Swickard                     | 90                | 0.4                | 18.4                       |                            |  |
|                 | R. W. Akers                                | 75                | 0.3                | 24.1                       |                            |  |
| Los Angeles     | Los Angeles County F.C. District           | 300               | 1.0                | 15.8                       |                            |  |
|                 | San Gabriel Valley Municipal W.D.          | 740               | 3.2                | 7.7                        |                            |  |
|                 |  |                   |                    |                            |                            |  |

1/ Head and flow data not available

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California. (Continued)

| County/Facility                                 | Owner                                | 1984             |                            |                            |
|---|--------------------------------------|------------------|----------------------------|----------------------------|
|   |                                      | Capacity<br>(kW) | Energy<br>Cost<br>(GWh/yr) | Energy<br>Cost<br>(\$/kWh) |
| Los Angeles (Continued)                         |                                      |                  |                            |                            |
| Big Dalton Dam                                  | Los Angeles County F.C. District     | 50               | 0.1                        | 53.2                       |
| Big Dalton Pressure Reducing Station (Pipeline) | San Gabriel Valley Municipal W.D.    | 280              | 1.2                        | 13.1                       |
| Big Tujunga No. 1 Dam                           | Los Angeles County F.C. District     | 300              | 1.3                        | 12.2                       |
| Castaic Outlet (Dam)                            | California Dept. of Water Resources  | 275              | 1.4                        | 10.7                       |
| Cogswell Dam                                    | Los Angeles County F.C. District     | 500              | 3.0                        | 7.0                        |
| Cottonwood No. 1 (Canal)                        | California Dept. of Water Resources  | 17 000           | 119.0                      | 5.0                        |
| Cottonwood No. 2 (Canal)                        | California Dept. of Water Resources  | 12 000           | 90.0                       | 2.3                        |
| Covina (Pipeline)                               | Metropolitan Water Dist. of So. Cal. | 2 500            | 16.9                       | 3.3                        |
| Dominguez Gap Barrier (Pipeline)                | Los Angeles County F.C. District     | 500              | 2.0                        | 10.5                       |
| El Segundo Distribution System (Pipeline)       | City of El Segundo                   | 500              | 3.9                        | 5.4                        |
| Emerald Pressure Reducing Station (Pipeline)    | San Gabriel Valley Municipal W.D.    | 340              | 1.5                        | 11.3                       |
| Etiwanda Pressure Reducing Station (Pipeline)   | San Gabriel Valley Municipal W.D.    | 250              | 1.1                        | 12.9                       |
| Franklin Inlet (Pipeline)                       | City of Los Angeles                  | 800              | 6.8                        | 3.9                        |
| Glendale Distribution System (Pipeline)         | City of Glendale                     | 400              | 2.0                        | 6.9                        |
| Littlerock Dam                                  | Palmdale Water District              | 50               | 0.2                        | 27.3                       |
| Los Angeles Distribution System                 | City of Los Angeles                  |                  |                            |                            |
| Location 1                                      |                                      | 610              | 3.3                        | 7.1                        |
| Location 2                                      |                                      | 270              | 2.2                        | 6.9                        |
| Location 3                                      |                                      | 420              | 2.1                        | 9.1                        |
| Location 4                                      |                                      | 270              | 1.8                        | 8.4                        |
| Location 5                                      |                                      | 140              | 1.2                        | 8.1                        |
| Location 6                                      |                                      | 190              | 1.1                        | 10.9                       |
| Location 7                                      |                                      | 120              | 1.0                        | 8.9                        |
| Location 8                                      |                                      | 130              | 0.8                        | 12.0                       |
| Location 9                                      |                                      | 70               | 0.6                        | 11.6                       |

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                     | Owner                                | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                            |
|-------------------------------------|--------------------------------------|------------------|--------------------|----------------------------|----------------------------|
|                                     |                                      |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| Los Angeles (Continued)             |                                      |                  |                    |                            |                            |
| Location 10                         |                                      | 100              | 0.6                |                            | 13.6                       |
| Location 11                         |                                      | 70               | 0.6                |                            | 11.6                       |
| Location 12                         |                                      | 100              | 0.6                |                            | 13.6                       |
| Location 13                         |                                      | 60               | 0.5                |                            | 13.1                       |
| Location 14                         |                                      | 60               | 0.5                |                            | 13.1                       |
| Location 15                         |                                      | 1 000            | 8.2                |                            | 3.4                        |
| Location 16                         |                                      | 1 800            | 9.0                |                            | 4.9                        |
| Los Angeles Reservoir (Dam)         | City of Los Angeles                  | 6 200            | 37.0               | 3.2                        |                            |
| Mount Olivette (Pipeline)           | City of Santa Monica                 | 150              | 1.1                | 7.9                        |                            |
| Pacoima Dam                         | Los Angeles County F.C. District     | 400              | 1.0                | 18.6                       |                            |
| Pyramid Stream Release (Dam)        | California Dept. of Water Resources  | 1 000            | 3.2                | 9.0                        |                            |
| Rindge Dam                          | Adamson Co.                          | 600              | 0.9                | 25.7                       |                            |
| Rio Hondo (Pipeline)                | Metropolitan Water Dist. of So. Cal. | 2 000            | 12.3               | 4.0                        |                            |
| San Dimas Dam                       | Los Angeles County F.C. District     | 100              | 0.3                | 27.3                       |                            |
| San Dimas (Pipeline)                | Metropolitan Water Dist. of So. Cal. | 9 000            | 68.2               | 2.6                        |                            |
| Santa Anita Dam                     | Los Angeles County F.C. District     | 500              | 3.0                | 7.0                        |                            |
| Santa Anita (Pipeline)              | Los Angeles County F.C. District     | 300              | 0.7                | 22.6                       |                            |
| Sepulveda Canyon (Pipeline)         | Metropolitan Water Dist. of So. Cal. | 8 600            | 56.2               | 2.8                        |                            |
| Stone Canyon Dam                    | City of Los Angeles                  | 300              | 2.0                | 7.9                        |                            |
| Van Owen Regulating (Pipeline)      | City of Los Angeles                  | 600              | 5.0                | 4.6                        |                            |
| Venice (Pipeline)                   | Metropolitan Water Dist. of So. Cal. | 10 100           | 60.0               | 3.0                        |                            |
| West Coast Basin Barrier (Pipeline) | Los Angeles County F.C.D.            | 500              | 4.2                | 4.1                        |                            |
| Madera                              |                                      |                  |                    |                            |                            |
| Ash Main Canal                      | Chowchilla Water District            | 150              | 0.7                | 14.9                       |                            |
| Califa Canal                        | Chowchilla Water District            | 200              | 0.9                | 14.0                       |                            |
| Hensley Lake (Hidden Dam)           | U.S. Army Corps of Engineers         | 1 300            | 4.0                | 8.7                        |                            |
| H. V. Eastman Lake (Buchanan Dam)   | U.S. Army Corps of Engineers         | 3 000            | 9.0                | 7.1                        |                            |

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                   | Owner                                  | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                  |
|-----------------------------------|--|------------------|--------------------|----------------------------|------------------|
|                                   |  |                  |                    | Energy<br>Cost<br>(\$/kWh) | Cost<br>(\$/kWh) |
| Madera (Continued)                |  |                  |                    |                            |                  |
| Madera Canal                      | U.S. Water & Power Resources Service   |                  |                    |                            |                  |
| Station 985+65                    |  | 2 000            | 5.5                | 3.8                        |                  |
| Station 1064+67                   |  | 560              | 1.9                | 11.8                       |                  |
| Station 1910+60                   |  | 650              | 2.6                | 9.1                        |                  |
| Chowchilla Main Canal             |  |                  |                    |                            |                  |
| Station 0+00                      | Chowchilla Water District              | 250              | 1.1                | 12.9                       |                  |
| Station 101+80                    |  | 250              | 1.1                | 12.9                       |                  |
| Station 175+00                    |  | 250              | 1.1                | 12.9                       |                  |
| Marin                             |  |                  |                    |                            |                  |
| Kent Lake (Peters Dam)            | Marin Municipal Water District         | 150              | 0.4                | 26.0                       |                  |
| Nicasio Dam                       | Marin Municipal Water District         | 400              | 1.7                | 11.0                       |                  |
| Mendocino                         |  |                  |                    |                            |                  |
| Lake Mendocino (Coyote Dam)       | U.S. Army Corps of Engineers           | 4 000            | 21.0               | 3.8                        |                  |
| Merced                            |  |                  |                    |                            |                  |
| Buhach (Canal)                    | Merced Irrigation District             | 60               | 0.3                | 21.8                       |                  |
| Canal Creek                       | Merced Irrigation District             | 940              | 3.3                | 5.7                        |                  |
| Escalafan Headworks (Canal)       | Merced Irrigation District             | 270              | 0.8                | 8.3                        |                  |
| Fairfield Drop (Canal)            | Merced Irrigation District             | 970              | 2.8                | 6.3                        |                  |
| Fisher Drop (Canal)               | Merced Irrigation District             | 75               | 0.3                | 24.1                       |                  |
| Lake Yosemite Dam                 | Merced Irrigation District             | 1 200            | 2.3                | 13.9                       |                  |
| Los Banos Detention Dam           | U.S. Water & Power Resources Service   | 100              | 0.5                | 16.4                       |                  |
| Richard B. Parker (on Main Canal) | Merced Irrigation District             | 2 800            | 9.2                | 5.4                        |                  |
| Youd Drop (Canal)                 | Merced Irrigation District             | 100              | 0.5                | 16.4                       |                  |
| Modoc                             |  |                  |                    |                            |                  |
| Big Sage Dam                      | Hot Springs Valley Irrigation District | 175              | 0.7                | 16.5                       |                  |
| Clear Lake (Dam)                  | U.S. Water & Power Resources Service   | 430              | 1.9                | 10.2                       |                  |

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California

| County/Facility                                      | Owner                                 | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                            |
|--|---------------------------------------|------------------|--------------------|----------------------------|----------------------------|
|  |                                       |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| Modoc (Continued)                                    |                                       |                  |                    |                            |                            |
| Doris Dam  | U.S. Fish & Wildlife Service          | 50               | 0.1                | 54.6                       |                            |
| West Valley Dam                                      | South Fork Pit River Irrigation Dist. | 900              | 3.8                | 7.1                        |                            |
| Mono   |                                       |                  |                    |                            |                            |
| Cardinal Power House                                 | Southern California Edison Co.        | 2 500            | 10.3               | 5.5                        |                            |
| Lake Mary & Twin Lakes Open<br>Diversions (Pipeline) | Mammoth County Water District         | 300              | 0.8                | 19.7                       |                            |
| Monterey   |                                       |                  |                    |                            |                            |
| Los Padres Dam                                       | California-American Water Company     | 75               | 0.3                | 24.1                       |                            |
| San Antonio Dam                                      | Monterey County F.C. & W.C.D.         | 6 000            | 25.6               | 11.8                       |                            |
| Napa   |                                       |                  |                    |                            |                            |
| Cache Slough (Pipeline)                              | City of Vallejo                       | 600              | 4.1                | 5.6                        |                            |
| Lake Berryessa (Monticello Dam)                      | U.S. Water & Power Resources Service  | 16 000           | 43.0               | 4.1                        |                            |
| Lake Curry (Pipeline)                                | City of Vallejo                       | 50               | 0.3                | 27.3                       |                            |
| Lake Hennessy (Conn Creek Dam)                       | City of Napa                          | 500              | 2.3                | 9.1                        |                            |
| Rector Creek Dam                                     | California State Dept. of Finance     | 100              | 0.5                | 16.4                       |                            |
| Nevada   |                                       |                  |                    |                            |                            |
| Anthony House Dam                                    | Lake Willwood Association             | 50               | 0.2                | 27.3                       |                            |
| Boca Dam   | U.S. Water & Power Resources Service  | 2 000            | 5.6                | 8.5                        |                            |
| Bowman Dam   | Nevada Irrigation District            | 3 000            | 14.7               | 2.7                        |                            |
| Combie Dam   | Nevada Irrigation District            | 525              | 2.9                | 7.5                        |                            |
| French Lake (Dam)                                    | Nevada Irrigation District            | 200              | 0.8                | 15.8                       |                            |
| Hour House (Dam)                                     | Yuba County Water Agency              | 100              | 0.3                | 27.3                       |                            |
| Jackson Meadows Dam                                  | Nevada Irrigation District            | 4 000            | 8.9                | 5.4                        |                            |
| Lake Fordyce Dam                                     | Pacific Gas & Electric Company        | 900              | 4.0                | 6.7                        |                            |
| Martis Creek (Dam)                                   | U.S. Army Corps of Engineers          | 250              | 1.1                | 12.9                       |                            |
| Prosser Creek Dam                                    | U.S. Water & Power Resources Service  | 1 000            | 3.5                | 8.0                        |                            |
| Scotts Flat Dam                                      | Nevada Irrigation District            | 1 300            | 5.5                | 6.3                        |                            |

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                                      | Owner                                 | Capacity<br>(kW) | Energy<br>(GMH/yr) | 1984                       |                  |
|--|---------------------------------------|------------------|--------------------|----------------------------|------------------|
|  |                                       |                  |                    | Energy<br>Cost<br>(\$/kWh) | Cost<br>(\$/kWh) |
| <b>Modoc (Continued)</b>                             |                                       |                  |                    |                            |                  |
| Doris Dam  | U.S. Fish & Wildlife Service          | 50               | 0.1                | 54.6                       |                  |
| West Valley Dam                                      | South Fork Pit River Irrigation Dist. | 900              | 3.8                | 7.1                        |                  |
| <b>Mono</b>  |                                       |                  |                    |                            |                  |
| Cardinal Power House                                 | Southern California Edison Co.        | 2 500            | 10.3               | 5.5                        |                  |
| Lake Mary & Twin Lakes Open<br>Diversions (Pipeline) | Mammoth County Water District         | 300              | 0.8                | 19.7                       |                  |
| <b>Monterey</b>                                      |                                       |                  |                    |                            |                  |
| Los Padres Dam                                       | California-American Water Company     | 75               | 0.3                | 24.1                       |                  |
| San Antonio Dam                                      | Monterey County F.C. & W.C.D.         | 6 000            | 25.6               | 11.8                       |                  |
| <b>Napa</b>  |                                       |                  |                    |                            |                  |
| Cache Slough (Pipeline)                              | City of Vallejo                       | 600              | 4.1                | 5.6                        |                  |
| Lake Berryessa (Monticello Dam)                      | U.S. Water & Power Resources Service  | 16 000           | 43.0               | 4.1                        |                  |
| Lake Curry (Pipeline)                                | City of Vallejo                       | 50               | 0.3                | 27.3                       |                  |
| Lake Hennessey (Conn Creek Dam)                      | City of Napa                          | 500              | 2.3                | 9.1                        |                  |
| Rector Creek Dam                                     | California State Dept. of Finance     | 100              | 0.5                | 16.4                       |                  |
| <b>Nevada</b>  |                                       |                  |                    |                            |                  |
| Anthony House Dam                                    | Lake Wildwood Association             | 50               | 0.2                | 27.3                       |                  |
| Boca Dam   | U.S. Water & Power Resources Service  | 2 000            | 5.6                | 8.5                        |                  |
| Bowman Dam   | Nevada Irrigation District            | 3 000            | 14.7               | 2.7                        |                  |
| Comble Dam   | Nevada Irrigation District            | 525              | 2.9                | 7.5                        |                  |
| French Lake (Dam)                                    | Nevada Irrigation District            | 200              | 0.8                | 15.8                       |                  |
| Hour House (Dam)                                     | Yuba County Water Agency              | 100              | 0.3                | 27.3                       |                  |
| Jackson Meadows Dam                                  | Nevada Irrigation District            | 4 000            | 8.9                | 5.4                        |                  |
| Lake Fordyce Dam                                     | Pacific Gas & Electric Company        | 900              | 4.0                | 6.7                        |                  |
| Mart's Creek (Dam)                                   | U.S. Army Corps of Engineers          | 250              | 1.1                | 12.9                       |                  |
| Prosser Creek Dam                                    | U.S. Water & Power Resources Service  | 1 000            | 3.5                | 8.0                        |                  |
| Scotts Flat Dam                                      | Nevada Irrigation District            | 1 300            | 5.5                | 6.3                        |                  |

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility  | Owner                                     | Capacity<br>(kw) | Energy<br>(GWh/yr) | 1984                       |  |
|--|---|------------------|--------------------|----------------------------|--|
|  |   |                  |                    | Energy<br>Cost<br>(\$/kWh) |  |
| Orange   |   |                  |                    |                            |  |
| Balboa (Pipeline)                                      | Metropolitan Water Dist. of So. Cal.      | 1 200            | 9.1                | 3.5                        |  |
| Coyote Creek (Pipeline)                                | Metropolitan Water Dist. of So. Cal.      | 2 900            | 19.6               | 3.1                        |  |
| Irvine Lake Pipeline<br>(Rattlesnake Reservoir)        | Irvine Ranch Water District               | 500              | 1.0                | 20.9                       |  |
| Orange County (OC) 28 (Pipeline)                       | Orange County Water District              | 6 300            | 12.0               | 10.2                       |  |
| Orange County (OC) 45 (Pipeline)                       | City of La Habra                          | 100              | 1/                 | --                         |  |
| Santiago Creek (Pipeline)                              | Metropolitan Water Dist. of So. Cal.      | 3 000            | 15.6               | 4.1                        |  |
| Valley View (Pipeline)                                 | Metropolitan Water Dist. of So. Cal.      | 2 400            | 14.2               | 3.8                        |  |
| Yorba Linda Feeder (Pipeline)                          | Metropolitan Water Dist. of So. Cal.      | 5 100            | 33.5               | 2.9                        |  |
| Placer   |   |                  |                    |                            |  |
| Camp Far West Dam                                      | South Sutter Water District               | 6 800            | 26.9               | 4.7                        |  |
| Folsom Lake Pipeline                                   | U. S. Water & Power Resources Service     | 500              | 2.4                | 8.7                        |  |
| Hell Hole Reservoir<br>(Lower Hell Hole Dam)           | Placer County Water Agency                | 550              | 3.0                | 7.4                        |  |
| Lake Clementine (North Fork Dam)                       | U.S. Army Corps of Engineers              | 12 000           | 63.5               | 3.2                        |  |
| Lake Valley Dam  | Pacific Gas & Electric Company            | 75               | 0.3                | 24.1                       |  |
| Sidney N. Peterson Water Treatment<br>Plant (Pipeline) | San Juan Suburban Water District          | 175              | 0.4                | 28.8                       |  |
| South Canal  | Pacific Gas & Electric Company            | 8 000            | 37.0               | 4.0                        |  |
| Plumas   |   |                  |                    |                            |  |
| Antelope Dam   | California Dept. of Water Resources       | 450              | 1.4                | 22.8                       |  |
| Bucks Lake (Bucks Storage Dam)                         | Pacific Gas & Electric Company            | 740              | 3.2                | 8.0                        |  |
| Frenchman Dam  | California Dept. of Water Resources       | 450              | 1.0                | 20.0                       |  |
| Lake Davis (Grizzly Valley Dam)                        | California Dept. of Water Resources       | 510              | 1.5                | 15.5                       |  |
| Lake Davis-Portola Pipeline                            | Plumas County Water Conservation District | 60               | 0.3                | 21.8                       |  |
| Little Grass Valley Dam                                | Oroville-Wyandotte Irrigation District    | 2 600            | 6.5                | 8.8                        |  |

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility  | Owner                                  | Capacity<br>(kW) | Energy<br>Cost<br>(\$/kWh) | 1984               |                  |
|--|--|------------------|----------------------------|--------------------|------------------|
|  |  |                  |                            | Energy<br>(GWh/yr) | Cost<br>(\$/kWh) |
| <b>Riverside</b>   |  |                  |                            |                    |                  |
| Corona (Pipeline)  | Metropolitan Water Dist. of So. Cal.   | 2 800            | 18.0                       | 3.3                |                  |
| Lake Hemet Dam   | Lake Hemet Municipal Water District    | 75               | 0.1                        | 72.2               |                  |
| Palo Verde Diversion Dam                                 | U.S. Water & Power Resources Service   | 8 700            | 65.0                       | 2.6                |                  |
| Perris Power Project (Pipeline)                          | Metropolitan Water Dist. of So. Cal.   | 7 900            | 40.3                       | 3.6                |                  |
| Snow Creek (Pipeline)                                    | Desert Water Agency                    | 300              | 1.7                        | 9.3                |                  |
| Robert A. Skinner Dam                                    | Metropolitan Water Dist. of So. Cal.   | 1 400            | 6.3                        | 5.8                |                  |
| Temescal (Pipeline)                                      | Metropolitan Water Dist. of So. Cal.   | 2 800            | 18.0                       | 3.3                |                  |
| Vail Dam   | Rancho California Water District       | 200              | 0.9                        | 14.0               |                  |
| Whitewater Canyon Irrigation System<br>(Pipeline)        | Whitewater Canyon Mutual Water Company | 400              | 2.5                        | 7.8                |                  |
| Whitewater River (Pipeline)                              | Desert Water Agency                    | 400              | 2.4                        | 7.7                |                  |
| <b>San Bernardino</b>                                    |  |                  |                            |                    |                  |
| Benson Feeder Pipeline                                   | Monte Vista County Water District      | 1/               | 1/                         | --                 |                  |
| City Creek Turnout (Pipeline)                            | San Bernardino Valley Municipal W.D.   | 2 000            | 3.0                        | 15.8               |                  |
| Deer Creek Collection Pipeline                           | Cucamonga County Water District        | 200              | 1.0                        | 12.2               |                  |
| Highland Avenue Pumping Plant<br>(Pipeline)              | City of Redlands                       | 600              | 2.6                        | 8.9                |                  |
| Lake Arrowhead Dam                                       | Arrowhead Lake Association             | 75               | 0.3                        | 24.1               |                  |
| Las Flores Turnout (Pipeline)                            | California Dept. of Water Resources    | 210              | 0.7                        | 20.0               |                  |
| Lytle Creek Turnout (Pipeline)                           | San Bernardino Valley Municipal W.D.   | 1 300            | 7.8                        | 4.6                |                  |
| Mojave Siphon No. 1<br>(Silverwood Lake Inlet, Pipeline) | California Dept. of Water Resources    | 6 000            | 47.0                       | 6.2                |                  |
| Mojave Siphon No. 2<br>(Silverwood Lake Inlet, Pipeline) | California Dept. of Water Resources    | 10 000           | 78.0                       | 2.3                |                  |
| Orange County (OC) 59 (Pipeline)                         | Orange County Water District           | 5 000            | 9.4                        | 10.1               |                  |
| Redlands Water Treatment Plant<br>(Pipeline)             | City of Redlands                       | 200              | 0.9                        | 14.0               |                  |
| Santa Ana Low Turnout (Pipeline)                         | San Bernardino Valley Municipal W.D.   | 1 400            | 3.8                        | 8.0                |                  |

1/ Head and flow data not available

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                                     | Owner                                 | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                            |
|---|---------------------------------------|------------------|--------------------|----------------------------|----------------------------|
|   |                                       |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| San Bernardino (Continued)                          |                                       |                  |                    |                            |                            |
| Sweetwater Turnout (Pipeline)                       | San Bernardino Valley Municipal W.D.  | 875              | 2.2                | 9.5                        |                            |
| Waterman Canyon Turnout (Pipeline)                  | San Bernardino Valley Municipal W.D.  | 4 000            | 7.0                | 7.5                        |                            |
| San Diego   |                                       |                  |                    |                            |                            |
| Alvarado Treatment Plant (Pipeline)                 | City of San Diego                     | 1 700            | 8.4                | 5.1                        |                            |
| Barratt Dam   | City of San Diego                     | 60               | 0.2                | 32.8                       |                            |
| Bear Valley Powerplant                              |                                       |                  |                    |                            |                            |
| Rehabilitation<br>(at Lake Wohlford Dam)            | Escondido Mutual Water Company        | 700              | 3.7                | 6.6                        |                            |
| Henshaw Dam   |                                       |                  |                    |                            |                            |
| Lake Hodges Dam                                     | Vista Irrigation District             | 200              | 1.0                | 12.6                       |                            |
| Lake Loveland Dam                                   | City of San Diego                     | 270              | 1.2                | 12.6                       |                            |
| Miramar Treatment Plant (Pipeline)                  | South Bay Irrigation District         | 100              | 0.5                | 16.4                       |                            |
| Point Loma Wastewater Treatment<br>Plant (Pipeline) | City of San Diego                     | 1 300            | 5.7                | 6.1                        |                            |
| San Dieguito Treatment Plant<br>(Pipeline)          | City of San Diego                     | 1 200            | 8.0                | 4.0                        |                            |
| San Vicente Reservoir (Pipeline)                    | San Dieguito W.D. & Santa Fe I.D.     | 1 000            | 4.5                | 6.2                        |                            |
| Sweetwater Treatment Plant<br>(Pipeline)            | San Diego County Water Authority      | 850              | 3.4                | 7.7                        |                            |
| San Joaquin   |                                       |                  |                    |                            |                            |
| Camache Dam   | San Dieguito W.D. & Santa Fe I.D.     | 1 400            | 6.3                | 5.8                        |                            |
| Farmington Dam                                      |                                       |                  |                    |                            |                            |
| Parker Drop (Canal)                                 | East Bay Municipal Utility District   | 10 680           | 35.0               | 5.5                        |                            |
|   | U.S. Army Corps of Engineers          | 400              | 2.0                | 9.3                        |                            |
|   | South San Joaquin Irrigation District | 300              | 0.8                | 19.7                       |                            |
| San Luis Obispo                                     |                                       |                  |                    |                            |                            |
| Lopez Dam   | San Luis Obispo County F.C. & W.C.D.  | 50               | 0.4                | 13.7                       |                            |
| Terminal Reservoir Inlet (Pipeline)                 | San Luis Obispo County F.C. & W.C.D.  | 75               | 0.6                | 10.7                       |                            |

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility  | Owner                                   | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                            |
|--|---|------------------|--------------------|----------------------------|----------------------------|
|  |   |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| San Mateo<br>Pillaritos Dam  | City & County of San Francisco          | 200              | 0.8                | 15.8                       |                            |
| Santa Barbara<br>Alisal Creek Dam  | Petan Company                           | 50               | 0.2                | 27.3                       |                            |
| Carmeros Power Project (Pipeline)  | Goleta County Water District            | 700              | 1.6                | 15.4                       |                            |
| Gibraltar Dam  | City of Santa Barbara                   | 1 500            | 4.0                | 9.8                        |                            |
| Jameson Lake (Junca Dam)   | Monterey County Water District          | 60               | 0.4                | 16.4                       |                            |
| North Portal Tecolote Tunnel   | U.S. Water & Power Resources Service    | 175              | 0.7                | 22.4                       |                            |
| South Portal Douilton Tunnel   | Monterey County Water District          | 200              | 0.5                | 25.2                       |                            |
| Santa Clara<br>Anderson Lake (Leroy Anderson Dam)                        | Santa Clara Valley Water District       | 500              | 2.2                | 8.0                        |                            |
| Calero Dam   | Santa Clara Valley Water District       | 100              | 0.5                | 16.4                       |                            |
| Chesbro Reservoir<br>(Elmer J. Chesboro Dam)                             | South Santa Clara Valley W & C.D.       | 100              | 0.2                | 36.8                       |                            |
| Coyote Dam   | Santa Clara Valley Water District       | 600              | 1.3                | 12.4                       |                            |
| Guadalupe Dam  | Santa Clara Valley Water District       | 60               | 0.3                | 21.8                       |                            |
| Lexington Dam  | Santa Clara Valley Water District       | 500              | 2.9                | 7.2                        |                            |
| Pacheco Lake (North Fork Dam)  | Pacheco Pass Water District             | 60               | 0.3                | 21.8                       |                            |
| Stevens Creek Dam  | Santa Clara Valley Water District       | 75               | 0.3                | 24.1                       |                            |
| Uvas Dam   | South Santa Clara Valley W & C.D.       | 300              | 1.0                | 13.1                       |                            |
| Santa Cruz<br>Big Creek Hydroelectric Plant<br>Rehabilitation (Pipeline) | Lockheed Missiles & Space Company, Inc. | 800              | 3.0                | 8.8                        |                            |
| Shasta<br>Anderson Flume Diversion                                       | Anderson-Cottonwood Irrigation District | 50               | 0.2                | 28.5                       |                            |
| Lake Redding (ACID Diversion Dam)  | Anderson-Cottonwood Irrigation District | 14 500           | 79.0               | 9.7                        |                            |

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                     | Owner                                   | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                            |
|-------------------------------------|---|------------------|--------------------|----------------------------|----------------------------|
|                                     |   |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| <b>Shasta (Continued)</b>           |   |                  |                    |                            |                            |
| Lost Creek Diversion Dam            | U.S. Forest Service                     | 1 800            | 10.0               | 4.4                        |                            |
| McCloud Dam                         | Pacific Gas & Electric Company          | 1 200            | 5.4                | 5.9                        |                            |
| Parkview Station (Canal)            | Anderson-Cottonwood Irrigation District | 150              | 0.5                | 15.8                       |                            |
| Volta No. 2 Powerhouse (Canal)      | Pacific Gas & Electric Company          | 1 000            | 5.0                | 6.0                        |                            |
| Whiskeytown Dam                     | U.S. Water & Power Resources Service    | 4 000            | 19.5               | 3.6                        |                            |
| <b>Sierra</b>                       |   |                  |                    |                            |                            |
| Stampede Dam                        | U.S. Water & Power Resources Service    | 3 000            | 16.0               | 4.3                        |                            |
| <b>Siskiyou</b>                     |   |                  |                    |                            |                            |
| Lake Shastina<br>(Shasta River Dam) | Montague Water Conservation District    | 200              | 0.7                | 13.4                       |                            |
| Leke Siskiyou (Box Canyon Dam)      | Siskiyou County F.C. & W.C.D.           | 6 000            | 21.9               | 5.3                        |                            |
| Pumping Plant Lower (Canal)         | Montague Water Conservation District    | 65               | 0.2                | 34.4                       |                            |
| <b>Stanislaus</b>                   |   |                  |                    |                            |                            |
| Turlock Main Canal                  | Turlock Irrigation District             | 660              | 2.1                | 7.6                        |                            |
| Canal Drop No. 2                    |   | 920              | 2.9                | 6.7                        |                            |
| Canal Drop No. 6                    |   | 700              | 2.1                | 8.0                        |                            |
| Canal Drop No. 7                    |   | 2 100            | 4.5                | 10.8                       |                            |
| Ceres Spillway (Canal)              | Turlock Irrigation District             | 4 700            | 17.0               | 4.4                        |                            |
| Frankenhelmer Drop (Canal)          | South San Joaquin Irrigation District   | 2 100            | 4.5                | 10.8                       |                            |
| Hickman Spillway (Canal)            | Turlock Irrigation District             | 1 000            | 3.4                | 9.6                        |                            |
| Modesto Reservoir (Dam)             | Modesto Irrigation District             | 1 000            | 4.0                | 9.6                        |                            |
| Stone Drop (Canal)                  | Modesto Irrigation District             | 4 000            | 15.9               | 5.0                        |                            |
| Upper Dawson Power Plant            | Turlock Irrigation District             | 2 300            | 6.9                | 5.0                        |                            |
| Woodward Dam                        | South San Joaquin Irrigation District   |                  |                    |                            |                            |

## Section A-3

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                               | Owner                                 | Capacity<br>(kW) | Energy<br>Cost<br>(¢/kWh) | 1984               |                           |
|---|---------------------------------------|------------------|---------------------------|--------------------|---------------------------|
|   |                                       |                  |                           | Energy<br>(GWh/yr) | Energy<br>Cost<br>(¢/kWh) |
| <b>Tehama</b>                                 |                                       |                  |                           |                    |                           |
| Black Butte Dam                               | U.S. Army Corps of Engineers          | 9 200            | 31.3                      | 6.4                |                           |
| Red Bluff Diversion Dam                       | U.S. Water & Power Resources Service  | 14 000           | 70.0                      | 3.4                |                           |
| <b>Trinity</b>                                |                                       |                  |                           |                    |                           |
| Del Loma Tunnel                               | George Costa                          | 250              | 1.9                       | 10.2               |                           |
| Ruth Reservoir<br>(Robert W. Matthews Dam)    | Humboldt Bay Municipal Water District | 4 000            | 14.2                      | 5.6                |                           |
| <b>Tulare</b>                                 |                                       |                  |                           |                    |                           |
| Dodge Ave Check (Canal)                       | Orange Cove Irrigation District       | 475              | 2.4                       | 8.6                |                           |
| Lake Kaweah (Terminus Dam)                    | U.S. Army Corps of Engineers          | 4 000            | 20.0                      | 4.0                |                           |
| Lemoncove Ditch (At Terminus Dam)             | U.S. Army Corps of Engineers          | 650              | 3.5                       | 7.7                |                           |
| People's Weir (Canal)                         | People's Ditch Company                | 2 200            | 3.5                       | 14.5               |                           |
| Sand Creek Check (Canal)                      | Orange Cove Irrigation District       | 200              | 1.5                       | 8.4                |                           |
| Success Dam                                   | U.S. Army Corps of Engineers          | 4 000            | 12.0                      | 6.6                |                           |
| <b>Tuolumne</b>                               |                                       |                  |                           |                    |                           |
| Early Intake Dam                              | City & County of San Francisco        | 1 300            | 8.7                       | 4.0                |                           |
| Hetch Hetchy Reservoir<br>(O'Shaughnessy Dam) | City & County of San Francisco        | 1 600            | 6.0                       | 6.9                |                           |
| Lake Eleanor Dam                              | City & County of San Francisco        | 60               | 0.3                       | 21.8               |                           |
| Lyons Dam                                     | Pacific Gas & Electric Company        | 300              | 1.5                       | 10.5               |                           |
| Moccasini Lower Dam                           | City & County of San Francisco        | 1 600            | 7.0                       | 5.9                |                           |
| Sand Bar Project (Dam)                        | Oakdale & South San Joaquin I.-D.     | 12 000           | 70.0                      | 2.9                |                           |
| Spicers Meadows Dam                           | Pacific Gas & Electric Co.            | 750              | 3.3                       | 7.8                |                           |
| <b>Ventura</b>                                |                                       |                  |                           |                    |                           |
| Casitas Dam                                   | U.S. Water & Power Resources Service  | 700              | 2.0                       | 12.3               |                           |
| Conejo Pump Station                           | Calleguas Municipal Water District    | 600              | 3.0                       | 7.7                |                           |

Table A-3. List of Potential Small Hydroelectric Projects at Existing Hydraulic Facilities in California (Continued)

| County/Facility                                 | Owner                                 | Capacity<br>(kW) | Energy<br>(GWh/yr) | 1984                       |                            |
|---|---------------------------------------|------------------|--------------------|----------------------------|----------------------------|
|   |                                       |                  |                    | Energy<br>Cost<br>(\$/kWh) | Energy<br>Cost<br>(\$/kWh) |
| Ventura (Continued)                             |                                       |                  |                    |                            |                            |
| Lake Piru (Santa Felicia Dam)                   | United Water Conservation District    | 3 600            | 7.8                | 9.1                        |                            |
| Matilija Dam                                    | Ventura County Flood Control District | 700              | 2.0                | 12.3                       |                            |
| Yuba  |                                       |                  |                    |                            |                            |
| Harding Canal                                   | Browns Valley Irrigation District     | 1 000            | 6.6                | 4.5                        |                            |
| Merle Collins Reservoir<br>(Virginia Ranch Dam) | Browns Valley Irrigation District     | 900              | 5.6                | 4.9                        |                            |
| Upper Main Canal                                | Browns Valley Irrigation District     | 200              | 0.9                | 14.0                       |                            |



APPENDIX B

Field Investigations Conducted by  
the Department of Water Resources



## Field Investigations Conducted by the Department of Water Resources

From the total inventory of 285 existing facilities with a potential for hydroelectric power development the Department selected 49 representative hydraulic structures for on-site inspections. During these inspections, the physical characteristics of the site were noted, including head and flow, types of conduits, gates and valves, and environmental data. The following is a brief description of each of the 49 facilities examined.

### 1. Anderson Flume

The Anderson Flume is the elevated concrete section of the Anderson Canal that crosses Anderson Creek in the City of Anderson in Shasta County. The flume and canal are owned and operated by the Anderson-Cottonwood Irrigation District. The site is a short distance upstream from where canal's flow enters the flume; there, water is dropped from the canal to a lower irrigation ditch for local use on the north side of Anderson Creek. The head is about 7 metres (m) or 23 feet (ft), and the average flow for the five-month period from May to September is about 1 cubic metre per second (cms) or 35 cubic feet per second (cfs). The potential capacity of the site is 50 kilowatt (kW), and the average annual output would be about 180 000 kilowatthours (kWh). A 13 kV transmission line owned by PGandE is located about 61 m (200 ft) from the site.

### 2. Parkview Station

Parkview Station is an overflow spillway for the Anderson Canal in Redding in Shasta County. It is owned and operated by the Anderson-Cottonwood Irrigation District. At this point on the canal, the flow can be blocked by installing stoplogs to divert the flow through the spillway to a ditch that connects to the Sacramento River. In this way, the canal can be used as a forebay for a hydroelectric plant during the nonirrigating season of November through March. The head is about 4.6 m (15 ft), and the flow available is about 4.2 cms (150 cfs). The potential capacity is 150 kW, and the average annual output would be about 548 000 kWh. A 13 kV transmission line is located about 30.5 m (100 ft) from the facility.

### 3. Harding Canal

The Harding Canal, a water conveyance facility near Browns Valley in Yuba County, is also owned and operated by the Browns Valley Irrigation District. It is a lateral canal that begins near the outlet of the Virginia Ranch Dam diversion tunnel on Dry Creek and extends southward to Tennessee Creek which conveys the water to the District's main canal. By extending the existing Harding Canal about 0.8 km (0.5 mi) along the 335 m (1100 ft) elevation contour, a penstock and powerhouse could be constructed to develop about 91 m (300 ft) of head for hydroelectric generation. After water flows through the powerhouse, it would be delivered to the District's main canal. Assuming an average flow of 1.4 cms (50 cfs) during the irrigation season, the Harding Canal site could develop about 1 000 kW of capacity, with an annual output of about 6.6 million kWh. It would be necessary to build about 1.6 kilometres (km) or 1 mile (mi) of 13 kV transmission line across undeveloped lands to connect to an existing PGandE transmission line.

#### 4. Merle Collins Reservoir (Virginia Ranch Dam)

Virginia Ranch Dam is an earthfill structure on Dry Creek near the community of Browns Valley in Yuba County. It is owned and operated by the Browns Valley Irrigation District. The dam forms Merle Collins Reservoir from where irrigation water is diverted by a tunnel and canal system to Browns Valley. Water is released through a valve to a concrete energy dissipator channel from where it flows, by gravity, to the District's canal system. Irrigation releases are made April through October; the largest releases of 3.4 cms (120 cfs) are made during July and August. The net operating head varies from about 32 m (105 ft) at the beginning of the irrigation season to about 24 m (80 ft) at the end of the season. A 900 kW generating unit at the facility could produce about 5.6 million kWh annually. A 13 kV transmission line owned by PGandE is located about 1.6 km (1 mi) from the power plant site.

#### 5. Frenchman Dam

Frenchman Dam is an earthfill structure on Little Last Chance Creek near Portola. It is owned and operated by the Department of Water Resources. Irrigation water is released under contract to the Sierra Valley. When the dam was constructed, provisions were made for later installation of hydroelectric generation capacity. A turbine/generator unit could be installed at the site after modifying of the existing outlet works. The potential hydroelectric capacity is about 450 kW, and the estimated annual output is about 1 million kWh. The nearest transmission line is located about 8 km (5 mi) from the facility and is owned by the Sierra-Plumas Rural Electric Cooperative.

#### 6. Beardsley Diversion Dam

Beardsley Diversion Dam is another timber dam on the Kern River near Bakersfield. It is also owned and operated by the City of Bakersfield, Kern Delta Water District, and North Kern Water District. Water diverted into a canal north of and running parallel to the Kern River is also used for municipal and industrial use in Bakersfield. The dam is 1.6 km (1 mi) upstream from the Rocky Point Diversion Dam. A hydroelectric power facility constructed here could use the flow of the Kern River that is not diverted into the Beardsley Canal. At Rocky Point downstream, this water is diverted into a canal on the south side of the river. The Beardsley Diversion Dam provides about a 1.5 m (5 ft) head for hydroelectric generation. The potential generation capacity is about 500 kW, and the annual output would be about 1 747 000 kWh. A 13 kV transmission line is located near the facility.

#### 7. Rocky Point Diversion Dam

Rocky Point Diversion Dam is a timber dam on the Kern River at Bakersfield. It is owned and operated by the City of Bakersfield, Kern Delta Water District, and North Kern Water District. Water diverted into a canal south of and running parallel to the Kern River is used for municipal and industrial purposes in Bakersfield. The canal contains two check

structures, one at the head of the canal near the Rocky Point Diversion dam and the other about 1.6 km (1 mi) downstream. It may be possible to combine the two check structures to develop a hydroelectric facility which would result in about a 3.1 m (10 ft) head. The potential hydroelectric capacity is about 300 kW, and the estimated annual output is 660 000 kWh. A 13 kV transmission line owned by PGandE is located near the site.

#### 8. Glendale Distribution

The Glendale Distribution System is owned and operated by the City of Glendale in Los Angeles County. The system distributes water over a 79 sq km (30 sq mi) area. The source of water is the Metropolitan Water District of Southern California (MWD), which is connected to the Glendale Distribution System by a pressure-reducing valve used to drop the 61 m (200 ft) of pressure differential between MWD and Glendale. The average daily flow is about 0.3 cms (10 cfs). During April, May, and June, the months of maximum water demand, the average daily flow is 0.7 cms (25 cfs).

Water flows through the system continuously, and yields between 8600 and 9300 cubic dekametres (7000 and 7500 acre-feet) per year. The site proposed for a hydroelectric facility is on property owned by the City of Glendale at the northeast corner of Glendale Avenue and Glenoaks Boulevard. The potential capacity is 400 kW, and the average annual output would be about 1.98 million kWh. A 4 kV transmission line owned by the City of Glendale, is located about 16 m (50 ft) from the site. The power generated would be used by the city-owned electric utility.

#### 9. Alvarado Treatment Plant

The Alvarado facility is a pressure reduction vault at the Alvarado Water Treatment Plant located near Lake Murray. It is owned and operated by the Water Utilities Department of San Diego. Water from the second San Diego aqueduct is delivered to the site at a relatively high pressure. The pressure is then reduced by globe valves for delivery to the El Monte pipeline. The potential hydroelectric capacity is about 800 kW, and the estimated annual output would be about 5 645 000 kWh based on flows measured in 1975-76. With a projected 33 percent increase in these flows over the next five years, reconnaissance-level studies may indicate that a 1000 kW generating unit could be installed at the Alvarado facility. A transmission connection can be made.

#### 10. Miramar Treatment Plant

The Miramar facility is a pressure reduction vault near the Miramar Water Treatment Plant located east of Route 15 and north of Pomerado Road in San Diego. It is owned and operated by the Water Utilities Department of San Diego. Water from the second San Diego Aqueduct is delivered to the site at relatively high pressure. The pressure is reduced by globe valves suitable for use at this plant. The potential hydroelectric capacity is about 500 kW, and the annual output would be about 4 million kWh based on flows measured in 1975-76. These flows are expected to increase between 1980 and 1985. A transmission line owned by San Diego Gas and Electric (SDG&E) is located at the site.

#### 11. Moccasin Reregulating Dam

The Moccasin Reregulating facility (also called the Moccasin Lower site) is the afterbay for the Hetch-Hetchy hydroelectric plant; it provides the headwaters for the diversion tunnel that carries water to San Francisco via the Hetch-Hetchy Aqueduct. The site is owned and operated by the City and County of San Francisco and is located on Moccasin Creek east of Sonora in Tuolumne County. Only the water that is not diverted to the aqueduct would be available for hydroelectric generation. A 1979 feasibility study by the City of San Francisco indicated the potential capacity of the site to be 1600 kW. The average annual output was estimated at about 7 million kWh, and the cost of power production was estimated at 1.65 cents per kWh.

#### 12. Mount Olivette Pressure Break

Mount Olivette is a pipeline pressure break owned and operated by the city of Santa Monica in Los Angeles County. Water is delivered to the site from the Metropolitan Water District via a 457 millimetre (18-inch) cast-iron pipeline 1066 m (3500 ft) long. The water is delivered to the Santa Monica water distribution system for the 107 m (350 ft) pressure zone. The net operating head varies with the water flow from about 58 m to 67 m (185 ft to 215 ft) due to friction losses in the long pipeline. A 150 kW generating unit at the site could produce about 1 116 000 kWh annually. A 4 kV transmission line owned by Southern California Edison Company (SCE) is located at the site.

#### 13. Chowchilla Main Canal

The Chowchilla Main Canal carries irrigation flows diverted from the Chowchilla River. It is owned and operated by the Chowchilla Water District in Madera County. Three check structures along the canal might be used for hydroelectric generation; they are characterized by very low heads of less than 3 m (10 ft) during periods of high flows. Flows during March to June are about 7.6 cms (250 cfs) and increase to about 11.4 cms (375 cfs) from June through August. The potential capacity at each of the three sites is 150 kW to 200 kW, and the total energy output of the three sites for the five-month irrigation season would be about 2 million kWh. The District has a feasibility study in progress.

#### 14. Fresno Main Canal

The Fresno Main Canal carries irrigation flows diverted from the Kings River east of Fresno County. It is owned and operated by the Fresno Irrigation District. Six check structures, located along the canal, including the head gate, have been identified by the District as potential hydroelectric sites. The sites are characterized by very low heads of 1 m to 2 m (3 ft to 6 ft) and high flows of 27 cms (900 cfs). The District has feasibility studies in progress for the three most promising sites, which have a combined potential of 1150 kW.

#### 15. Gould Weir Diversion

Gould Weir, a diversion structure on the Kings River, is located east of Fresno downstream from Pine Flat Reservoir in Fresno County. It is

owned and operated by the Fresno Irrigation District. The weir diverts water into the Enterprise Canal for irrigation. Hydroelectric development at the facility would use water that now flows over the weir. The facility is characterized by a low head of about 2 m (6 ft) and high flows of 60 cms to 105 cms (2000 cfs to 3700 cfs) during the summer months. The potential capacity is about 850 kW, and the estimated annual output would be about 3 490 000 kWh. A 13 kV transmission line is located about 152 m (500 ft) from the facility.

#### 16. Del Loma Tunnel

The Del Loma Tunnel was constructed in the late 1800s to serve as a by-pass for waters of the Trinity River to permit gold mining in the streambed where the river makes a horseshoe bend. The tunnel is on privately-owned property about 32 km (20 mi) west of Weaverville in Trinity County. The tunnel's intake is at an elevation that allows a small part of the existing streamflow to pass through the tunnel. The available head is about 3.4 m (11 ft). The potential capacity is about 250 kW, and the average annual output would be about 1.9 million kWh. A 13 kV transmission line owned by PGandE is located about 61 m (200 ft) from the structure. Since the Trinity River has been designated as a Wild and Scenic River, any environmental impact may be significant. It would be difficult to develop the hydroelectric potential at this facility.

#### 17. Buckeye Conduit

Buckeye Conduit is an irrigation pipeline located about 3.2 km (2 mi) northeast of Georgetown in El Dorado County. It is owned and operated by the Georgetown Divide Public Utility District. The conduit carries water about 3.2 km (2 mi) from Lake Walton to the Georgetown Divide Ditch. The net head is 56 m (180 ft), with summer flows of approximately 0.8 cms (230 cfs). During wet years, this flow could be extended into the winter months. The flow is controlled by a butterfly valve and a concrete energy-dissipation structure. The potential capacity is 350 kW and the average annual output would be about 2.4 million kWh. A 13 kV transmission line owned by PGandE is located about 94 m (300 ft) from the facility.

#### 18. Stumpy Meadows Reservoir (Mark Edson Dam)

Stumpy Meadows is a reservoir formed by Mark Edson Dam, an earthfill structure on Pilot Creek 8 km (5 mi) east of Quintette in El Dorado County. It is owned and operated by the Georgetown Divide Public Utility District. The dam conserves water for irrigation and domestic use. The net head varies from 40 m to 48 m (127 ft to 154 ft), and the flow is 0.8 cms (30 cfs) for 9.5 months of the year. The potential capacity is 325 kW, and the average annual output would be about 2.2 million kWh. A single-phase, 35 kV transmission line is located about 6.4 km (4 mi) from the site. Development of a hydroelectric plant at the site would require the construction of 6.4 km (4 mi) of a 13 kV transmission line and upgrading the existing 14.5 km (9 mi) single-phase transmission line to a three-phase line.

19. Ruth Reservoir (Robert W. Matthews Dam)

Robert W. Matthews Dam is an earthfill structure owned and operated by the Humboldt Bay Municipal Water District on the Mad River. It is located about 8 km (5 mi) west of Forest Glen in Trinity County. The dam, which creates Ruth Reservoir, was constructed in 1962 to provide water for Humboldt Bay, Eureka, Arcata, McKinleyville, and several other agencies. The average flow into the reservoir exceeds its storage capacity and is discharged through the spillway. The potential capacity is about 1600 kW, and the average annual output would be about 8.3 million kWh. The District has received a loan from the U.S. Department of Energy to study the feasibility of installing hydroelectric facilities at Matthews Dam.

20. Alamo Drop 3A

Alamo Drop 3A, a concrete overflow structure on the agriculture drainage system flowing into the Salton Sea, is located near Calipatria in Imperial County. It is owned and operated by the Imperial Irrigation District. The net head is about 4.9 m (16 ft), and the maximum design flow would be about 33 cms (1100 cfs). The potential capacity is about 1200 kW, and the average annual output would be about 6.7 million kWh. Construction of 1.6 km (1 mi) of 13 kV transmission line along a dirt road through agriculture lands to the District's electric system would be required.

21. No. 8 Heading

No. 8 Heading is a check structure on the Westside Main Canal about 8 km (5 mi) northwest of Imperial in Imperial County. It is owned and operated by the Imperial Irrigation District. The net head is about 4.6 m (15 ft) and the maximum design flow is about 22 cms (775 cfs). The potential capacity is about 750 kW, and average annual output would be about 3 911 000 kWh. A 13 kV transmission line owned by the District is located at the site.

22. Tuberose Check

Tuberose is a check structure on the Eastside Main Canal located about 11 km (7 mi) north of Imperial in Imperial County. It is owned and operated by the Imperial Irrigation District. The site is just upstream from Turnip Check where the District installed hydroelectric generation in 1964. The nominal head at Turnip Check is 5 m (16 ft), and the installed capacity is 420 kW; the annual output is about 2 million kWh. The net head at Tuberose is about 3 m (10 ft), and the available flows would be the same as at the downstream Turnip site. The potential capacity at Tuberose is about 200 kW, and the average annual output would be about 1.3 million kWh. A 13 kV transmission line owned by the District is located at the site.

23. Vail Heading

Vail Heading is a series of low-head check structures closely spaced in staircase fashion along the Vail Supply Canal about 9.7 km (6 mi) east of Calipatria in Imperial County. The canal is owned and operated by the Imperial Irrigation District. Vail Heading includes eleven drops with a total height of 13.7 m (45 ft). The greatest drop occurs in the first 0.8 km (0.5 mi) at the rate of 5 m (16 ft) per 305 m (1000 ft) of canal

length. About 500 kW of capacity could be developed at the first drop of the Vail Supply Canal using a steel conduit about 610 m (2000 ft) long. A 13 kV transmission line owned by the District is located at the facility.

#### 24. Lake Amador Jackson Creek Dam

Lake Amador is formed by Jackson Creek Dam, an earthfill structure about 1.6 km (1 mi) southeast of Ione in Amador County. It is owned and operated by the Jackson Valley Irrigation District. Lake Amador provides water for irrigation and domestic uses. Reservoir releases are divided at the outlet works to divert one-half of the discharge into a pipeline into Jackson Creek. The Jackson Creek discharges could be used for hydroelectric generation. In an average year, the reservoir yield could maintain a discharge rate of 0.8 cms (30 cfs) from January through October. The net head would range from 52 m (168 ft) in winter months to 47 m (150 ft) in October. The potential capacity is 350 kW, and the average annual output would be about 2.5 million kWh. A 13 kV transmission line owned by PGandE is located at the facility.

#### 25. Pacoima Dam

Pacoima Dam, a concrete arch structure, is located near San Fernando in Los Angeles County. It is owned and operated by the Los Angeles County Flood Control District in Pacoima Canyon. The Pacoima Reservoir regulates flood flows which result from brief but intense storms that normally occur during the winter months. Thus, the releases are of short durations that extend from a few days to two weeks and vary widely in flow between 0.3 cms to 4.5 cms (10 cfs to 150 cfs). Based on the field investigation and on a preliminary review of discharge data, the installation of hydroelectric facilities at Pacoima Dam was not considered to be compatible with the dam's primary purpose of flood control.

#### 26. San Gabriel Dam

San Gabriel Dam, an earthfill structure, is located on the San Gabriel River near Glendora in Los Angeles County. It is owned and operated by the Los Angeles County Flood Control District. The dam is used for flood control and to deliver water to the Azusa conduit. Hydroelectric generation units could be installed on the Azusa conduit at the existing regulating valve and energy dissipators. The net head would vary from about 30.5 m to 45.7 m (100 ft to 150 ft). The potential power capacity is about 500 kW, and the average annual output would be about 3 million kWh. A 13 kV transmission line is located at the facility. The District is studying the feasibility of installing hydroelectric facilities.

#### 27. West Coast Basin Barrier

The West Coast Basin site is a pressure-reduction facility on a pipeline located in a vault under El Segundo Boulevard, near the Los Angeles International Airport. It is owned and operated by the Los Angeles County Flood Control District. Valves reduce water pressure from 1138 to 552 kilopascals (165 psi to 80 psi). The site is a part of the West Coast Basin Barrier Project where water is injected into wells along the coastline to repel seawater intrusion into the ground water basin. The potential capacity is about 500 kW, and the average annual output would be

about 4.2 million kWh. The facility can be connected to the electricity distribution system.

#### 28. Eastside Pipeline

The Eastside Pipeline is a water conveyance facility located near Lost Hills in Kern County. It is owned and operated by the Lost Hills Water District. The pipeline, constructed of precast concrete sections, is about 3000 m (10,000 ft) long. It delivers water from the State Water Project's California Aqueduct to an irrigation ditch in the District. The drop over the length of the pipeline is about 16 m (52 ft) and the capacity is 8.5 cms (300 cfs), although the pipeline has never operated at full capacity. The field inspection showed the pipeline to be unsuitable for hydroelectric generation because the concrete pipe cannot be pressurized.

#### 29. Lake Shastina (Shasta River Dam)

The Shasta River Dam at Lake Shastina is a hydraulic-fill earthfill structure owned and operated by the Montague Water Conservation District. It is located about 16 km (10 mi) southeast of Grenada in Siskiyou County. The dam, built in 1928, is used to conserve water for irrigation in the Shasta Valley and for urban use in Montague. Water is released during the irrigation season from mid-April through mid-September. The net head is about 15 m (50 ft) at the beginning of the irrigation season and decreases to about 10 m (32 ft) at the end of the season. The potential capacity is about 200 kW, and the average annual output would be about 741 000 kWh. A 13 kV transmission line owned and operated by the Pacific Power and Light Company is about 300 m (1000 ft) from the site.

#### 30. Pumping Plant Lower

Pumping Plant Lower, a drop between upper and lower irrigation canals, is located about 6.4 km (4 mi) east of Montague in Siskiyou County. It is owned and operated by the Montague Water Conservation District. The plant was constructed in the 1920s to use the hydraulic energy of water falling from the upper canal to the lower canal to pump a part of that water to an elevation higher than the upper canal. However, the facilities were not used for that purpose. The site is now operated to drop water 12 m (40 ft) during the irrigation season from mid-April to mid-September. Flows range from 0.3 cms to 0.7 cms (10 cfs to 24 cfs), with the higher flows occurring in June, July, and August. The potential capacity is 65 kW, and the average annual output would be about 172,000 kWh. A 13 kV transmission line owned by Pacific Power and Light Company is located at the facility.

#### 31. Picay Pressure Break

The Picay Pressure Break is an unpressurized, concrete vault owned and operated by the Montecito County Water District near Santa Barbara in Santa Barbara County. It is located on a water conveyance facility that carries water from Jameson Lake through the Santa Ynez Mountains via the Doulton Tunnel, and then, by way of a steel pipe about 1558 m (5000 ft) long to the Picay vault. The average flow is about 0.1 cms (2.5 cfs), and the gross head is 200 m (655 ft). The water level in the Picay vault provides the head for conveying water to the Bella Vista Reservoir via

another pipeline. Since all of the gross head is lost through friction in the pipeline, the existing facility provides no head for hydroelectric generation.

#### 32. Lyons Dam

Lyons Dam is a concrete arch structure owned and operated by PGandE on the South Fork of the Stanislaus River, about 24 km (15 mi) northeast of Sonora in Tuolumne County. The dam diverts river water into the Tuolumne Canal for municipal and industrial use. The existing discharge is dropped into a stilling basin at the foot of the dam; this serves as an energy dissipator. The potential capacity of the facility is about 300 kW, using one of the two existing outlet valves, and the annual output would be about 1.5 million kWh. A 13 kV transmission line owned by PGandE is located at the facility.

#### 33. San Vicente

The San Vicente site is at the outlet of a tunnel that conveys water from the first San Diego Aqueduct to San Vicente Lake. The facility is owned and operated by the Water Utilities Department of San Diego and is located north of Lakeside and east of Route 67. The outfall basin at the tunnel outlet also provides head pressure for a pipeline that by-passes San Vicente Lake. A hydroelectric facility could be constructed at the facility by installing a penstock from the tunnel outfall basin to a power plant on the shore of San Vicente Lake. This facility has a potential of about 850 kW. If the tunnel flow were discharged through the power plant into San Vicente Lake rather than diverted through the pipeline, the estimated annual output would be about 3.4 million kWh. It would be necessary to build a 13 kV transmission line for a distance of about 8 km (5 mi).

#### 34. Sidney N. Peterson Treatment Plant

The Sidney N. Peterson water treatment plant is located near Folsom on the boundary between Placer and Sacramento Counties. It is owned and operated by the San Juan Suburban Water District. Water from Folsom Reservoir is carried to the site by a pipe tapped into the Folsom-Roseville Pipeline. The pipeline is pressurized by the head from the Folsom Reservoir. The gross head at the plant varies from zero to 9.4 m (30 ft) usually with a net head of 5.6 m to 7.8 m (18 ft to 25 ft) during May through July. The potential capacity is about 175 kW, and the annual output would be about 350 000 kWh.

#### 35. Chesbro Dam

Chesbro Dam, an earthfill structure on Llagas Creek, is located about 13 km (8 mi) northwest of Gilroy in Santa Clara County. It is owned and operated by the South Santa Clara Valley Water Conservation District. The dam conserves water which is released between January and June for percolation into the groundwater basin from where it will be pumped from wells for irrigation. The releases are coordinated with diversions from Uvas Dam to Llagas Creek. The net head varies from about 11 m to 18 m (35 ft to 60 ft), and the discharge varies from 0.3 cms to 1.3 cms (10 cfs

to 47 cfs). The potential capacity is 100 kW, and the average annual output would be about 216 300 kWh. A 13 kV transmission line owned by PGandE is about 156 m (500 ft) from the facility.

36. Uvas Dam

Uvas Dam, an earth structure on Uvas Creek, about 10 km (6 mi) northwest of Gilroy in Santa Clara. It is owned and operated by the South Santa Clara Valley Water Conservation District. This dam also conserves water for percolation and later use for irrigation. Releases are either discharged into Uvas Creek or diverted to Llagas Creek via a 6.4 km (4 mi) concrete pipeline. The water released into Uvas Creek could be used for hydroelectric generation. The effective head ranges from 10 m to 25 m (34 ft to 82 ft). Water is released between January and August. The potential capacity is 300 kW, and the average annual output would be about 1 042 000 kWh. A 13 kV transmission line is about 150 m (500 ft) from the site.

37. Black Butte Dam

Black Butte Dam is an earthfill structure located on Stoney Creek near Orland in Glenn and Tehama Counties. It is owned and operated by the U.S. Army Corps of Engineers. The dam provides flood control, irrigation, and recreation. Its flood control operation requires the availability of storage space from September through June. Irrigation water is diverted through a gate house adjacent to the energy dissipator at the outlet works. The net head varies from 21 m to 31 m (70 ft to 100 ft), and the average monthly flows vary from 6 cms to 65 cms (200 cfs to 2300 cfs). The potential capacity is about 9200 kW, and the annual output would be about 31.3 million kWh. To develop the full potential capacity, a transmission line of either 34 kV or 69 kV and about 14.5 km (9 mi) long would be needed.

38. Hensley Lake (Hidden Dam)

Hidden Dam is a federally-owned earthfill structure operated by the U.S. Army Corps of Engineers on the Fresno River, east of Madera in Madera County. The dam's primary function is flood control. The net head varies from 17 m to 31 m (55 ft to 100 ft), and the flows range from 0.3 cms to 6.4 cms (10 cfs to 210 cfs). The potential capacity is about 1500 kW, and the average annual output is about 4 million kWh. A 13 kV transmission line owned by PGandE is located at the facility.

39. H.V. Eastman Lake (Buchanan Dam)

Buchanan Dam is a federally-owned earthfill structure operated by the U.S. Army Corps of Engineers on the Chowchilla River, east of Chowchilla in Madera County. The dam's primary function is flood control. The net head varies from 39 m to 42 m (125 ft to 135 ft) and the average monthly flows range from 0.3 cms to 8.8 cms (10 cfs to 310 cfs). The potential capacity is 3000 kW and the average annual output would be about 9 million kWh. A 13 kV transmission line owned by PGandE is located at the facility.

#### 40. Lake Kaweah (Terminus Dam)

Terminus Dam is a federally-owned earthfill structure operated by the U.S. Army Corps of Engineers on the Kaweah River about 32 km (20 mi) upstream from Visalia in Tulare County. Although the dam provides both flood control and irrigation, its primary function is flood control. The net head varies from 22 m to 50 m (70 ft to 160 ft), and the flows vary from 3 cms to 41 cms (100 cfs to 1450 cfs). The potential capacity is about 4000 kW and the annual output would be about 20 million kWh. A 13 kV transmission line owned by PGandE is located at the facility.

#### 41. Lemoncove Ditch

The Lemoncove facility is an alternate, partially-hydroelectric development of Terminus Dam. Terminus Dam is a flood control dam located about 32 km (20 mi) upstream from Visalia on the Kaweah River in Tulare County. It is owned and operated by the U.S. Army Corps of Engineers. The dam outlet works contain a separate conduit used exclusively to deliver water to Lemoncove Ditch. Since the conduit can carry flows in excess of the water required for Lemoncove Ditch, it could be redeveloped and used for both water deliveries and hydroelectric generation. The potential capacity is about 650 kW, and the annual output would be about 3 482 000 kWh. A 13 kV transmission line owned by PGandE is located at the site.

#### 42. New Hogan Dam

New Hogan Dam is a federally-owned earthfill structure operated by the U.S. Army Corps of Engineers on the Calaveras River, near the community of Jenny Lind in Calaveras County. The dam's primary function is flood control. The net head varies from 41 m to 47 m (130 ft to 150 ft), and the flows vary from 0.8 cms to 15 cms (30 cfs to 530 cfs). The potential capacity is about 2250 kW and the annual output would be about 8 million kWh. A 13 kV transmission line is located at the facility.

#### 43. All-American Canal Drop No. 5

Drop No. 5 is a check structure on the All-American Canal and is located about 8 km (5 mi) east of Calexico in Imperial County. It is owned by WPRS and is operated by the Imperial Irrigation District. Under a contract with WPRS, the District is amortizing the federal investment and will own the site when the contract expires in a few years. When the structure was built, the foundations and radial gates for a future powerhouse were included. The net head is about 7.3 m (24 ft) and design flow for hydroelectric generation is 91 cms (3000 cfs). The District estimates the potential capacity to be 5000 kW and annual output would be 24 million kWh. The District is studying the feasibility of installing hydroelectric facilities at Drop No. 5.

#### 44. Jenkinson Lake (Sly Park Dam)

Sly Park Dam, an earthfill structure owned by WPRS and operated by the El Dorado Irrigation District, is located on Sly Park Creek near Pollock Pines in El Dorado County. Sly Park Creek joins Camp Creek downstream from the dam and flows into the Consumnes River. The facility stores water for irrigation and domestic use throughout western El Dorado County. The net

head varies from 37 m to 53 m (120 ft to 170 ft). The average monthly flows during the irrigation season vary from 0.7 cms to 1.9 cms (24 cfs to 67 cfs). The potential capacity is about 650 kW, and the annual output would be about 1 848 000 kWh. A 13 kV transmission line owned by PGandE is located at the facility.

#### 45. North Portal Tecolote

Tecolote Intake, a diversion facility at the north portal of the Tecolote Tunnel, diverts water from Lake Cachuma to the South Coast area of Santa Barbara County. The Cachuma Project, of which the Tecolote Tunnel is a part, was designed and built by the U.S. Water and Power Resources Service (WPRS) for the Santa Barbara County Water Agency. The Cachuma Operation and Maintenance Board operates the facility for four water districts and the City of Santa Barbara. It may be possible to install a small turbine/generator unit in the gate chamber structure at the Tecolote Intake. The design of the unit would present a challenge due to the size of the gate chamber which requires entry through an elevator. Assuming an average flow of 0.9 cms (32 cfs) and a head of 26 m (85 ft) the potential hydroelectric capacity is about 175 kW, and the estimated annual output is 720 000 kWh. A 13 kV transmission line owned by PGandE is located at the facility.

#### 46. Stampede Dam

Stampede Dam is an earthfill structure owned and operated by WPRS. It is located on the Little Truckee River, near Truckee in Sierra County. The dam is used for flood control and water conservation. Large releases of about 14 cms to 28 cms (500 cfs to 1000 cfs) are made during May to replenish Pyramid Lake. When the facility was constructed, provisions were made to install hydroelectric generation later. The net head varies from 57 m to 65 m (186 ft to 212 ft), and the average monthly flows, excluding the Pyramid Lake releases, vary from 1.7 cms to 5.7 cms (60 cfs to 200 cfs). The potential capacity is about 3000 kW, and the annual output would be about 17 million kWh. A 13 kV transmission line owned by Sierra-Pacific Power Company is located at the facility.

#### 47. Sonoma Reservoir

Sonoma Reservoir consists of two tanks which contain 7.6 and 22.7 megalitres (2 million and 6 million gallons) of water in the City of Sonoma, in Sonoma County. The tanks provide both storage and water pressure for water distribution. They are owned and operated by the Valley of the Moon Water District. A valve at the reservoir inlet reduces pressure from the Sonoma pipeline, which carries water from the Russian River. The valve is an altitude-control type which responds to the level of water stored in the tanks. It may be possible to install a hydroelectric generation unit at this site, but the design would pose a significant challenge due to the wide range of heads and flows. The potential capacity is about 50 kW; the average annual output would be about 210 000 kWh. A 13 kV transmission line owned by PGandE is located at the site.

#### 48. Clear Lake Dam

Clear Lake Dam is a concrete structure located about 4 km (2.5 mi) east of Lower Lake in Lake County. It is owned and operated by the Yolo County Flood and Water Conservation District. The dam, built in 1914, determines the water surface level of Clear Lake. The stored water is used for irrigation in Yolo County. The net head varies from 7.5 m to 9.3 m (24.5 ft to 30.5 ft), and the flows range between 0.09 cms and 42.4 cms (3 cfs and 1400 cfs). The greatest discharges occur January through March, when flows average about 34 cms (1200 cfs). Summer discharges (June through August) average about 13 cms (450 cfs). The potential capacity is about 2000 kW; the average annual output would be about 7.5 million kWh. A single-phase 13 kV transmission line owned by PGandE is located at the site. It would be necessary to upgrade about 2.4 km (1.5 mi) of the existing transmission line to three-phase by adding a third conductor.

#### 49. Indian Valley Dam

Indian Valley Dam is an earthfill structure on Cache Creek, near Clear Lake in Lake County. It is owned and operated by the Yolo County Flood Control and Water Conservation District. The dam is used for flood control and irrigation. Since the dam was completed in 1976, the reservoir has never been filled to capacity. Based on the reservoir yield indicated in a feasibility report supporting a loan application under Public Law 984, the potential capacity is about 3200 kW, and the average annual output would be about 7.2 million kWh. Since electrical transmission facilities are not available at the site, a 13 kV transmission line 15 km to 16 km (9 mi to 10 mi) long would be needed.



APPENDIX C

Preliminary Feasibility Studies for 28 Representative  
Facilities, Prepared by the Department of Water Resources



## APPENDIX C

### Preliminary Feasibility Studies for 28 Representative Facilities, Prepared by the Department of Water Resources

Preliminary feasibility studies are made to determine if a proposed hydroelectric project has sufficient merit and potential value to warrant further investigation and the commitment of development funds. This type of study is also called an appraisal or reconnaissance study.

The amount of detail covered in a preliminary study depends on the availability of site-specific information such as construction drawings of the existing hydraulic structures, records of water flow covering a period long enough to allow the average monthly flow to be estimated, and enough data to determine the average monthly head at the proposed power facility.


Such site-specific information was available for some of the 28 representative sites discussed below. When it was available, a reasonably complete study was made. For other sites, however, much of this information was lacking and only general estimates were prepared. With only sketchy information and a visual inspection of the site, the study was superficial. Because of this, the 28 preliminary feasibility studies discussed here vary in scope from detailed quantitative analyses to relatively qualitative narratives with conclusions based largely on professional judgment. However, in all cases the preliminary feasibility studies were sufficient to enable the site developer to apply to the Federal Energy Regulatory Commission (FERC) for a Preliminary Permit or a License Exemption (see Appendix F), or to the U.S. Department of Energy (DOE) for a feasibility study loan (see Appendix H). The 28 facilities are described in this chapter, and the results of a preliminary feasibility study of each are summarized in Table C.



Table C. Summary of Preliminary Feasibility Studies for 28 Representative Facilities

| Site  | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Cost<br>(\$/kW) | Annual Cost (% of Project Cost) |      |            |      |            |      | Average Cost of Generation (\$/kWh) |      |            |      |            |      |
|---|------------------|--------------------|---------------------------|-------------------------|---------------------------------|------|------------|------|------------|------|-------------------------------------|------|------------|------|------------|------|
|   |                  |                    |                           |                         | 20-yr Debt                      |      | 35-yr Debt |      | 20-yr Debt |      | 35-yr Debt                          |      | 20-yr Debt |      | 35-yr Debt |      |
|   |                  |                    |                           |                         | 9%                              | 15%  | 9%         | 15%  | 9%         | 15%  | 9%                                  | 15%  | 9%         | 15%  | 9%         | 15%  |
| 1. Alamo Drop 3A (Canal)                            | 1200             | 6.7                | 64                        | 2312                    | 19.6                            | --   | --         | 15.4 | --         | --   | 7.2                                 | --   | --         | 6.4  | --         | --   |
| 2. Anderson Flume                                   | 50               | 0.2                | 41                        | 5518                    | 20.5                            | 24.0 | 25.8       | 18.6 | 22.4       | 24.2 | 31.4                                | 36.7 | 39.5       | 28.5 | 34.3       | 37.0 |
| 3. Beardsley Diversion                              | 500              | 1.7                | 40                        | 8062                    | 15.5                            | 19.0 | 20.8       | 13.6 | 17.4       | 19.2 | 35.8                                | 43.9 | 48.1       | 31.5 | 40.2       | 44.4 |
| 4. Black Butte Dam                                  | 9200             | 31.3               | 39                        | 1717                    | 14.6                            | 18.1 | 19.9       | 12.7 | 16.5       | 18.3 | 7.4                                 | 9.1  | 10.0       | 6.4  | 8.3        | 9.2  |
| 5. Buckeye Conduit                                  | 350              | 2.4                | 79                        | 2451                    | 17.2                            | 20.7 | 22.5       | 15.3 | 19.1       | 20.9 | 6.1                                 | 7.4  | 8.0        | 5.4  | 6.8        | 7.4  |
| 6. Chesbro Reservoir                                | 100              | 0.2                | 25                        | 5343                    | 16.8                            | 20.3 | 22.1       | 14.9 | 18.7       | 20.5 | 41.5                                | 50.1 | 54.6       | 36.8 | 46.2       | 50.6 |
| 7. Clear Lake Imp. Dam                              | 2000             | 7.5                | 43                        | 2469                    | 14.4                            | 17.9 | 19.7       | 12.5 | 16.3       | 18.1 | 9.5                                 | 11.7 | 12.9       | 8.2  | 10.7       | 11.9 |
| 8. Del Loma Tunnel                                  | 250              | 1.9                | 87                        | 5138                    | 17.0                            | 20.5 | 22.3       | 15.1 | 18.9       | 20.7 | 11.5                                | 13.9 | 15.1       | 10.2 | 12.8       | 14.9 |
| 9. Frenchman Dam                                    | 450              | 1.0                | 26                        | 3657                    | 14.4                            | 17.9 | 19.7       | 12.5 | 16.3       | 18.1 | 23.0                                | 28.6 | 31.4       | 20.0 | 26.0       | 28.9 |
| 10. Glendale Distribution                           | 400              | 2.0                | 57                        | 2558                    | 15.3                            | --   | --         | 13.3 | --         | --   | 7.9                                 | --   | --         | 6.9  | --         | --   |
| 11. Gould Weir Diversion                            | 850              | 3.5                | 47                        | 7499                    | 14.9                            | 18.4 | 20.2       | 13.0 | 16.8       | 18.6 | 27.1                                | 33.5 | 36.8       | 23.7 | 30.6       | 33.9 |
| 12. Harding Canal                                   | 1000             | 6.6                | 75                        | 2077                    | 16.1                            | 19.6 | 21.4       | 14.2 | 18.0       | 19.8 | 5.1                                 | 6.2  | 6.8        | 4.5  | 5.7        | 6.3  |
| 13. Indian Valley Dam                               | 3200             | 7.2                | 26                        | 1648                    | 16.2                            | 19.7 | 21.5       | 14.3 | 18.1       | 19.9 | 11.8                                | 14.4 | 15.7       | 10.5 | 13.2       | 14.6 |
| 14. Jonkison Lake<br>(Sly Park Dam)                 | 650              | 1.8                | 33                        | 2208                    | 16.0                            | 19.5 | 21.3       | 14.1 | 15.5       | 19.7 | 12.4                                | 15.1 | 16.5       | 10.9 | 12.0       | 15.3 |
| 15. Lake Amador<br>(Jackson Creek Dam)              | 350              | 2.5                | 83                        | 2566                    | 16.0                            | 19.5 | 21.4       | 14.2 | 17.9       | 19.7 | 5.7                                 | 6.9  | 7.5        | 5.0  | 6.3        | 7.0  |
| 16. Lake Shastina<br>(Shasta River Dam)             | 200              | 0.7                | 40                        | 3608                    | 15.7                            | 19.2 | 21.0       | 13.8 | 17.6       | 19.4 | 15.2                                | 18.7 | 20.4       | 13.4 | 17.1       | 18.9 |
| 17. Lemnacoove Ditch<br>(At Terminus Dam)           | 650              | 3.5                | 61                        | 2754                    | 16.8                            | 20.3 | 22.1       | 14.9 | 19.3       | 20.5 | 8.6                                 | 10.4 | 11.4       | 7.7  | 9.6        | 10.5 |
| 18. Merle Collins Reservoir<br>(Virgilia Ranch Dam) | 900              | 5.6                | 71                        | 2314                    | 15.0                            | 18.5 | 20.3       | 13.1 | 16.9       | 18.7 | 5.5                                 | 6.8  | 7.5        | 4.8  | 6.2        | 6.9  |
| 19. Mount Olivette                                  | 150              | 1.1                | 84                        | 3646                    | 18.1                            | 21.6 | 23.4       | 16.2 | 20.0       | 21.8 | 8.8                                 | 10.6 | 11.4       | 7.9  | 9.8        | 10.7 |
| 20. No. 8 Heading (Canal)                           | 750              | 3.9                | 59                        | 3382                    | 17.4                            | --   | --         | 15.4 | --         | --   | 11.3                                | --   | --         | 10.0 | --         | --   |
| 21. North Portal Tecolote                           | 175              | 0.7                | 46                        | 6993                    | 15.1                            | 18.6 | 20.4       | 13.2 | 17.0       | 18.8 | 25.7                                | 31.6 | 34.7       | 22.4 | 28.9       | 32.0 |
| 22. Parkview Station                                | 150              | 0.5                | 38                        | 4030                    | 16.2                            | 20.0 | 21.6       | 14.4 | 18.2       | 20.0 | 18.0                                | 21.1 | 23.8       | 15.8 | 20.0       | 22.0 |
| 23. Pumping Plant Lower                             | 65               | 0.2                | 30                        | 5331                    | 19.0                            | 22.5 | 24.3       | 17.1 | 20.9       | 22.7 | 38.3                                | 45.3 | 48.9       | 34.4 | 42.1       | 45.7 |
| 24. Rocky Point Diversion                           | 300              | 0.7                | 25                        | 4150                    | 15.1                            | 18.6 | 20.4       | 13.2 | 17.0       | 18.8 | 28.4                                | 35.0 | 38.4       | 24.8 | 32.0       | 35.4 |
| 25. Stumpy Meadows Reservoir<br>(Clark Edison Dam)  | 325              | 2.2                | 76                        | 4652                    | 14.1                            | 17.6 | 19.4       | 12.2 | 16.0       | 17.8 | 9.9                                 | 12.3 | 13.6       | 8.5  | 11.2       | 12.4 |
| 26. Uvas Dam  | 300              | 1.0                | 40                        | 3267                    | 15.8                            | 19.3 | 21.1       | 13.9 | 17.7       | 19.5 | 14.9                                | 18.2 | 19.9       | 13.1 | 16.7       | 18.4 |
| 27. Vail Heading (Canal)                            | 225              | 1.0                | 52                        | 6167                    | 15.2                            | --   | --         | 13.1 | --         | --   | 20.6                                | --   | --         | 17.8 | --         | --   |
| 28. West Coast Basin Barrier                        | 500              | 4.2                | 96                        | 2270                    | 17.0                            | 20.5 | 22.3       | 15.1 | 18.0       | 20.7 | 4.6                                 | 5.5  | 6.0        | 4.1  | 5.1        | 5.6  |

Figure C-1A Alamo Drop 3A Powerplant



## 1. Alamo Drop 3A

The Alamo Drop 3A site is a concrete overflow structure near Calipatria in Imperial County on the agriculture drainage system flowing into the Salton Sea (Fig. C-1A). It is owned and operated by the Imperial Irrigation District.

Site Characteristics. The existing structure is about 13.7 metres (m) or 45 feet (ft) wide, and discharges streamflows over a 4.9 m (16 ft) drop. The structure includes two spillways, one on each side of a concrete overflow section. The spillways have radial gates 2.4 m (8 ft) wide; the ungated center section is 16.8 m (55 ft) wide. Under normal-flow conditions the water is discharged through the spillways; water overflows the center section only during high-water conditions. The spillways and the central ungated weir have a series of short baffle piers near their downstream ends.

Potential Generation. A horizontal, tube-type turbine is considered for installation at this site because of the constantly low head of about 4.6 m (15 ft). Since the flows range between 20 cms and 34 cms (700 cfs and 1200 cfs)--cubic-metre-per-second and cubic-feet-per-second--for eleven months of the year, a fixed-propeller runner would produce about 90 percent of the potential energy at the site.





The potential installed capacity would be 1200 kW, and the estimated annual generation is about 6.7 million kWh (Table C-1A).

Table C-1A. Energy Generation for Alamo Drop 3A Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 4.8  | 15.8 | 11.2  | 396   | --             | --            | --              |
| February  | 4.7  | 15.4 | 17.8  | 624   | 60             | 487           | 328 000         |
| March     | 4.6  | 15.0 | 26.0  | 916   | 77             | 893           | 666 000         |
| April     | 4.5  | 14.8 | 35.0  | 1235  | 84             | 1296          | 935 000         |
| May       | 4.5  | 14.8 | 29.9  | 1055  | 84             | 1107          | 826 000         |
| June      | 4.6  | 15.0 | 22.0  | 777   | 73             | 723           | 522 000         |
| July      | 4.6  | 15.0 | 24.1  | 852   | 74             | 798           | 595 000         |
| August    | 4.6  | 15.0 | 24.9  | 880   | 75             | 835           | 623 000         |
| September | 4.6  | 15.0 | 27.4  | 966   | 79             | 966           | 697 000         |
| October   | 4.6  | 15.0 | 25.3  | 892   | 76             | 858           | 640 000         |
| November  | 4.6  | 15.0 | 20.2  | 713   | 67             | 613           | 442 000         |
| December  | 4.7  | 15.3 | 19.3  | 681   | 65             | 572           | 426 000         |
| Total     |      |      |       |       |                |               | 6 700 000       |

New Power Plant Structures. The proposed generating facility includes an intake, about 5.7 m (18.7 ft) wide, on the right side of the existing ungated weir; a horizontal standard tube-type turbine; and a tailrace channel about 15 m (49.2 ft) long (Fig. C-1B). The turbine would develop 1600 hp under the available head and would be connected, through a speed increaser, to a horizontal air-cooled synchronous generator with a rated

Figure C-1B



STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES  
IMPERIAL REGION DISTRICT  
ALAMO DROP 3A  
BROWN POWER PLANT  
POWERHOUSE - PLAN AND SECTION

NOTE:  
THIS PLAN AND THE SECTION THEREON, EXCEPT AREA  
SET FORTH HEREIN, SHALL BE VOID IN THE EVENT OF ANY  
CONFLICT WITH ANY OTHER PLAN OR SECTION.

output of 1200 kW. An inlet gate installed in front of the turbine would enable dewatering of the turbine for maintenance.

Since the water at this site is relatively salty agriculture waste water, the potential effect of this water on the turbine runner was discussed with a turbine manufacturer. The water is not expected to cause significant problems since the turbine would have stainless steel blades and would be working under a low head, well out of the range where cavitation could occur.

About 1.6 kilometres (km) or 1 mile (mi) of a 13 kV transmission line would have to be built from the site to the District's distribution system. The new transmission line would follow a dirt road through agricultural land.

Cost of the New Power Plant. The estimated cost of the new generating facility is \$1,699,300, based on January 1980 prices. About 36 months will be required for completing the feasibility study, obtaining approvals, and building. Although most of the water used for generation will be agricultural waste water, the stream channel at the site is a natural river bed and, as such, may not be exempt from federal licensing requirements. (The exemption provision is discussed in detail in Appendix F.)

If the project were initiated in 1981 and 36 months were required to obtain approvals, arrange financing, design, and build the project, the work would be completed in early 1984. At an inflation rate of 12 percent, the estimated project cost in 1984 is \$2,773,900 (Table C-1B).

Table C-1B. Project Cost for Alamo Drop 3A Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$1,219,300 |
| Transmission Facilities                       | 45,000      |
| Subtotal                                      | \$1,264,300 |
| Contingencies (20%)                           | 252,900     |
| Total   | \$1,517,200 |
| Engineering and Administration (12%)          | 182,100     |
| Total Construction Cost (January 1980 Prices) | \$1,699,300 |
| Escalation (4 yrs. at 12% per year)           | 974,600     |
| Total Construction Cost (January 1984 Prices) | \$2,673,900 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$2,773,900 |
| Cost per kW (1200 kW)                         | \$ 2,312    |

Cost of Generation. Since this facility and the electric transmission and distribution system are owned and operated by the Imperial Irrigation

District, it is assumed that the District would develop and use the power in its own electric system. The annual cost of owning and operating the project would include debt repayment, operation and maintenance costs, insurance, replacements, administration, and overhead.

It is assumed that the District would finance construction by issuing tax-exempt revenue bonds, and that the bonds could be issued for a 35-year term at 9 percent interest. The actual interest rate would depend on financial conditions when the bonds were issued. It is expected that initial development would be financed from electric system revenues or short-term loans and that the bonds would not be issued until about 12 months before the project is completed. The additional cost of operating the plant would be insignificant, since the District already has a full staff of operating personnel. Regular maintenance could be scheduled during the nonirrigation season when there would be no water for power generation.

If the project were scheduled for an on-line date early in 1984, the bond issue would be about \$3,350,000, based on January 1980 bid prices, with a 12 percent annual inflation rate for 35-year bonds and a one-year construction period (Table C-1C).

Table C-1C. Annual Cost for Alamo Drop 3A Project

| Cost Item                       | Amount             |                    |
|---------------------------------|--------------------|--------------------|
|                                 | 20-year<br>Bonds   | 35-year<br>Bonds   |
| Project Cost                    | \$2,773,900        | \$2,773,900        |
| Capitalized Interest            | 249,600            | 249,600            |
| Interest Earnings               | (124,800)          | (124,800)          |
| <b>Total Capital Cost</b>       | <b>\$2,898,700</b> | <b>\$2,898,700</b> |
| Bond Reserve Fund               | 373,600            | 317,000            |
| Financing Cost                  | 134,700            | -134,300           |
| Bond Issue                      | \$3,407,000        | \$3,350,000        |
| Debt Service (9% interest)      | \$ 373,200         | \$ 317,000         |
| Operation and Maintenance       | 27,200             | 27,200             |
| Insurance                       | 107,700            | 107,700            |
| Interim Replacements            | 6,100              | 6,100              |
| Interest Earnings               | (28,500)           | (28,500)           |
| <b>Total Annual Cost</b>        | <b>\$ 485,700</b>  | <b>\$ 429,500</b>  |
| Annual Cost (% of Project Cost) | 19.6               | 15.4               |
| Average Cost (per kWh)          | 7.2¢               | 6.4¢               |

The estimated average generation cost, assuming 35-year bonds, is \$429,500 or 6.4 cents per kWh (Table C-1C). With 20-year bonds, the estimated average generation cost would increase to 7.2 cents per kWh.

Since the District has experience with small hydroelectric facilities, it might elect to be self-insured--in full or in part--to reduce the annual

insurance premium on mechanical and electrical equipment. This would reduce its annual generation cost substantially.

Value of Generation. Since the District would probably use the energy produced in its own electric system, the estimated average avoidable cost is about 4.5 cents per kWh, at 1980 price levels. This will be discussed in the preliminary feasibility study for the "No. 8 Heading" site which is also owned by the District. The projected value of energy is discussed in Appendix G, and the estimates of partial-peak energy are assumed to be applicable to the Alamo Drop 3A output. The assumed value for capacity is \$100 per kW per year.


Based on this, the estimated value of Alamo Drop 3A generation in 1984 is \$742,500 or 11.1¢ per kWh (Table C-1D).

Table C-1D. Generation Value for Alamo Drop 3A Project

| <u>Item</u>                    | <u>Amount</u> |
|--------------------------------|---------------|
| Capacity (June Capacity)       |               |
| 725 kW at \$100 per kW         | \$ 72,500     |
| Energy                         |               |
| 6.7 million kWh at 10¢ per kWh | 670,000       |
| Total                          | \$742,500     |
| Average Value (per kWh)        | 11.1¢         |

Conclusions. Since the estimated value of Alamo Drop 3A generation, exceeds the estimated cost of generation (6.4 to 7.2 cents per kWh), the project would be cost effective during its first year of operation, and additional benefits would accrue during subsequent years as the price of oil increases. The cost of Alamo Drop 3A generation would change little from year to year, since only the cost of maintaining the facility is subject to inflation.

Figure C-2A Anderson Flume Powerplant



## 2. Anderson Flume

The Anderson Flume site is a turnout on the Anderson Canal, a short distance upstream from the point where the canal enters an overhead concrete flume across Anderson Creek. The canal and turnout are owned and operated by the Anderson-Cottonwood Irrigation District, and are located in Anderson in Shasta County (Fig. C-2A). The turnout drops water from the canal to a lower irrigation ditch for local use on the north side of Anderson Creek.

Site Characteristics. The existing structures consist of an intake in the Anderson Canal with a small diameter steel pipe of unknown size. The water discharges into a concrete energy dissipater box from where it then flows into a lower irrigation ditch. The difference in elevation between the water surface in the canal and the lower ditch is about 7 m (23 ft). Detailed flow records are not maintained, but operating personnel estimate an average flow of about 1 cms (35 cfs) between May and September. A 13 kV transmission line, owned by PGandE, is located about 61 m (200 ft) from the site.

Potential Generation. Assuming an average flow of 1 cms (35 cfs), the potential installed capacity would be 50 kW, and the estimated average annual output would be 180 000 kWh. Since the Sacramento River provides water for both the canal and the proposed hydroelectric site, it is expected that the 180 000 kWh output could be sustained even during dry years.

New Power Plant Structures. A turbine-generator installed at the downstream end of the steel turnout pipe (where the concrete energy dissipater is located) could use the 7 m (23 ft) available head. The proposed generating facility includes an intake structure and new steel penstock, 0.9 m (3 ft) in diameter, to carry water to a vertical turbine which could develop 83 hp under the available head (Fig. C-2B). The turbine would be connected, through a speed increaser, to a horizontal generator with a rated output of 50 kW. Since the turbine would have wicket gates, a shutoff valve would be unnecessary. The intake structure would include a small gate for dewatering the entire penstock and powerhouse. If a more in-depth study of this site is made, the use of other types of turbines, such as a constant flow propeller-type, should be considered.

Cost of the New Power Plant. The estimated cost of the new generating facility is \$160,100, based on January 1980 prices. Since the new facility would be located on a manmade conduit and would use existing property, it would probably be exempt from federal licensing requirements, and the environmental approval process would be simplified.

If the project were initiated in 1981 and about 18 months were needed to obtain approvals and build the project, work should be completed in late 1982 for operation in 1983. The estimated project cost in late 1983, with 12 percent inflation, is \$251,900 (Table C-2A).

Figure C-2B




Table C-2A. Project Cost for Anderson Flume Plant

| Cost Item                                     | Amount     |
|---|------------|
| Direct Cost                                   |            |
| Hydroelectric Plant Facilities                | \$ 106,000 |
| Transmission Facilities                       | 10,000     |
| Subtotal                                      | \$ 116,000 |
| Contingencies (20%)                           | 23,200     |
| Total   | \$ 139,200 |
| Engineering and Administration (15%)          | 20,900     |
| Total Construction Cost (January 1980 Prices) | \$ 160,100 |
| Escalation (4 yrs. at 12% per year)           | 91,800     |
| Total Construction Cost (January 1984 Prices) | \$ 251,900 |
| Studies, Licensing, Permits and Approvals     | 24,000     |
| Total   | \$ 275,900 |
| Cost per kW (50 kW)                           | \$ 5,518   |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-2B). Regular maintenance could be scheduled during the winter months when there is insufficient water for generation.

Table C-2B. Annual Operating Cost for Anderson Flume Project

| Cost Item                 | Amount   |
|---------------------------|----------|
| Operation and Maintenance | \$13,000 |
| Insurance                 | 8,500    |
| Interim Replacements      | 500      |
| Total                     | \$22,000 |

The annual cost of owning and operating the project range between 19 and 27 percent of the direct project cost of \$251,900 depending on financing. The estimated cost of generation ranges between 28.5 cents and 39.5 cents per kWh (Table C-2C).




Table C-2C. Average Energy Cost of Anderson Flume Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt  |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$ 34,500     | \$ 44,100 | \$ 49,100 |
| Operating Cost            | 22,000        | 22,000    | 22,000    |
| Total Annual Cost         | \$ 56,500     | \$ 66,100 | \$ 71,100 |
| Average Cost (per kWh)    | 31.4¢         | 36.7¢     | 39.5¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 29,200     | \$ 39,700 | \$ 44,700 |
| Operating Cost            | 22,000        | 22,000    | 22,000    |
| Total Annual Cost         | \$ 51,200     | \$ 61,700 | \$ 66,700 |
| Average Cost (per kWh)    | 28.5¢         | 34.3¢     | 37.0¢     |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh, using the median CEC oil-cost projection for future costs of electrical energy.

Conclusions. Since the estimated value of Anderson Flume generation is significantly less than the estimated cost of generation (28.5 to 39.5 cents per kWh), the project if constructed by 1984 would probably not be cost effective until 1993. This is based on the projected energy rates shown in Table 8, Chapter II.

Figure C-3A Beardsley Diversion Dam Powerplant



### 3. Beardsley Diversion Dam

Beardsley Dam is a diversion structure on the Kern River in Bakersfield in Kern County (Fig. C-3A). It is owned and operated by the City of Bakersfield, Kern Delta Water District, and North Kern Water District. The dam diverts water into a canal which parallels the north side of the Kern River. The site is characterized by a low head and relatively large flows during the summer months.

Site Characteristics. The Beardsley Diversion Dam is a wood timber structure about 80 m (262 ft) long and 3 m (10 ft) high. Timber construction was used because of the sandy stream bed. A 13 kV transmission line is located about 100 m (300 ft) from the site.

Potential Generation. The potential installed capacity is 500 kW, and the estimated average annual output is about 1.7 million kWh (Table C-3A).


Table C-3A. Energy Generation for Beardsley Diversion Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 1.5  | 5    | 11.3  | 399   | 84             | 125           | 93 000          |
| February  | 1.5  | 5    | 8.8   | 310   | 83             | 109           | 73 000          |
| March     | 1.5  | 5    | 16.0  | 564   | 79             | 188           | 140 000         |
| April     | 1.5  | 5    | 13.8  | 488   | 77             | 159           | 114 000         |
| May       | 1.5  | 5    | 16.2  | 571   | 80             | 193           | 144 000         |
| June      | 1.5  | 5    | 35.7  | 1262  | 84             | 448           | 323 000         |
| July      | 1.5  | 5    | 41.4  | 1463  | 80             | 495           | 368 000         |
| August    | 1.5  | 5    | 36.8  | 1301  | 84             | 462           | 344 000         |
| September | 1.5  | 5    | 9.8   | 345   | 84             | 123           | 88 000          |
| October   | 1.5  | 5    | 6.9   | 243   | 78             | 80            | 60,000          |
| November  | 1.5  | 5    | 3.5   | 125   | --             | --            | --              |
| December  | 1.5  | 5    | 4.9   | 172   | --             | --            | --              |
| Total     |      |      |       |       |                |               | 1 747 000       |

New Power Plant Structures. Four small turbine-generator units could be installed at the dam because of the widely varying flow. They would use the 1.5 m (5 ft) head available at the site. The proposed generating facility would include an approach channel, about 22 m (72 ft) long, excavated into the river bank on the left abutment of the dam; the channel would carry water to the four standard propeller-type turbines then return it to the river through a short tailrace channel (Fig. C-3B).

The four fixed-blade turbines with runners 1829 mm (72 in)--mili-metres and inches, respectively--in diameter could develop 168 hp each under the available head. Each turbine would be connected, through a gear box speed increaser, to a generator with a rated output of 125 kW. The total power plant capacity would be 500 kW. Inlet gates installed upstream from the turbines would be used to partially dewater the units for inspection. Only one or two intake gates would be needed, since all units would not be inspected at the same time.

Figure C-3B



STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES

CITY OF BAKERSFIELD

BEARDSLEY DIVERSION  
 500kW POWER PLANT  
 POWERHOUSE - PLAN AND SECTION

NOTE:  
 ENGLISH UNITS IN BRACKETS

SECTION A-A

Cost of the New Power Plant. The estimated cost of building the generating facility is \$2,498,500, based on January 1980 prices (Table 3B). If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983 (with 12 percent annual inflation) is \$4,031,400 (Table C-3B).

Table C-3B. Project Cost for Beardsley Diversion Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$1,784,000 |
| Transmission Facilities                       | 75,000      |
| Subtotal                                      | \$1,859,000 |
| Contingencies (20%)                           | 371,800     |
| Total   | \$2,230,800 |
| Engineering and Administration (12%)          | 267,700     |
| Total Construction Cost (January 1980 Prices) | \$2,498,500 |
| Escalation (4 yrs. at 12% per year)           | 1,432,900   |
| Total Construction Cost (January 1984 Prices) | \$3,931,400 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$4,031,400 |
| Cost per kW (500 kW)                          | \$ 8,062    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-3C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-3C. Annual Operating Cost for Beardsley Diversion Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 52,000 |
| Insurance                 | 59,500    |
| Interim Replacements      | 10,700    |
| Total                     | \$122,200 |

The annual costs of owning and operating the project would range between 14 and 21 percent of the direct project cost of \$4,031,400, depending on financing. The estimated cost of generation ranges between 31.5 cents and 48.1 cents per kWh (Table C-3D).





Table C-3D. Average Cost of Energy for Beardsley Diversion Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$503,900     | \$645,000 | \$717,600 |
| Operating Cost            | 122,200       | 122,200   | 122,200   |
| Total Annual Cost         | \$626,100     | \$767,200 | \$839,800 |
| Average Cost (per kWh)    | 35.8¢         | 43.9¢     | 48.1¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$427,300     | \$580,500 | \$653,100 |
| Operating Cost            | 122,200       | 122,200   | 122,200   |
| Total Annual Cost         | \$549,500     | \$702,700 | \$775,300 |
| Average Cost (per kWh)    | 31.5¢         | 40.2¢     | 44.4¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of energy produced at the Beardsley Diversion facility is significantly less than the estimated generation cost (31.5 to 48.1 cents per kWh), the project if constructed by 1984 is not expected to be cost effective until 1994. This is based on the projected energy rates shown in Table 8, Chapter II.

Figure C-4A Black Butte Dam Powerplant



#### 4. Black Butte Dam

Black Butte Dam is a rolled earthfill structure, owned and operated by the U. S. Army Corps of Engineers on Stony Creek near Orland in Glenn and Tehama Counties (Fig. C-4A). The dam provides flood control, irrigation, and recreation.


The reservoir is operated primarily for flood control and water conservation. Flood control operation requires the availability of water storage from September through June. Storage amounts to a maximum of 197 000 cubic dekametres (160,000 ac-ft) between October 1 and March 1. The dam's flood protection is vital to the urban areas of Orland and Hamilton City, and to about 25 900 hectares (64,000 acres) of highly-developed agriculture land along the lower reaches of Stony Creek. The project is a unit of the comprehensive plan for flood control and other uses in the Sacramento River Basin.

Black Butte Reservoir also provides an average of 70 100 cubic dekametres (56,800 ac-ft) of water for downstream irrigation. The irrigation water is delivered to the Orland South Main Canal.




Site Characteristics. Black Butte Dam has a maximum height of about 73 m (140 ft) above the streambed and a crest length of 905 m (2,970 ft). Controlled releases from the reservoir are made through the dam's lower outlet located in the right abutment of the dam. The outlet works consist of a combined intake and control tower, control house, circular concrete lined tunnel, 7 m (23 ft) in diameter, outlet portal, energy dissipater, and irrigation diversion structure. Combined flood-control and irrigation releases are regulated by five 2 m by 4.3 m (6.5 ft by 14 ft) hydraulically-operated service gates and five similar emergency slide gates housed in the gate chamber of the control tower. Diversion to the South Side Canal for irrigation is made by a gate house at the tunnel outlet adjacent to the energy dissipater.

Potential Generation. Two vertical Francis turbines with electric generators, rated at 4600 kW each, are considered for installation at Black Butte. The potential annual output is estimated at about 31.3 million kWh (Table C-4A).

Figure C-4B



STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES  
U.S. ARMY CORPS OF ENGINEERS  
**BLACK BUTTE DAM**  
**9200W POWER PLANT**  
GENERAL PLAN



ALONG  $\phi$  TUNNEL,  $\phi$  MANIFOLD,  $\phi$  PIERCEWAY &  $\phi$  DRAFT TUBE  
0 10 20 METERS

**NOTE:**  
DIMENSIONS IN INCHES.

Table C-4A. Energy Generation for Black Butte Dam Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 24.7 | 81   | 66.1  | 2334  | 84             | 9200          | 6 844 000       |
| February  | 25.9 | 85   | 46.6  | 1644  | 84             | 9200          | 6 182 000       |
| March     | 29.9 | 98   | 30.2  | 1067  | 72             | 6370          | 4 739 000       |
| April     | 30.5 | 100  | 20.6  | 729   | 84             | 5181          | 3 730 000       |
| May       | 29.3 | 96   | 19.4  | 697   | 82             | 4642          | 3 454 000       |
| June      | 27.1 | 89   | 17.1  | 605   | 77             | 3508          | 2 526 000       |
| July      | 25.0 | 82   | 16.1  | 569   | 76             | 3000          | 2 232 000       |
| August    | 23.2 | 76   | 13.9  | 491   | 68             | 2147          | 1 597 000       |
| September | 21.3 | 70   | 10.6  | 373   | --             | --            | --              |
| October   | 19.8 | 65   | 5.7   | 200   | --             | --            | --              |
| November  | 21.3 | 70   | 1.5   | 52    | --             | --            | --              |
| December  | 23.8 | 78   | 10.3  | 365   | --             | --            | --              |
| Total     |      |      |       |       |                |               | 31 304 000      |

New Power Plant Structures. A hydroelectric facility installed near the downstream end of the lower outlet could use the available head of about 14 m to 24.7 m (46 ft to 81 ft). The proposed generating facility includes a new intake about 135 m (443 ft) northeasterly of the existing intake, a short 3.4 m (11 ft) diameter concrete lined shaft, a 3.4 m (11 ft) diameter concrete lined tunnel, a 3.4 m (11 ft) manifold, and two 2.4 m (7.8 ft) steel penstocks, which would convey the water to two vertical Francis turbines (Figs. C-4B and C-4C).

Each turbine could develop 6160 hp under the available head and would be connected directly to a vertical, air-cooled synchronous generator with a rated output of 4600 kW. The turbine draft tubes discharge the water into the existing energy dissipater. Each unit can be dewatered for maintenance without interfering with the operation of the other unit by closing the upstream butterfly valve, and by installing stop logs downstream of the draft tube. The intake, which houses a slide gate with a hoist mechanism, is located at an elevation of 144.5 m (474 ft), which is the elevation of the existing ungated spillway crest. Construction of the new generating facilities would probably have minimal impact on the operation of the existing installation.

Transmission Facilities. A 13 kV transmission line is available at the site; the nearest high voltage line is about 14.5 km (9 mi) away. Since the 9200 kW generating capacity being considered for the Black Butte project is significantly larger than what can be carried by the 13 kV line, a detailed study of the transmission capacity and power flows in the project area should be made to determine what additional facilities would be required to handle project generation. Alternatives to be considered include increasing the conductor size of the existing transmission system or building a higher voltage line about 14.5 km (9 mi) long. Reconductoring the existing line would be the preferable alternative both economically and environmentally. However, a new higher voltage line may be necessary



to increase transmission capacity. For this preliminary feasibility study, it was assumed that a new transmission line of higher cost would be required.

Cost of the New Power Plant. The estimated cost of building the new generating facilities is \$9,977,900, based on January 1980 prices (Table 4B). If the project were initiated in 1981, and about 24 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work would be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent inflation, is \$15,800,400 (Table C-4B).

Table C-4B. Project Cost for Black Butte Dam Plant

| Cost Item                                     | Amount       |
|---|--------------|
| Direct Cost                                   |              |
| Hydroelectric Plant Facilities                | \$ 6,924,000 |
| Transmission Facilities                       | 500,000      |
| Subtotal                                      | \$ 7,424,000 |
| Contingencies (20%)                           | 1,484,800    |
| Total   | \$ 8,908,800 |
| Engineering and Administration (12%)          | 1,069,100    |
| Total Construction Cost (January 1980 Prices) | \$ 9,977,900 |
| Escalation (4 yrs. at 12% per year)           | 5,722,500    |
| Total Construction Cost (January 1984 Prices) | \$15,700,400 |
| Studies, Licensing, Permits, and Approvals    | 100,000      |
| Total   | \$15,800,400 |
| Cost per kW (9 200 kW)                        | \$ 1,717     |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-4C). Regular maintenance could be scheduled during the autumn months when there is insufficient water for power generation.

Table C-4C. Annual Operating Cost for Black Butte Dam Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$126,000 |
| Insurance                 | 170,000   |
| Interim Replacements      | 31,800    |
| Total                     | \$327,800 |



The annual cost of owning and operating the project would range between 13 and 20 percent of the direct project costs of \$15,800,400, depending on financing. The estimated cost of generation ranges between 6.4 cents and 10.0 cents per kWh (Table C-4D).


Table C-4D. Average Cost of Energy for Black Butte Dam Project

| Cost Item                 | Amount        |             |             |
|---------------------------|---------------|-------------|-------------|
|                           | Interest Rate |             |             |
|                           | 9%            | 12%         | 15%         |
| For 20-year term of debt: |               |             |             |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%       | 17.8%       |
| Fixed Annual Cost         | \$1,975,000   | \$2,528,000 | \$2,812,400 |
| Operating Cost            | 327,800       | 327,800     | 327,800     |
| Total Annual Cost         | \$2,302,800   | \$2,855,800 | \$3,140,200 |
| Average Cost (per kWh)    | 7.4¢          | 9.1¢        | 10.0¢       |
| For 35-year term of debt: |               |             |             |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%       | 16.2%       |
| Fixed Annual Cost         | \$1,674,800   | \$2,275,200 | \$2,559,600 |
| Operating Cost            | 327,800       | 327,800     | 327,800     |
| Total Annual Cost         | \$2,002,600   | \$2,603,000 | \$2,887,400 |
| Average Cost (per kWh)    | 6.4¢          | 8.3¢        | 9.2¢        |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydro-electric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. The estimated value of Black Butte generation exceeds the estimated cost of generation for interest rates from 9 to 12 percent (6.4 to 10.0 cents per kWh). Thus, the project would be cost effective during the first year of operation for interest rates up to about 11.5 percent for a 20-year debt, and would break even during the second year of operation for interest rate of 15 percent. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of Black Butte generation would change little from year to year, since only the maintenance cost of the facility is subject to inflation.

Figure C-5A Buckeye Powerplant



## 5. Buckeye Conduit

Buckeye Conduit is an irrigation pipeline owned and operated by the Georgetown Divide Public Utility-District. It is located about 3.2 km (2 mi) northeast of Georgetown in El Dorado County (Fig. C-5A). The conduit carries water about 3.2 km (2 mi) from Lake Walton to the Georgetown Divide Ditch.

Site Characteristics. The hydraulic structure consists of a concrete pipe, 762 mm (30 in) in diameter and about 3.2 km (2 mi) long, that tapers to a 457 mm (18 in) pipe where the conduit enters a concrete energy dissipater box. The flow is controlled by a 457 mm (18 in) butterfly valve. When the water leaves the energy dissipater it flows through a reinforced-concrete pipe 1067 mm (42 in) in diameter and is discharged into the Georgetown Divide Ditch. A 13 kV transmission line is located about 91 m (300 ft) from the site.


Potential Generation. The potential capacity of the site would be about 350 kW, and the estimated average annual output is about 2.4 million kWh (Table C-5A).

Table C-5A. Energy Generation for Buckeye Conduit Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 126 000         |
| February  | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 234 000         |
| March     | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 259 000         |
| April     | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 251 000         |
| May       | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 259 000         |
| June      | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 251 000         |
| July      | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 259 000         |
| August    | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 259 000         |
| September | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 251 000         |
| October   | 54.9 | 180  | 0.8   | 27    | 85             | 350           | 259 000         |
| November  | 54.9 | 180  | --    | --    | --             | --            | --              |
| December  | 54.9 | 180  | --    | --    | --             | --            | --              |
| Total     |      |      |       |       |                |               | 2 408 000       |

New Power Plant Structures. A turbine-generator installed at the Buckeye Conduit outlet could use the 55 m (180 ft) available head. The proposed generating facility includes a steel pipe by-pass, 457 mm (18 in) in diameter, beginning about 4 m (13 ft) upstream from the existing energy dissipater and carrying the water to a horizontal Francis turbine (Fig. C-5B). The turbine could develop 470 hp under the available head and would be connected directly to a horizontal, air-cooled synchronous generator with a rated output of 350 kW. The operation of the hydroelectric plant would be separated from that of the existing installation by a butterfly valve installed upstream from the turbine. A short tailrace channel would discharge the water into the Georgetown Divide Ditch.

Figure C-5B



NOTE:  
DIMENSIONS IN BRACKETS

STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES

GEORGETOWN DIVIDE PUBLIC UTILITY DISTRICT  
BUCKEYE CONDUIT  
350 kW POWER PLANT  
POWERHOUSE - PLAN AND SECTION

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$513,400, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$857,800 (Table C-5B).

Table C-5B. Project Cost for Buckeye Conduit Plant

| Cost Item                                     | Amount     |
|---|------------|
| <b>Direct Cost</b>                            |            |
| Hydroelectric Plant Facilities                | \$ 367,000 |
| Transmission Facilities                       | 15,000     |
| Subtotal                                      | \$ 382,000 |
| Contingencies (20%)                           | 76,400     |
| Total   | \$ 458,400 |
| Engineering and Administration (12%)          | 55,000     |
| Total Construction Cost (January 1980 prices) | \$ 513,400 |
| Escalation (4 yrs. at 12% per year)           | 294,400    |
| Total Construction Cost (January 1984 prices) | \$ 807,800 |
| Studies, Licensing, Permits, and Approvals    | 50,000     |
| Total   | \$ 857,800 |
| Cost per kW (350 kW)                          | \$ 2,451   |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-5C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-5C. Annual Operating Cost for Buckeye Conduit Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 20,400 |
| Insurance                 | 17,000    |
| Interim Replacements      | 3,000     |
| Total                     | \$ 40,400 |

The annual cost of owning and operating the project would range between 15.3 and 22.5 percent of the direct project costs depending on financing. The estimated cost of generation ranges between 5.4 cents and 8.0 cents per kWh (Table C-5D).




Table C-5D. Average Cost of Energy for Buckeye Conduit Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$107,200     | \$137,200 | \$152,700 |
| Operating Cost            | 40,400        | 40,400    | 40,400    |
| Total Annual Cost         | \$147,600     | \$177,600 | \$193,100 |
| Average Cost (per kWh)    | 6.1¢          | 7.4¢      | 8.0¢      |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 90,900     | \$123,500 | \$139,000 |
| Operating Cost            | 40,400        | 40,400    | 40,400    |
| Total Annual Cost         | \$131,300     | \$163,900 | \$179,400 |
| Average Cost (per kWh)    | 5.4¢          | 6.8¢      | 7.4¢      |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is further assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future costs of electrical energy.

Conclusions. Since the estimated value of Buckeye Conduit generation exceeds the estimated cost of generation (5.4 to 8.0 cents per kWh), the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of Buckeye Conduit generation would change little from year to year because only the maintenance cost of the facility is subject to inflation.

Figure C-6A Chesbro Dam Powerplant



## 6. Chesbro Reservoir

Chesbro Reservoir is a water conservation facility owned and operated by the South Santa Clara Valley Water Conservation District. It is located on Llagas Creek about 13 km (8 mi) northwest of Gilroy in Santa Clara County (Fig. C-6A). Water released during the irrigation season percolates into the ground water basin from where it is pumped from wells and used for irrigation.

Site Characteristics. Chesbro Dam, officially Elmer J. Chesbro Dam, is an earth structure approximately 32 m (105 ft) high and 210 m (690 ft) long, at its crest. The intake in the reservoir has two 1.1 m (3.5 ft) square horizontal hydraulic slide gates.


Controlled releases are made from the reservoir through the dam's lower outlet--a steel pipe, 1.4 m (4.7 ft) in diameter and 185 m (607 ft) long, encased in a reinforced-concrete jacket. Flow through the outlet is controlled by a 1.4 m (4.5 ft) valve in a control structure at the downstream end of the outlet pipe. A 13 kV transmission line is located 152 m (500 ft) from the site.

Potential Generation. The potential capacity would be 100 kW, and the estimated average annual output is 216 600 kWh (Table C-6A).

Table C-6A. Energy Generation for Chesbro Reservoir Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 11.6 | 38   | 0.3   | 11    | --             | --            | --              |
| February  | 17.4 | 57   | 1.0   | 36    | 84             | 100           | 67 200          |
| March     | 18.6 | 61   | 0.5   | 19    | 65             | 64            | 47 600          |
| April     | 10.7 | 35   | 0.3   | 10    | --             | --            | --              |
| May       | 10.7 | 35   | 1.3   | 47    | 84             | 100           | 74 400          |
| June      | 14.6 | 48   | 0.5   | 17    | 55             | 38            | 27 400          |
| July      | 11.3 | 37   | --    | --    | --             | --            | --              |
| August    | --   | --   | --    | --    | --             | --            | --              |
| September | --   | --   | --    | --    | --             | --            | --              |
| October   | --   | --   | --    | --    | --             | --            | --              |
| November  | --   | --   | --    | --    | --             | --            | --              |
| December  | --   | --   | --    | --    | --             | --            | --              |
| Total     |      |      |       |       |                |               | 216 600         |

New Power Plant Structures. A turbine-generator installed at the downstream end of the existing lower outlet pipe could use the 11.6 m to 19.8 m (38 ft to 65 ft) available head at the Chesbro site. The proposed generating facility includes a 1.4 m (4.7 ft) diameter steel pipe by-pass starting about 4 m (13 ft) upstream from the existing outlet control structure which carries water to a Francis turbine (Fig. C-6B). The turbine could develop 160 hp under a 20 m (65 ft) head. The turbine would be connected, through a gear box speed increaser, to a generator having a rated output of 100 kW. The operation of the hydroelectric plant and of the existing



STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES  
 SOUTH SANTA CLARA VALLEY WATER  
 CONSERVATION DISTRICT  
**CHESSBRO DAM**  
 100 KW POWER PLANT  
 GENERAL PLAN

installation would be kept separate by a butterfly valve installed upstream from the turbine.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$307,800, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were needed to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$534,300 (Table C-6B).

Table C-6B. Project Cost for Chesbro Reservoir Plant


| Cost Item                                     | Amount    |
|---|-----------|
| Direct Cost                                   |           |
| Hydroelectric Plant Facilities                | \$214,000 |
| Transmission Facilities                       | 15,000    |
| Subtotal                                      | \$229,000 |
| Contingencies (20%)                           | 45,800    |
| Total   | \$274,800 |
| Engineering and Administration (12%)          | 33,000    |
| Total Construction Cost (January 1980 prices) | \$307,800 |
| Escalation (4 yrs. at 12% per year)           | 176,500   |
| Total Construction Cost (January 1984 prices) | \$484,300 |
| Studies, Licensing, Permits, and Approvals    | \$ 50,000 |
| Total   | \$534,300 |
| Cost per kW (100 kW)                          | \$ 5,343  |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-6C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-6C. Annual Operating Cost for Chesbro Reservoir Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 8,500     |
| Interim Replacements      | 1,300     |
| Total                     | \$ 22,800 |

The annual cost of owning and operating the project would range between 15 and 22 percent of the direct project cost of \$534,300,



depending on financing. The estimated cost of generation ranges between 36.8 cents and 54.6 cents per kWh (Table C-6D).


Table C-6D. Average Cost of Energy for Chesbro Reservoir Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$ 66,800     | \$ 85,500 | \$ 95,100 |
| Operating Cost            | 22,800        | 22,800    | 22,800    |
| Total Annual Cost         | \$ 89,600     | \$108,300 | \$117,900 |
| Average Cost (per kWh)    | 41.5¢         | 50.1¢     | 54.6¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 56,600     | \$ 76,900 | \$ 86,600 |
| Operating Cost            | 22,800        | 22,800    | 22,800    |
| Total Annual Cost         | \$ 79,400     | \$ 99,700 | \$109,400 |
| Average Cost (per kWh)    | 36.8¢         | 46.2¢     | 50.6¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE at its published price for small hydroelectric facilities of 100 kW or less. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh, using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of Chesbro Dam generation is significantly less than the estimated cost of generation (36.8 to 54.6 cents per kWh), the project if constructed by 1984 would probably not be cost effective until 1996. This is based on the projected energy rates shown in Table 8, Chapter II.

Figure C-7A Clear Lake Dam Powerplant



## 7. Clear Lake Impounding Dam

Clear Lake Impounding Dam is owned and operated by the Yolo County Flood Control and Water Conservation District. It is located about 4 km (2.5 mi) east of Lower Lake in Lake County (Fig. C-7A). The dam, built in 1914, establishes the water level of Clear Lake; stored waters are released for irrigation.

Site Characteristics. The dam is a concrete structure about 12 m (40 ft) high and 90 m (295 ft) long. Controlled releases from the reservoir can be made through fifteen lower outlets which have hydraulically-operated slide gates. Originally, a small water wheel located in a concrete structure at the north end of the dam was used to generate the power that operated the slide gates, but the waterwheel has been removed.

A single-phase 13 kV transmission line is located at the site. It would be necessary to upgrade about 2.4 km (1.5 mi) of this existing line to three-phase capacity by adding a third conductor.





Potential Generation. Two turbine-generator units are considered for installation at Clear Lake Dam because of the monthly pattern of releases. The potential capacity would be 2000 kW, and the estimated average annual output is 7.5 million kWh (Table C-7A).

Table C-7A. Energy Generation for Clear Lake Impounding Dam Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 9.1  | 30   | 28.6  | 1009  | 84             | 2000          | 1 488 000       |
| February  | 9.1  | 30   | 39.0  | 1378  | 84             | 2000          | 1 344 000       |
| March     | 9.1  | 30   | 30.0  | 1060  | 84             | 2000          | 1 488 000       |
| April     | 9.1  | 30   | 17.3  | 609   | 84             | 1000          | 720 000         |
| May       | 9.1  | 30   | 11.5  | 407   | 84             | 868           | 646 000         |
| June      | 8.5  | 28   | 13.6  | 481   | 84             | 957           | 689 000         |
| July      | 8.2  | 27   | 13.8  | 486   | 84             | 933           | 694 000         |
| August    | 7.9  | 26   | 10.5  | 372   | 78             | 638           | 475 000         |
| September | 7.6  | 25   | 5.4   | 188   | --             | --            | --              |
| October   | 7.3  | 24   | 1.2   | 42    | --             | --            | --              |
| November  | 7.6  | 25   | 0.1   | 3     | --             | --            | --              |
| December  | 7.9  | 26   | 3.5   | 123   | --             | --            | --              |
| Total     |      |      |       |       |                |               | 7 544 000       |

New Power Plant Structures. Turbines and generators installed at the existing Clear Lake Impounding Dam could use the 9.1 m (30 ft) available head. The proposed generating facility would use the two (of the existing fifteen) lower outlets nearest the left abutment of the dam as intakes for two standard tube-type turbine units (Fig. C-7B). The turbines would have 1.5 m (5 ft) diameter runners and could develop 1341 hp each under the available head. Each turbine would be connected, through a gear box speed increaser, to an air-cooled synchronous generator with a rated output of

Figure C-7B



LEGEND:  
EXISTING CONCRETE  
NEW CONCRETE

NOTE:  
1. ELEVATIONS TAKEN FROM YOLO WATER AND POWER CO. DRAWING  
2. DIMENSIONS APPROXIMATE TO CENTERLINE OF CHANNEL BOTTOM.  
3. JULY 1962, REVISED JAN 17, 1963  
2. ENGLISH UNITS IN BRACKETS

STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES  
YOLO COUNTY FLOOD CONTROL AND  
WATER CONSERVATION DISTRICT  
CLEAR LAKE DAM  
2000 KW POWER PLANT  
POWERHOUSE - PLAN AND SECTION

1000 kW for a total capacity of 2000 kW. An inclined turbine-generator arrangement was selected to minimize cost.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$3,075,100, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were needed to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$4,938,400 (Table C-7B).

Table C-7B. Project Cost for Clear Lake Impounding Dam Plant

| Cost Item                                     | Amount      |
|---|-------------|
| <b>Direct Cost</b>                            |             |
| Hydroelectric Plant Facilities                | \$2,238,000 |
| Transmission Facilities                       | 50,000      |
| Subtotal                                      | \$2,288,000 |
| Contingencies (20%)                           | 457,600     |
| Total   | \$2,745,600 |
| Engineering and Administration (12%)          | 329,500     |
| Total Construction Cost (January 1980 prices) | \$3,075,100 |
| Escalation (4 yrs. at 12% per year)           | 1,763,300   |
| Total Construction Cost (January 1984 prices) | \$4,838,400 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$4,938,400 |
| Cost per kW (2 000 kW)                        | \$ 2,469    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-7C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-7C. Annual Operating Cost for Clear Lake Impounding Dam Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 26,000 |
| Insurance                 | 59,500    |
| Interim Replacements      | 10,200    |
| Total                     | \$ 95,700 |



The annual cost of owning and operating the project would range between 12.5 and 20 percent of the direct project cost of \$4,938,400, depending on financing. The estimated cost of generation ranges between 8.2 cents and 12.9 cents per kWh (Table C-7D).


Table C-7D. Average Cost of Energy for Clear Lake Impounding Dam Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$617,300     | \$790,100 | \$879,000 |
| Operating Cost            | 95,700        | 95,700    | 95,700    |
| Total Annual Cost         | \$713,000     | \$885,800 | \$974,700 |
| Average Cost (per kWh)    | 9.5¢          | 11.7¢     | 12.9¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$523,500     | \$711,100 | \$800,000 |
| Operating Cost            | 95,700        | 95,700    | 95,700    |
| Total Annual Cost         | \$619,200     | \$806,800 | \$895,700 |
| Average Cost (per kWh)    | 8.2¢          | 10.7¢     | 11.9¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydro-electric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. The estimated minimum value of Clear Lake generation is within the range of estimated costs to develop the site (8.2 to 12.9 cents per kWh). Thus, the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of Clear Lake generation would change little from year to year because only the maintenance cost of the facility is subject to inflation.

Figure C-8A Del Loma Powerplant



## 8. Del Loma Tunnel

The Del Loma Tunnel was constructed in the late 1800s as a by-pass for the Trinity River to enable gold mining in the stream bed where the river makes a horseshoe bend. The tunnel is owned by Mr. George Costa, and is located about 32 km (20 mi) west of the community of Weaverville in Trinity County (Fig. C-8A). The Trinity River was designated a federal Wild and Scenic River, and any development, including hydroelectric power, cannot alter the existing environment.

Site Characteristics. The existing hydraulic facility consists of a rectangular concrete intake structure, located on the river bank just upstream from the point where the river begins to make a horseshoe bend; a tunnel, about 2.7 m (9 ft) in diameter and 137 m (450 ft) long, cut through solid rock; and an outlet which returns the water to the river at the other end of the horseshoe bend. The intake structure consists of a rectangular opening 8.5 m (28 ft) wide with three vertical railroad rails spaced 2.1 m (7 ft) apart. The depth of the Trinity River at the opening of the intake structure determines how much water flows through the tunnel. The elevation at the intake invert is 338 m (1109 ft), and the elevation at the outlet invert is 337 m (1105 ft). The outlet is located about 1.5 m (5 ft) above the stream bed resulting in a net available head of about 3.4 m (11 ft). A 13 kV transmission line is located about 61 m (200 ft) from the site.

Potential Generation. No records are available for water flows through the tunnel. Considering the location of the intake structure along the river bank, the estimated flow through the tunnel is 8.5 cms (300 cfs). The potential capacity would be 250 kW, and the estimated average annual output is about 1.9 million kWh allowing 700 hours per year for routine maintenance.

New Power Plant Structures. A hydraulic turbine and electric generator installed at the downstream end of the tunnel could use the 3.4 m (11 ft) head. The proposed generating facility includes an unproved vertical Samson-type of Francis turbine which could develop 352 hp under the available head (Fig. C-8B). The turbine would be connected, through a gear box speed increaser, to a horizontal generator with a rated output of 250 kW.

An open-flume type of power plant would be situated against the hill at the existing tunnel outlet portal. About 15 m to 20 m (50 ft to 66 ft) of the tunnel approach to the powerhouse would be lined with concrete to provide a uniform flow to the turbine. It might be necessary to line other portions of the tunnel if weak zones of rock are present.

Cost of the New Power Plant. The estimated package cost of the new generating facility is \$752,800, based on January 1980 prices. If the project were initiated in 1981 and about 30 to 36 months were required to obtain approvals, arrange financing, design, and build the project, the work could be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent inflation, is \$1,284,500 (Table C-8A).

Figure C-8B




Table C-8A. Project Cost for Del Loma Tunnel Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 528,500  |
| Transmission Facilities                       | 17,000      |
| Subtotal                                      | \$ 545,500  |
| Contingencies (20%)                           | 109,100     |
| Total   | \$ 654,600  |
| Engineering and Administration (15%)          | 98,200      |
| Total Construction Cost (January 1980 Prices) | \$ 752,800  |
| Escalation (4 yrs. at 12% per year)           | 431,700     |
| Total Construction Cost (January 1983 Prices) | \$1,184,500 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$1,284,500 |
| Cost per kW (250 kW)                          | \$ 5,138    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-8B). Since water for generation is available throughout the year, regular maintenance could be scheduled at the convenience of purchaser.

Table C-8B. Annual Operating Cost for Del Loma Tunnel Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 47,600 |
| Insurance                 | 8,500     |
| Interim Replacements      | 1,600     |
| Total                     | \$ 57,700 |

The annual cost of owning and operating the project would range between 15 and 22 percent of the direct project cost of \$1,284,500, depending on financing. The estimated cost of generation ranges between 10.2 cents and 15.1 cents per kWh (Table C-8C).




Table C-8C. Average Cost of Energy for Del Loma Tunnel Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$160,600     | \$205,500 | \$228,600 |
| Operating Cost            | 57,700        | 57,700    | 57,700    |
| Total Annual Cost         | \$218,300     | \$263,200 | \$286,300 |
| Average Cost (per kWh)    | 11.5¢         | 13.9¢     | 15.1¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$136,200     | \$185,000 | \$208,100 |
| Operating Cost            | 57,700        | 57,700    | 57,700    |
| Total Annual Cost         | \$193,900     | \$242,700 | \$265,800 |
| Average Cost (per kWh)    | 10.2¢         | 12.8¢     | 14.0¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. Since water would flow through the tunnel during all months of the year (even during dry years), the Del Loma site would have a capacity value in addition to its energy value. The capacity value is estimated at about \$15,900 annually, representing an average of 0.8 cent per kWh in 1980. The total value of project generation (including both capacity and energy) in 1984, is 11.1 cents per kWh using the CEC median oil-price projection as the basis for estimating the future cost of electrical energy.

Conclusions. The estimated value of Del Loma generation is within the range of the estimated generation cost (10.2 to 15.1 cents per kWh). The project would probably be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of Del Loma generation would change little from year to year since only the maintenance cost of the facility is subject to inflation.

Figure C-9A Frenchman Dam Powerplant



## 9. Frenchman Dam

Frenchman Dam, owned and operated by the DWR, is located on Little Last Chance Creek near Chilcoot in Plumas County (Fig. C-9A). The dam and reservoir are used for flood control, water conservation, and recreation. Water is released in accordance with contracts for water deliveries in the Sierra Valley.

Site Characteristics. The dam is an earth structure approximately 38 m (125 ft) long. Controlled releases from the reservoir are made through the dam's lower outlet which is about 155 m (510 ft) long. For the first 60 m (197 ft) from the reservoir intake structure to a valve chamber, the outlet consists of a 914 mm (36 in) diameter concrete conduit. From the valve chamber for about 95 m (312 ft) to the outlet control house, the outlet consists of a 0.8 m (2.5 ft) diameter steel pipe enclosed by a horseshoe-shaped concrete conduit having an inside diameter of 2 m (6.5 ft). The main valve, located in the outlet control house, is a 0.6 m (2 ft) hollow cone-type valve. About 2.7 m (9 ft) upstream from the outlet control house, the steel pipe is tapped with a 0.5 m (1.5 ft) steel pipe stubbed and capped for future use for hydroelectric generation.

Potential Generation. A horizontal Francis turbine is considered for installation at the dam using a new tap into the existing 0.8 m (2.5 ft) steel pipe. The potential installed capacity would be 450 kW, and the estimated annual generation is about 1 million kWh (Table C-9A).

Table C-9A. Energy Generation for Frenchman Dam Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 30.2 | 99   | 0.1   | 2     | --             | --            | --              |
| February  | 30.5 | 100  | 0.1   | 3     | --             | --            | --              |
| March     | 31.1 | 102  | 0.3   | 10    | --             | --            | --              |
| April     | 31.7 | 104  | 0.5   | 19    | --             | --            | --              |
| May       | 31.7 | 104  | 1.1   | 39    | 73             | 250           | 186 000         |
| June      | 31.1 | 102  | 1.8   | 63    | 79             | 429           | 309 000         |
| July      | 30.2 | 99   | 1.3   | 47    | 82             | 323           | 240 000         |
| August    | 29.0 | 95   | 1.8   | 63    | 79             | 400           | 298 000         |
| September | 28.7 | 94   | 0.5   | 19    | --             | --            | --              |
| October   | 28.4 | 93   | 0.3   | 10    | --             | --            | --              |
| November  | 28.4 | 93   | 0.1   | 2     | --             | --            | --              |
| December  | 28.7 | 94   | 0.1   | 2     | --             | --            | --              |
| Total     |      |      |       |       |                |               | 1 033 000       |

New Power Plant Structures. A hydraulic turbine and electric generator installed at the downstream end of the existing lower outlet pipe could use the 29 m to 31.7 m (95 ft to 104 ft) head available at Frenchman Dam. The proposed generating facility would include a 0.8 m (2.5 ft) steel pipe by-pass from about 5 m (16.5 ft) upstream of the existing outlet control house to carry water to a horizontal Francis turbine (Figs C-9B and C-9C). The turbine could develop 605 hp under the available head and would be



connected directly to a horizontal, air-cooled synchronous generator with a rated output of 450 kW.

The operations of the hydroelectric plant and of the existing installation would be kept separate by a butterfly valve installed upstream from the turbine. Although a 0.5 m (1.5 ft) steel pipe was installed when Frenchman Dam was built, it would not be used for the proposed installation because its small diameter would prevent the full use of the available flows, and because its physical location is such that construction of a powerhouse using it would require considerable rock and earth excavation.

Transmission Facilities. The nearest transmission line is owned and operated by the Sierra-Plumas Rural Electric Cooperative. It would be necessary to construct about 8 km (5 mi) of 13 kV transmission line to connect the proposed project with the existing transmission grid.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$982,400, based on January 1980 prices. If the project were initiated in 1981, and about 24 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$1,645,800 (Table C-9B).

Table C-9B. Project Cost for Frenchman Dam Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 555,900  |
| Transmission Facilities                       | 175,000     |
| Subtotal                                      | \$ 730,900  |
| Contingencies (20%)                           | 146,200     |
| Total   | \$ 877,100  |
| Engineering and Administration (12%)          | 105,300     |
| Total Construction Cost (January 1980 Prices) | \$ 982,400  |
| Escalation (4 yrs. at 12% per year)           | 563,400     |
| Total Construction Cost (January 1984 Prices) | \$1,545,800 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$1,645,800 |
| Cost per kW (450 kW)                          | \$ 3,657    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-9C). Regular maintenance could be scheduled during winter months when there is insufficient water for power generation.



Table C-9C. Annual Operating Cost for Frenchman Dam Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 16,000    |
| Interim Replacements      | 2,700     |
| Total                     | \$ 31,700 |

The annual costs of owning and operating the project would range between 13 and 20 percent of the direct project cost of \$1,645,800, depending on financing. The estimated cost of generation ranges between 20.0 cents and 31.4 cents per kWh (Table C-9D).

Table C-9D. Average Cost of Energy for Frenchman Dam Project


| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$205,700     | \$263,300 | \$293,000 |
| Operating Cost            | 31,700        | 31,700    | 31,700    |
| Total Annual Cost         | \$237,400     | \$295,000 | \$324,700 |
| Average Cost (per kWh)    | 23.0¢         | 28.6¢     | 31.4¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$174,500     | \$237,000 | \$266,600 |
| Operating Cost            | 31,700        | 31,700    | 31,700    |
| Total Annual Cost         | \$206,200     | \$268,700 | \$298,300 |
| Average Cost per (kWh)    | 20.0¢         | 26.0¢     | 28.9¢     |

Value of Generation. Project generation from Frenchman Dam could be wheeled through Plumas-Sierra Rural Electric Coop., Inc., California-Pacific Utilities Company, and PGandE for use on the State Water Project. It is assumed that the value of this energy to DWR is comparable to the rates that utilities will be required to pay under Section 210 of PURPA. The estimated value of this generation is 11.1 cents per kWh in 1984 and 22.9 cents per kWh in 1990, based on the median CEC oil cost projection for future costs of electrical energy.

Conclusions. By 1989, the value of Frenchman Dam generation is within the range of the generation cost (20.0 to 31.4 cents per kWh).

For approximately the first 5 years of operation, project costs would exceed the value of the energy. However, during subsequent years as the price of oil increases the value of this resource will more than offset the high initial cost of the project.

Figure C-10A Glendale Distribution System Powerplant



## 10. Glendale Distribution System

The Glendale Distribution System facility is a water distribution system owned and operated by the City of Glendale in Los Angeles County (Fig. C-10A). Water is delivered to the site by a pipeline pressurized at the source by the Metropolitan Water District of Southern California. A valve is used to reduce the water pressure for the Glendale water distribution system. The system covers an area of 78 sq km (30 sq mi) and serves over 128 000 people.

Site Characteristics. The hydraulic facility consists of a 1.5 m (59 in) diameter water main operated at a pressure equal to an elevation of 282 m (925 ft), connected through a pressure-reducing valve to a 762 mm (30 in) diameter pipeline operated at a pressure equal to an elevation 221 m (724 ft). A 4 kV transmission line is located adjacent to the site.

Potential Generation. The potential capacity of the Glendale Distribution System facility would be about 400 kW, and the estimated average annual output is about 2 million kWh (Table C-10A).

Table C-10A. Energy Generation for Glendale Distribution Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 57.3 | 188  | 0.3   | 11    | 85             | 149           | 111 000         |
| February  | 58.2 | 191  | 0.3   | 12    | 85             | 165           | 111 000         |
| March     | 56.4 | 185  | 0.3   | 12    | 85             | 160           | 119 000         |
| April     | 59.1 | 194  | 0.8   | 28    | 85             | 391           | 282 000         |
| May       | 60.0 | 197  | 0.8   | 27    | 85             | 383           | 285 000         |
| June      | 56.4 | 185  | 0.7   | 25    | 85             | 333           | 240 000         |
| July      | 60.3 | 198  | 0.4   | 13    | 85             | 185           | 138 000         |
| August    | 58.2 | 191  | 0.3   | 12    | 85             | 165           | 123 000         |
| September | 57.9 | 190  | 0.4   | 13    | 85             | 178           | 128 000         |
| October   | 61.0 | 200  | 0.4   | 14    | 85             | 202           | 150 000         |
| November  | 55.2 | 181  | 0.4   | 15    | 85             | 195           | 140 000         |
| December  | 59.1 | 194  | 0.4   | 15    | 85             | 210           | 156 000         |
| Total     |      |      |       |       |                |               | 1 983 000       |

New Power Plant Facilities. Hydraulic turbines and electric generators installed at the site could use the available head of about 61 m (200 ft). The proposed generating facility includes a new pipeline, 406 mm (16 in) in diameter and about 17 m (55.7 ft) long; a powerhouse; and a discharge pipeline, 406 mm (16 in) in diameter and about 27 m (89 ft) long (Fig. C-10B). The upstream pipe would take water through a T-connection from the existing 0.8 m (2.5 ft) pipe operated at an elevation pressure of 282 m (925 ft). The downstream pipe would discharge the water through a new T-connection into the existing Glendale pipeline which operates at elevation pressure of 221 m (724 ft).

The powerhouse would contain two horizontal, modified pump-type turbines, each capable of developing 268 hp under the available head. The


STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES

CITY OF GLENDALE

**GLENDALE DISTRIBUTION SYSTEM  
400KW POWER PLANT**

POWERHOUSE — PLAN AND SECTION

NOTE:  
ENGLISH UNITS IN BRACKETS



turbines would be connected directly to horizontal generators with a rated output of 200 kW each. The operations of the power plant and the existing water supply system would be separated by butterfly valves installed both upstream and downstream from each turbine.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$573,900, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were needed to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$1,023,000 (Table C-10B).

Table C-10B. Project Cost for Glendale Distribution Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 412,000  |
| Transmission Facilities                       | 15,000      |
| Subtotal                                      | \$ 427,000  |
| Contingencies (20%)                           | 85,400      |
| Total   | \$ 512,400  |
| Engineering and Administration (12%)          | 61,500      |
| Total Construction Cost (January 1980 prices) | \$ 573,900  |
| Escalation (4 yrs. at 12% per year)           | 399,100     |
| Total Construction Cost (January 1984 prices) | \$ 973,000  |
| Studies, Licensing, Permits, and Approvals    | 50,000      |
| Total   | \$1,023,000 |
| Cost per kW (400 kW)                          | \$ 2,558    |

Cost of Generation. Since the Glendale Distribution System site, and an electric transmission and distribution system are owned and operated by the City of Glendale, it is assumed that the city would develop and use the power in its own electric system. The annual cost of owning and operating the project include debt repayment, operation and maintenance, insurance, replacements, administration, and overhead.

It is assumed that the city would finance the construction of the hydroelectric facility by issuing tax-exempt revenue bonds at a 9 percent interest rate. The actual interest rate would depend on financial conditions at the time of issue. It is anticipated that initial development would be financed from electric system revenues or short-term loans, and that the bonds would not be issued until about 12 months before the project is completed. The additional cost to operate the plant would be insignificant, since the city has a full staff of operating personnel.

Assuming that the project will be scheduled to be on-line late in 1983, the bond issue would amount to about \$1,220,000, based on January 1980 bid prices, with 12 percent annual inflation, and a one-year construction period (Table C-10C).

Table C-10C. Annual Cost for Glendale Distribution Project

| Cost Item                       | Amount             |                    |
|---------------------------------|--------------------|--------------------|
|                                 | 20-Year<br>Bonds   | 35-Year<br>Bonds   |
| Project Cost                    | \$1,023,000        | \$1,023,000        |
| Capitalized Interest            | 85,800             | 85,800             |
| Interest Earnings               | (42,900)           | (42,900)           |
| <b>Total Capital Cost</b>       | <b>\$1,065,900</b> | <b>\$1,065,900</b> |
| Bond Reserve Fund               | 128,700            | 108,800            |
| Financing Costs                 | 50,400             | 45,300             |
| Bond Issue                      | \$1,245,000        | \$1,220,000        |
| Debt Service (9% interest)      | \$ 136,400         | \$ 115,500         |
| Operation and Maintenance       | 20,400             | 20,400             |
| Insurance                       | 8,500              | 8,500              |
| Interim Replacements            | 1,500              | 1,500              |
| Interest Earnings               | (9,800)            | (9,800)            |
| <b>Total Annual Cost</b>        | <b>\$ 157,000</b>  | <b>\$ 136,000</b>  |
| Annual Cost (% of Project Cost) | 15.3               | 13.3               |
| Average Cost (per kWh)          | 7.9¢               | 6.9¢               |

The annual cost of owning and operating the project, if it were constructed in 1983 and first operated in 1984, is estimated to be between \$136,100 and \$157,000 (Table C-10C).

The estimated average generation cost (assuming 35-year bonds) is 6.5 cents per kWh. With 20-year bonds, the estimated average cost of generation increases to 7.9 cents per kWh. Since the city is experienced in owning and operating electric facilities, it might elect to be self-insured--in full or in part--to reduce the annual insurance premium on mechanical and electrical equipment. This would reduce its annual generation cost.


Value of Generation. It is assumed that the city would use the energy produced at the Glendale Distribution System site in its own electric system. The value of such hydroelectric generation to the city would be equal to the energy that it would otherwise have to purchase if the new hydroelectric facility were not built.

Computing this avoided cost to the city is beyond the scope of this study. However, the annual average avoided cost can be estimated based on the rates established by SCE for the purchase of energy from small power

facilities. The SCE rate for mid-peak energy, and thus the estimated value of avoided energy for the city, can be taken from the partial-peak projection shown in Appendix G. The estimated value of project generation in 1984 would be 10.1 cents per kWh, plus 0.8 cent per kW for capacity.

Conclusions. Since the estimated value of Glendale Distribution System generation (10.9 cents per kWh in 1984) exceeds the estimated cost of generation (6.9 cents per kWh for 35-year financing at 9 percent), the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of generation would change little from year to year, since only the cost of maintaining the facility is subject to inflation.

Figure C-11A Gould Weir Powerplant



## 11. Gould Weir

Gould Weir is a diversion structure owned and operated by the Fresno Irrigation District on the Kings River. It is located east of Fresno and downstream from the Pine Flat Reservoir in Fresno County (Fig. C-11A). The weir diverts water into the Enterprise Canal for distribution by the District. The site is characterized by a low head of about 1.8 m (6 ft) and high flows of 57 cms to 85 cms (2000 cfs to 3000 cfs) during the summer months.

Site Characteristics. The diversion structure consists of five bays, each containing stop logs held in place by a reinforced-concrete framework. The structure was repaired in 1969 after the bank opposite the canal headworks had eroded during a period of high flows. The bank was repaired by constructing a dike riprapped with quarry rock. Because of the repair work, the structure, which originally contained seven bays, was left with five bays, each about 4.7 m (15.4 ft) wide. The structure is about 4.6 m (15 ft) high.


Potential Generation. Two horizontal, standard tube-type turbines are considered for installation at Gould Weir because of the low 1.8 m (6 ft) head and high flows. The generators would be 425 kW each, and the estimated annual generation is about 3.5 million kWh (Table C-11A).

Table C-11A. Energy Generation for Gould Weir Diversion Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 1.8  | 6    | 6.6   | 233   | --             | --            | --              |
| February  | 1.8  | 6    | 12.7  | 447   | 66             | 150           | 101 000         |
| March     | 1.8  | 6    | 31.9  | 1128  | 84             | 425           | 316 000         |
| April     | 1.8  | 6    | 37.0  | 1308  | 84             | 425           | 306 000         |
| May       | 1.8  | 6    | 61.8  | 2184  | 84             | 850           | 632 000         |
| June      | 1.8  | 6    | 104.8 | 3700  | 84             | 850           | 612 000         |
| July      | 1.8  | 6    | 90.6  | 3201  | 84             | 850           | 632 000         |
| August    | 1.8  | 6    | 55.4  | 1958  | 84             | 850           | 632 000         |
| September | 1.8  | 6    | 24.0  | 847   | 84             | 363           | 261 000         |
| October   | 1.8  | 6    | 4.4   | 155   | --             | --            | --              |
| November  | 1.8  | 6    | 1.8   | 65    | --             | --            | --              |
| December  | 1.8  | 6    | 3.7   | 131   | --             | --            | --              |
| Total     |      |      |       |       |                |               | 3 492 000       |

New Power Plant Structures. The proposed generating facility would include an approach channel, 14 m (46 ft) wide and 12 m (39.4 ft) long, on the weir's left abutment to the powerhouse (Fig. C-11B). The water would be returned to the river through a short tailrace channel. The turbines, with runners 3 m (9.8 ft) in diameter (the largest size available for standard tube type units), could develop 570 hp each under a 1.8 m (6 ft) head and a 28 cms (980 cfs) flow. Each turbine would be connected, through a speed increaser, to a horizontal air-cooled synchronous generator having a rated output of 425 kW. Inlet gates would be installed in front of the turbines

Figure C-11B



STATE OF CALIFORNIA  
THE RESOURCE AGENCY  
DEPARTMENT OF WATER RESOURCES  
KINGS RIVER WATER AGENCY  
GOULD WEIR  
950 kW POWER PLANT  
POWERHOUSE - PLAN AND SECTIONS

and draft-tube gates would be installed downstream from the turbines so the units could be dewatered for maintenance.

The possibility of installing three turbine-generator units rated at 336 kW each, using 2.8 m (9 ft) runners, was also considered. The three-unit arrangement was less economical because the installation cost would be increased by 40 percent while the saleable capacity would not change due to reduced streamflows in August. In addition, the three-unit arrangement would require that one of the five weir discharge bays be used for the powerhouse.

Minimal new transmission facilities are required, since a 13 kV transmission line is located about 152 m (500 ft) from the site.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$3,987,400, based on January 1980 prices. From 24 to 36 months will be required for completing the feasibility study, obtaining approvals, and building. If the project were initiated in 1981, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983 (with 12 percent annual inflation) is \$6,374,200 (Table C-11B).

Table C-11B. Project Cost for Gould Weir Diversion Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$2,951,800 |
| Transmission Facilities                       | 15,000      |
| Subtotal                                      | \$2,966,800 |
| Contingencies (20%)                           | 593,400     |
| Total   | \$3,560,200 |
| Engineering and Administration (12%)          | 427,200     |
| Total Construction Cost (January 1980 Prices) | \$3,987,400 |
| Escalation (4 yrs. at 12% per year)           | 2,286,800   |
| Total Construction Cost (January 1984 Prices) | \$6,274,200 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$6,374,200 |
| Cost per kW (850 kW)                          | \$ 7,499    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-11C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-11C. Annual Operating Cost for Gould Weir Diversion Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 50,500 |
| Insurance                 | 85,000    |
| Interim Replacements      | 15,000    |
| Total                     | \$150,500 |

The annual costs of owning and operating the project would range between 13 and 20 percent of the direct project cost of \$6,374,200, depending on financing. The estimated cost of generation ranges between 23.7 cents and 36.8 cents per kWh (Table C-11D).


Table C-11D. Average Cost of Energy for Gould Weir Diversion Project

| Cost Item                 | Amount        |             |             |
|---------------------------|---------------|-------------|-------------|
|                           | Interest Rate |             |             |
|                           | 9%            | 12%         | 15%         |
| For 20-year term of debt: |               |             |             |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%       | 17.8%       |
| Fixed Annual Cost         | \$796,800     | \$1,019,900 | \$1,134,600 |
| Operating Cost            | 150,500       | 150,500     | 150,500     |
| Total Annual Cost         | \$947,300     | \$1,170,400 | \$1,285,100 |
| Average Cost (per kWh)    | 27.1¢         | 33.5¢       | 36.8¢       |
| For 35-year term of debt: |               |             |             |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%       | 16.2%       |
| Fixed Annual Cost         | \$675,700     | \$ 917,900  | \$1,032,600 |
| Operating Cost            | 150,500       | 150,500     | 150,500     |
| Total Annual Cost         | \$826,200     | \$1,068,400 | \$1,183,100 |
| Average Cost (per kWh)    | 23.7¢         | 30.6¢       | 33.9¢       |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of energy produced in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the value of Gould Weir hydroelectric generation is less than the cost of generation (23.7 to 36.8 cents per kWh), the project if constructed by 1984 would probably not be cost effective until 1991. This is based on the projected energy rates shown in Table 8, Chapter II.

Figure C-12A Harding Canal Powerplant



## 12. Harding Canal

Harding Canal, a water conveyance facility owned and operated by the Browns Valley Irrigation District, is located near the community of Browns Valley in Yuba County (Fig. C-12A). It is a lateral canal that extends south from a point near the outlet of the Virginia Ranch Dam diversion tunnel on Dry Creek to Tennessee Creek in Browns Valley. The diverted waters flow down Tennessee Creek to the District's main irrigation canal. All water flowing in the Harding Canal that is not used for local purposes eventually flows into the Browns Valley system.





Site Characteristics. Harding Canal is an unlined, dug trench with a maximum capacity of about 1.7 cms (60 cfs). By extending the canal about 0.8 km (0.5 mi) along the 335 m (1100 ft) elevation contour, a penstock and powerhouse could be constructed to develop about a 91 m (300 ft) head for hydroelectric generation. Water flowing through the new powerhouse could be carried by natural channels to the District's Main Canal. The canal extension and powerhouse would be located on an undeveloped grass-oak woodland site with access available only by foot travel. Since transmission facilities are not available at the site, a 13 kV transmission line, about 1.6 km (1 mi) long, would have to be built across undeveloped lands in order to use the power produced.

Potential Generation. The potential generation capacity would be 1000 kW based on the average usable canal capacity of 1.4 cms (50 cfs). Using both the irrigation releases between April and October and the part of the spillway discharge that is now passed down Dry Creek from Virginia Ranch Dam, power could be generated for about 9 months; the average annual output would be about 6 550 000 kWh.

New Power Plant Structures. A turbine-generator could be installed at the site to use the 91 m (300 ft) available head. The proposed generating facility would require extending the existing Harding Canal and installing a penstock 533 mm (21 in) in diameter and about 300 m (984 ft) long, a powerhouse, and a short tailrace channel (Fig. C-12B). A horizontal, Francis turbine at the powerhouse would develop 1340 hp under the available head and would be connected directly to a horizontal, air-cooled synchronous generator with a rated output of 1000 kW. A butterfly valve installed upstream from the turbine would separate the generation and irrigation activities.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$1,256,600, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983 (with 12 percent annual inflation) is \$2,077,300 (Table C-12A).

Figure C-12B



STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES

BROWNS VALLEY IRRIGATION DISTRICT

**HARDING CANAL**  
**1000kW POWER PLANT**  
**POWERHOUSE-PLAN AND SECTION**

**NOTE:**  
 ENGLISH UNITS IN BRACKETS

Table C-12A. Project Cost for Harding Canal Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 890,000  |
| Transmission Facilities                       | 45,000      |
| Subtotal                                      | \$ 935,000  |
| Contingencies (20%)                           | 187,000     |
| Total   | \$1,122,000 |
| Engineering and Administration (12%)          | 134,600     |
| Total Construction Cost (January 1980 Prices) | \$1,256,600 |
| Escalation (4 yrs. at 12% per year)           | 720,700     |
| Total Construction Cost (January 1984 Prices) | \$1,977,300 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$2,077,300 |
| Cost per kW (1 000 kW)                        | \$ 2,077    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-12B). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-12B. Annual Cost for Harding Canal Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 45,000 |
| Insurance                 | 25,500    |
| Interim Replacements      | 4,500     |
| Total                     | \$ 75,000 |

The annual costs of owning and operating the project would range between 14 and 21 percent of the direct project cost of \$2,077,300, depending on financing. The estimated cost of generation ranges between 4.5 cents and 6.8 cents per kWh (Table C-12C).




Table C-12C. Average Cost of Energy for Harding Diversion Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$259,700     | \$332,400 | \$369,800 |
| Operating Cost            | 75,000        | 75,000    | 75,000    |
| Total Annual Cost         | \$334,700     | \$407,400 | \$444,800 |
| Average Cost (per kWh)    | 5.1¢          | 6.2¢      | 6.8¢      |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$220,200     | \$299,100 | \$336,500 |
| Operating Cost            | 75,000        | 75,000    | 75,000    |
| Total Annual Cost         | \$295,200     | \$374,100 | \$411,500 |
| Average Cost (per kWh)    | 4.5¢          | 5.7¢      | 6.3¢      |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations study acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh, using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of Harding Canal generation exceeds the estimated cost of generation (4.5 to 6.8 cents per kWh), the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of generation would change little from year to year because only the cost of maintaining the facility is subject to inflation.

Figure C-13A Indian Valley Dam Powerplant



### 13. Indian Valley Dam

Indian Valley Dam is a rock and earthfill structure owned and operated by the Yolo County Flood Control and Water Conservation District. It is located on Cache Creek, near Clear Lake in Lake County (Fig. C-13A). The dam is used for flood control, water conservation, and recreation.

The District provides irrigation water to an area of Yolo County approximately defined as the rectangular area with corners near Woodland, Davis, Winters, and Capay. The projected irrigated acreage is about 51 400 hectares (127,000 acres), and the estimated annual agricultural water demand is about 481 000 cubic dekametres (390,000 ac-ft). The estimated annual urban water requirement is 61 675 cubic dekametres (50,000 ac-ft).

The dam was completed in 1976, but the reservoir has never filled. A feasibility report, prepared in support of a Public Law 984 Loan, lists the expected firm yield of the reservoir at 59 200 cubic dekametres (48,000 ac-ft). Flood control storage space is 49 300 cubic dekametres (40,000 ac-ft) with the full amount required between December 1 and March 15. Storage in the gross pool at an elevation of 452.6 m (1,485 ft) is 370 790 cubic dekametres (300,600 ac-ft). The bottom of the flood control pool is 197 360 cubic dekametres (160,000 ac-ft) at an elevation of 449.6 m (1,475 ft).

It is expected that once the reservoir fills, it will operate between elevations of 448.7 m (1,472 ft) and 452.6 m (1,485 ft) for flood control and reservoir yield. Under these conditions, the average net head available for power generation would be about 53.3 m (175 ft).

Site Characteristics. Indian Valley Dam has a maximum height of 63 m (207 ft) above the stream bed and a crest 294 m (965 ft) long. Controlled releases from the reservoir are made through the dam's lower outlet located at about in middle of the dam. The outlet works consist of a vertical tower and trash rack; 168 m (550 ft) of 1524 mm (60 in) pipe extending to the butterfly valve in the valve chamber; 174 m (570 ft) of 1.5 m (5 ft) saddle-supported steel pipe inside a 2.9 m (9.5 ft) diameter concrete arch tunnel; and a 1.5 m (5 ft) hollow jet valve. A separate 356 mm (14 in) piping and valving arrangement would meet fish-release requirements with flows up to 0.57 cms (20 cfs); the pipe would start just ahead of the butterfly valve and end with a 305 mm (12 in) hollow jet valve located near the hollow existing jet valve in the outlet terminal building. Both valves would discharge water directly into the spillway stilling basin.

Potential Generation. A vertical Francis turbine with an electric generator rated at 3200 kW is considered for installation at the facility. The potential annual output is estimated at 7.2 million kWh (Table C-13A).

Figure C-13B




Table C-13A. Energy Generation for Indian Valley Dam Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 56.4 | 185  | 0.3   | 10    | --             | --            | --              |
| February  | 56.4 | 185  | 0.3   | 10    | --             | --            | --              |
| March     | 56.4 | 185  | 0.3   | 10    | --             | --            | --              |
| April     | 56.4 | 185  | 1.0   | 34    | --             | --            | --              |
| May       | 56.4 | 185  | 5.1   | 179   | 75             | 2213          | 1 647 000       |
| June      | 56.4 | 185  | 5.7   | 202   | 80             | 2530          | 1 821 000       |
| July      | 56.4 | 185  | 6.9   | 244   | 84             | 3200          | 2 381 000       |
| August    | 56.4 | 185  | 4.6   | 163   | 72             | 1837          | 1 367 000       |
| September | 56.4 | 185  | 1.4   | 50    | --             | --            | --              |
| October   | 56.4 | 185  | 0.3   | 10    | --             | --            | --              |
| November  | 56.4 | 185  | 0.3   | 10    | --             | --            | --              |
| December  | 56.4 | 185  | 0.3   | 10    | --             | --            | --              |
| Total     |      |      |       |       |                |               | 7 216 000       |

**New Power Plant Structures.** A turbine-generator installed at the downstream end of the existing lower outlet could use the 52.4 m to 56.4 m (172 ft to 185 ft) available head at Indian Valley Dam. The proposed generating facility includes a 1.5 m (5 ft) steel pipe by-pass, starting about 8 m (26 ft) upstream from the existing outlet control structure, which would carry water to a vertical Francis turbine (Figs. C-13B and C-13C). The turbine could develop 4295 hp under a 46.7 m (185 ft) head and would be connected directly to a vertical, 600 rpm air-cooled synchronous generator with a rated output of 3200 kW. Since the new powerhouse would be adjacent to the existing outlet control structure (Fig. C-13C), the turbine draft tube would discharge the water directly into the existing stilling basin. The operation of the hydroelectric plant and of the existing installation would be kept separate by a 1.3 m (4.3 ft) butterfly valve installed upstream from the turbine. The existing access road is adequate.

**Transmission Facilities.** Electric transmission facilities are not available at the Indian Valley site. The nearest transmission line which could carry project power is about 14.5 km (9 mi) away along the existing access road. An alternate routing would be about 16 km (10 mi) cross-country to the vicinity of Clear Lake Oaks. A 13 kV transmission line would be adequate to carry project generation.

**Cost of the New Power Plant.** The estimated cost of building the new generating facility is \$3,287,600, based on January 1980 prices. If the project were initiated in 1981, and about 24 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work would be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent inflation, is \$5,273,100 (Table C-13B).

Figure C-13C




Table C-13B. Project Cost of Indian Valley Dam Plant

| Cost Item                                     | Amount       |
|---|--------------|
| Direct Cost                                   |              |
| Hydroelectric Plant Facilities                | \$ 2,046,200 |
| Transmission Facilities                       | 400,000      |
| Subtotal                                      | \$ 2,446,200 |
| Contingencies (20%)                           | 489,200      |
| Total   | \$ 2,935,400 |
| Engineering and Administration (12%)          | 352,200      |
| Total Construction Cost (January 1980 Prices) | \$ 3,287,600 |
| Escalation (4 yrs. at 12% per year)           | 1,885,500    |
| Total Construction Cost (January 1984 Prices) | \$ 5,173,100 |
| Studies, Licensing, Permits, and Approvals    | 100,000      |
| Total   | \$ 5,273,100 |
| Cost per kW (3 200 kW)                        | \$ 1,648     |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-13C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-13C. Annual Operating Cost of Indian Valley Dam Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$126,000 |
| Insurance                 | 59,500    |
| Interim Replacements      | 10,700    |
| Total                     | \$196,200 |

The annual cost of owning and operating the project would range between 14 and 22 percent of the direct project cost of \$5,273,100, depending on financing. The estimated cost of generation ranges between 10.5 and 15.7 cents per kWh (Table C-13D).




Table C-13D. Average Cost of Energy for Indian Valley Dam Project

| Cost Item                 | Amount        |             |             |
|---------------------------|---------------|-------------|-------------|
|                           | Interest Rate |             |             |
|                           | 9%            | 12%         | 15%         |
| For 20-year term of debt: |               |             |             |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%       | 17.8%       |
| Fixed Annual Cost         | \$659,100     | \$ 843,700  | \$ 938,600  |
| Operating Cost            | 196,200       | 196,200     | 196,200     |
| Total Annual Cost         | \$855,300     | \$1,039,900 | \$1,134,800 |
| Average Cost (per kWh)    | 11.8¢         | 14.4¢       | 15.7¢       |
| For 35-year term of debt: |               |             |             |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%       | 16.2%       |
| Fixed Annual Cost         | \$559,000     | \$ 759,300  | \$ 854,200  |
| Operating Cost            | 196,200       | 196,200     | 196,200     |
| Total Annual Cost         | \$755,200     | \$ 955,500  | \$1,050,400 |
| Average Cost (per kWh)    | 10.5¢         | 13.2¢       | 14.6¢       |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydro-electric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. The estimated value of Indian Valley generation is within the estimated generation cost (10.5 to 15.7 cents per kWh). Assuming that a theoretical water and power operations study showed no capacity value, the project cost would equal or exceed revenues from the sale of project generation for the first year of operation. Thus, the project would probably be cost effective.

Figure C-14A Sly Park Dam Powerplant



#### 14. Jenkinson Lake (Sly Park Dam)

Sly Park Dam is owned by WPRS and is operated by the El Dorado Irrigation District. It is located on Sly Park Creek near Pollock Pines in El Dorado County (Fig. C-14A). Sly Park Creek joins Camp Creek downstream from the dam and flows into the Consumnes River. The dam creates Jenkinson Lake which has a total storage capacity of 50 600 cubic dekametres (41,000 ac-ft). Controlled releases are made from the reservoir, and the water is diverted by pipeline throughout El Dorado County for irrigation and domestic use.

Site Characteristics. Sly Park Dam is an earthfill structure 58 m (190 ft) high with a crest about 247 m (810 ft) long. The outlet works consist of a concrete conduit, 1219 mm (48 in) in diameter, extending from the reservoir intake for a distance of about 104 m (340 ft) to a gate chamber located at about the mid-point of the dam; a 0.9 m (3 ft) steel pipe within a 2.0 m (6.5 ft) diameter horseshoe-shaped concrete conduit extends from the gate chamber for a distance of about 128 m (420 ft) to the outlet control structure at the foot of the dam. Just upstream from the outlet control structure the steel pipe changes, by a Y-transition, to two 813 mm (32 in) steel pipes, each controlled by a 686 sq mm (27 sq in) high-pressure slide gate. Downstream from the slide gates, the energy in the water is dissipated in a concrete box about 6 m (20 ft) long. From this energy dissipater, the water enters a 1.2 m (4 ft) concrete pipe operating under pressure created by the water level in the energy dissipater. A by-pass valve and a 203 mm (8 in) pipe located upstream from the dissipater provide a minimum release of 0.03 cms (1 cfs) to enhance streamflow.

Potential Generation. A vertical Francis turbine is considered for installation at Sly Park Dam, because the 39 m to 51 m (128 ft to 167 ft) net operating head exceeds the range of a tube-type turbine. Although a Kaplan turbine could be installed, the limited water available for generation during the nonirrigation season does not justify the Kaplan unit's 50 to 70 percent higher cost.

The potential installed capacity would be 650 kW, and the estimated annual generation is about 1.8 million kWh (Table C-14A).



Table C-14A. Energy Generation for Jenkinson Lake Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 40.2 | 132  | 0.26  | 9     | --             | --            | --              |
| February  | 45.7 | 150  | 0.26  | 9     | --             | --            | --              |
| March     | 50.9 | 167  | 0.28  | 10    | --             | --            | --              |
| April     | 50.9 | 167  | 0.31  | 11    | --             | --            | --              |
| May       | 50.9 | 167  | 0.88  | 31    | 55             | 240           | 179 000         |
| June      | 46.9 | 154  | 1.53  | 54    | 79             | 554           | 400 000         |
| July      | 44.5 | 146  | 1.90  | 67    | 84             | 693           | 517 000         |
| August    | 42.0 | 138  | 1.87  | 66    | 84             | 646           | 482 000         |
| September | 40.2 | 132  | 1.30  | 46    | 73             | 374           | 270 000         |
| October   | 39.0 | 128  | 0.68  | 24    | --             | --            | --              |
| November  | 39.0 | 128  | 0.31  | 11    | --             | --            | --              |
| December  | 37.2 | 122  | 0.23  | 8     | --             | --            | --              |
| Total     |      |      |       |       |                |               | 1 848 000       |

**New Power Plant Structures.** A turbine and generator could be installed at the downstream end of the existing lower outlet pipe to use the 39 m to 51 m (128 ft to 167 ft) available head. The proposed generating facility includes a 0.9 m (3 ft) steel pipe by-pass starting about 4 m (13 ft) upstream from the existing outlet control structure, a vertical Francis turbine adjacent to the existing outlet gate building, and a tailrace conduit, about 7 m (23 ft) long, discharging into the existing energy dissipater box (Figs. C-14B and C-14C). The turbine could develop 870 hp under a 45 m (147 ft) head and would be connected directly to a vertical, air-cooled synchronous generator with a rated output of 650 kW.


The operation of the hydroelectric plant and that of existing installation would be kept separate by a butterfly valve installed upstream from the turbine. The turbine could be dewatered for maintenance by closing the butterfly valve and placing a cover at the entrance of the tailrace conduit into the energy dissipater.

**Transmission Facilities.** A 13 kV transmission line is located at the site. The only electric facilities needed are a transformer, protective equipment, and a short connecting line.

**Cost of the New Power Plant.** The estimated cost of building the new generating facility is \$880,300, based on January 1980 prices. Since the generating facility would be located on a manmade conduit operated primarily for purposes other than power generation, it is expected that the site would be exempt from federal licensing requirements. (The exemption provision is discussed in detail in Appendix F.) However, the District would have to comply with the CEQA requirements and determine if the other state approvals are necessary.

If the project were initiated in 1981 and about 30 months were required to complete the feasibility study, obtain approvals, arrange

Figure C-14C



financing, design, and build the project, the work would be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent inflation, is \$1,435,200 (Table C-14B).

Table C-14B. Project Cost for Jenkinson Lake Project

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 643,300  |
| Transmission Facilities                       | 11,700      |
| Subtotal                                      | \$ 655,000  |
| Contingencies (20%)                           | 131,000     |
| Total   | \$ 786,000  |
| Engineering and Administration (12%)          | 94,300      |
| Total Construction Cost (January 1980 Prices) | \$ 880,300  |
| Escalation (4 yrs. at 12% per year)           | 504,900     |
| Total Construction Cost (January 1984 Prices) | \$1,385,200 |
| Studies, Licensing, Permits, and Approvals    | 50,000      |
| Total   | \$1,435,200 |
| Cost per kW (650 kW)                          | \$ 2,208    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-14C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-14C. Annual Operating Cost for Jenkinson Lake Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 20,400 |
| Insurance                 | 25,500    |
| Interim Replacements      | 3,800     |
| Total                     | \$ 49,700 |

The annual cost of owning and operating the project would range between 14 and 21 percent of the direct project cost of \$1,435,200, depending on financing. The estimated cost of generation ranges between 10.9 cents and 16.5 cents per kWh (Table C-14D).




Table C-14D. Average Cost of Energy for Jenkinson Lake Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$179,400     | \$229,600 | \$255,500 |
| Operating Cost            | 49,700        | 49,700    | 49,700    |
| Total Annual Cost         | \$229,100     | \$279,300 | \$305,200 |
| Average Cost (per kWh)    | 12.4¢         | 15.1¢     | 16.5¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$152,100     | \$172,200 | \$232,500 |
| Operating Cost            | 49,700        | 49,700    | 49,700    |
| Total Annual Cost         | \$201,800     | \$221,900 | \$282,200 |
| Average Cost (per kWh)    | 10.9¢         | 12.0¢     | 15.3¢     |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is further assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. The value of Jenkinson Lake generation estimated at is within the estimated cost of generation (10.9 to 16.5 cents per kWh). Assuming that a theoretical water and power operations study showed no capacity value, the project cost would about equal revenues from sales of project generation. Thus, the project would probably be cost effective during its first year of operation.

Figure C-15A Jackson Creek Dam Powerplant



### 15. Lake Amador (Jackson Creek Dam)

Lake Amador and Jackson Creek Dam, owned and operated by the Jackson Valley Irrigation District, are about 1.6 km (1 mi) east of Ione in Amador County (Fig. C-15A). Water is stored in the reservoir for irrigation and municipal use in the District's service area. Lake Amador also provides recreational opportunities. In an average-water year, the reservoir yield could maintain a discharge rate of 0.8 cms (30 cfs) between January and October. The effective head would vary from 51.2 m (168 ft) during the winter months to about 45.7 m (150 ft) in October.

Site Characteristics. Jackson Creek Dam is an earthfill structure approximately 55 m (180 ft) high. Controlled releases from the reservoir are made through the dam's lower outlet approximately 270 m (886 ft) long. The first 108 m (354 ft) of the lower outlet, from the reservoir intake to a gate chamber, consist of a 0.9 m (3 ft) steel pipe embedded in concrete. Downstream from the gate chamber for about 160 m (520 ft) to the valve house, the lower outlet consists of a 0.8 m (2.5 ft) steel pipe within a horseshoe concrete conduit having a 1.8 m (6 ft) inside diameter. The main valve is a 0.6 m (2 ft) hollow-cone type valve. About 7.6 m (25 ft) upstream from the outlet structure, the 0.8 m (2.5 ft) steel pipe is provided with a stub of the same diameter, which diverts water into a pipeline.

Potential Generation. A horizontal Francis turbine with a generator rated at 350 kW is considered for installation at Lake Amador. The estimated annual generation is about 2.5 million kWh (Table C-15A).

Table C-15A. Energy Generation for Lake Amador Project

| Month        | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr)  |
|--------------|------|------|-------|-------|----------------|---------------|------------------|
|              | (m)  | (ft) | (cms) | (cfs) |                |               |                  |
| January      | 51.2 | 168  | 0.8   | 30    | 85             | 361           | 269 000          |
| February     | 51.2 | 168  | 0.8   | 30    | 85             | 361           | 243 000          |
| March        | 51.2 | 168  | 0.8   | 30    | 85             | 361           | 269 000          |
| April        | 50.6 | 166  | 0.8   | 30    | 85             | 361           | 260 000          |
| May          | 50.6 | 166  | 0.8   | 30    | 85             | 357           | 266 000          |
| June         | 50.0 | 164  | 0.8   | 30    | 85             | 353           | 254 000          |
| July         | 49.7 | 163  | 0.8   | 30    | 85             | 351           | 261 000          |
| August       | 48.2 | 158  | 0.8   | 30    | 85             | 340           | 253 000          |
| September    | 46.0 | 151  | 0.8   | 30    | 85             | 325           | 234 000          |
| October      | 45.7 | 150  | 0.8   | 30    | 85             | 323           | 233 000          |
| November     | 46.0 | 151  | --    | --    | --             | --            | --               |
| December     | 47.9 | 157  | --    | --    | --             | --            | --               |
| <b>Total</b> |      |      |       |       |                |               | <b>2 542 000</b> |

New Power Plant Structures. A turbine and generator installed at the downstream end of the lower outlet pipe could use the 46 m to 51 m (150 ft to 168 ft) available head. The proposed generating facility includes a 762 mm (30 in) steel pipe by-pass, starting about 4 m (13 ft) upstream from the existing outlet control structure, which carries the water to a horizontal



Francis turbine (Figs. C-15B and C-15C). The turbine could develop 470 hp under a 51 m (168 ft) head and would be connected directly to a horizontal, air-cooled synchronous generator with a rated output of 350 kW. The operation of the hydroelectric plant and of the existing installation would be kept separate with a butterfly valve.

The new powerhouse would be located adjacent to the existing outlet control structure, at approximately the same elevation. An access road to the site exists.

Transmission Facilities. A 13 kV transmission line owned by PGandE is located at the site. No additional transmission facilities are required.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$538,900, based on January 1980 prices. If the project were initiated in 1981 and about 30 months were needed to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work would be completed in late 1983 for operation in 1984. The estimated capital cost in late 1983, with 12 percent inflation, is \$898,000 (Table C-15B).

Table C-15B. Project Cost for Lake Amador Project

| Cost Item                                     | Amount     |
|---|------------|
| Direct Cost                                   |            |
| Hydroelectric Plant Facilities                | \$ 389,000 |
| Transmission Facilities                       | 12,000     |
| Subtotal                                      | \$ 401,000 |
| Contingencies (20%)                           | 80,200     |
| Total   | \$ 481,200 |
| Engineering and Administration (12%)          | 57,700     |
| Total Construction Cost (January 1980 Prices) | \$ 538,900 |
| Escalation (4 yrs. at 12% per year)           | 309,100    |
| Total Construction Cost (January 1984 Prices) | \$ 848,000 |
| Studies, Licensing, Permits, and Approvals    | 50,000     |
| Total   | \$ 898,000 |
| Cost per kW (350 kW)                          | \$ 2,566   |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-15C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Figure C-15C




Table C-15C. Annual Operating Cost for Lake Amador Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,600 |
| Insurance                 | 16,000    |
| Interim Replacements      | 2,400     |
| Total                     | \$ 32,000 |

The annual cost of owning and operating the project would range between 14 to 21 percent of the direct project cost of \$898,000, depending on financing. The estimated cost of generation ranges between 5.0 cents and 7.5 cents per kWh (Table C-15D).


Table C-15D. Average Cost of Energy for Lake Amador Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$112,300     | \$143,700 | \$159,800 |
| Operating Cost            | 32,000        | 32,000    | 32,000    |
| Total Annual Cost         | \$144,300     | \$175,700 | \$191,800 |
| Average Cost (per kWh)    | 5.7¢          | 6.9¢      | 7.5¢      |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 95,200     | \$129,300 | \$145,500 |
| Operating Cost            | 32,000        | 32,000    | 32,000    |
| Total Annual Cost         | \$127,200     | \$161,300 | \$177,500 |
| Average Cost (per kWh)    | 5.0¢          | 6.3¢      | 7.0¢      |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is further assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of Lake Amador hydroelectric generation exceeds the estimated cost of generation (5.0 to 7.5 cents per kWh), the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of Lake Amador generation would change little from year to year since only the maintenance cost of the facility is subject to inflation.

Figure C-16A Lake Shastina Powerplant



## 16. Lake Shastina (Shasta River Dam)

Shasta River Dam, owned and operated by the Montague Water Conservation District, is located about 16 km (10 mi) southeast of Grenada in Siskiyou County (Fig. C-16A). The dam's reservoir, Lake Shastina, provides water for irrigation in the Shasta Valley and for municipal purposes in the city of Montague.

Site Characteristics. The dam is a hydraulic earthfill structure about 30.5 m (100 ft) high. Water is released through the dam's lower outlet which is a concrete pipe 2.6 m (8.5 ft) in diameter and about 150 m (492 ft) long. Releases are controlled by four 0.9 m by 1.3 m (2.8 ft by 4.3 ft) cast iron slide gates located in a tower at the dam and about 45 m (148 ft) from the reservoir's intake structure. The outlet discharges water directly into a canal. Under normal conditions only one of the four gates is used to release water. A 13 kV transmission line is located about 300 m (1,000 ft) from the site.



Potential Generation. The potential capacity is 200 kW, and the estimated average annual output is 741 000 kWh (Table C-16A).

Table C-16A. Energy Generation for Lake Shastina Project


| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | --   | --   | --    | --    | --             | --            | --              |
| February  | --   | --   | --    | --    | --             | --            | --              |
| March     | --   | --   | --    | --    | --             | --            | --              |
| April     | 15.2 | 50   | 1.5   | 52    | 65             | 143           | 103 000         |
| May       | 14.6 | 48   | 1.8   | 64    | 78             | 203           | 151 000         |
| June      | 14.0 | 46   | 2.0   | 69    | 78             | 209           | 150 000         |
| July      | 12.2 | 40   | 2.2   | 78    | 78             | 206           | 153 000         |
| August    | 10.4 | 34   | 2.1   | 75    | 78             | 168           | 125 000         |
| September | 9.8  | 32   | 1.4   | 48    | 63             | 82            | 59 000          |
| October   | 9.1  | 30   | 0.8   | 28    | --             | --            | --              |
| November  | --   | --   | --    | --    | --             | --            | --              |
| December  | --   | --   | --    | --    | --             | --            | --              |
| Total     |      |      |       |       |                |               | 741 000         |

New Power Plant Structures. A turbine and generator installed near the downstream end of the existing lower outlet conduit could use the 9 m to 15 m (30 ft to 50 ft) available head at the dam. The proposed generating facility includes a 0.9 m (3 ft) steel penstock installed inside the outlet conduit starting from the existing gate structure (Fig. C-16B). The penstock would use one of the four existing slide-gate openings. The slide gate would be left open, and releases to the generating unit would be controlled by a butterfly valve. The penstock would carry water to a horizontal Francis turbine that could develop 270 hp under a 15 m (50 ft) head. The turbine would be connected directly to a horizontal, air-cooled synchronous generator with a rated output of 200 kW. Operation of the


Figure C-16B




NEW POWERHOUSE PLAN




SECTION A-A



SECTION B-B



PLAN



PROFILE

(ALONG § OUTLET WORKS, § PENSTOCK AND § TUNNEL)

STATE OF CALIFORNIA  
THE RESOURCE AGENCY  
DEPARTMENT OF WATER RESOURCES  
MORTGAGE WATER CONSERVATION DISTRICT  
LAKE SHASTINA  
200KW POWER PLANT  
POWERHOUSE - PLAN AND SECTIONS

NOTE:  
DIMENSION UNITS IN BRACKETS

hydroelectric plant and of the existing facility would be kept separate by a butterfly valve upstream from the turbine.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$426,800, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$721,600 (Table C-16B).

Table C-16B. Project Cost for Lake Shastina Plant

| Cost Item                                     | Amount    |
|---|-----------|
| Direct Cost                                   |           |
| Hydroelectric Plant Facilities                | \$302,600 |
| Transmission Facilities                       | 15,000    |
| Subtotal                                      | \$317,600 |
| Contingencies (20%)                           | 63,500    |
| Total   | \$381,100 |
| Engineering and Administration (12%)          | 45,700    |
| Total Construction Cost (January 1980 prices) | \$426,800 |
| Escalation (4 yrs. at 12% per year)           | 244,800   |
| Total Construction Cost (January 1984 prices) | \$671,600 |
| Studies, Licensing, Permits, and Approvals    | 50,000    |
| Total   | \$721,600 |
| Cost per kW (200 kW)                          | \$ 3,608  |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-16C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-16C. Annual Operating Cost for Lake Shastina Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 8,500     |
| Interim Replacements      | 1,300     |
| Total                     | \$ 22,800 |

The annual cost of owning and operating the project would range from 14 to 21 percent of the direct project cost of \$721,600, depending on



financing. The estimated cost of generation ranges between 13.4 cents and 18.9 cents per kWh (Table C-16D).


Table C-16D. Average Cost of Energy for Lake Shastina Project

| Cost Item                 | Amount<br>Interest Rate |           |           |
|---------------------------|-------------------------|-----------|-----------|
|                           | 9%                      | 12%       | 15%       |
| For 20-year term of debt: |                         |           |           |
| Fixed Annual Cost Rate    | 12.5%                   | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$ 90,200               | \$115,500 | \$128,400 |
| Operating Cost            | 22,800                  | 22,800    | 22,800    |
| Total Annual Cost         | \$113,000               | \$138,300 | \$151,200 |
| Average Cost (per kWh)    | 15.2¢                   | 18.7¢     | 20.4¢     |
| For 35-year term of debt: |                         |           |           |
| Fixed Annual Cost Rate    | 10.6%                   | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 76,500               | \$103,900 | \$116,900 |
| Operating Cost            | 22,800                  | 22,800    | 22,800    |
| Total Annual Cost         | \$ 99,300               | \$126,700 | \$139,700 |
| Average Cost (per kWh)    | 13.4¢                   | 17.1¢     | 18.9¢     |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is further assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh, using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. The estimated value of Lake Shastina generation is less than the estimated cost of generation (13.4 to 20.4 cents per kWh). The project cost would probably exceed revenues from sales of project generation for the first year of operation. Thus, the project would probably be cost effective after the first year of generation. Benefits would accrue during subsequent years as the price of oil increases, since only the cost of maintaining the facility is subject to inflation.

Figure C-17A Lemoncove Ditch Powerplant



## 17. Lemoncove Ditch (At Terminus Dam)

The Lemoncove Ditch site is an alternative partial development of the Terminus Dam for hydroelectric generation. Terminus Dam, a flood control facility operated by the U.S. Army Corps of Engineers, is about 32 km (20 mi) upstream from Visalia on the Kaweah River in Tulare County (Fig. C-17A). Terminus Dam creates a reservoir known as Lake Kaweah.

The outlet works of the facility contains a separate conduit used exclusively for delivering water to Lemoncove Ditch. The conduit can carry flows considerably higher than the water requirements of Lemoncove Ditch and, by minor redevelopment, could be used both to deliver water to Lemoncove and to carry partial releases from Lake Kaweah for electrical generation.

Site Characteristics. The outlet works of Terminus Dam include a 0.9 m (3 ft) concrete-encased steel pipe through the dam used for delivering irrigation water into the Lemoncove and Hawkeye Ditches. The pipe passes through the intake gate chamber where flows are controlled by standard service and emergency gate valves. The pipe is under the outlet tunnel invert between the intake gate chamber and the outlet tunnel portal and is about 370 m (1200 ft) long (Sec. A-A of Fig. C-17B). From the outlet tunnel portal, the pipe passes under the outlet channel for about 9 m (30 ft) then turns left to discharge water into a stilling well at the headworks of Lemoncove Ditch.

Potential Generation. Water deliveries to Lemoncove Ditch amount to 0.23 cms (8 cfs) during the irrigation season and 0.03 cms (1 cfs) or less at other times of the year. The 0.3 m (1 ft) pipe from the stilling well to Hawkeye Ditch can deliver up to 0.09 cms (3 cfs) of water. The capacity of the 0.9 m (3 ft) pipe through the dam is about 1.84 cms (65 cfs). All water releases up to the capacity of the pipe could be used for electrical generation.

A vertical Francis turbine is being considered for installation at the site, because the head, which normally varies between 21 m and 49 m (70 ft and 160 ft), is greater than the range that can be used with tube turbines. During most years the pipe could be operated continuously at full capacity.

The potential installed capacity would be 650 kW, and the estimated annual generation is about 3.5 million kWh (Table C-17A).

Table C-17A. Energy Generation for Lemoncove Ditch Project

| Month   | Head |      | Flow  |       | Efficiency<br>(%) | Capacity<br>(kW) | Energy<br>(kWh/yr) |
|---|------|------|-------|-------|-------------------|------------------|--------------------|
|   | (m)  | (ft) | (cms) | (cfs) |                   |                  |                    |
| January   | 25.3 | 83   | 1.8   | 65    | 84                | 382              | 285 000            |
| February  | 24.1 | 79   | 1.8   | 65    | 84                | 364              | 245 000            |
| March   | 28.7 | 94   | 1.8   | 65    | 84                | 433              | 323 000            |
| April   | 37.2 | 122  | 1.6   | 57    | 84                | 493              | 356 000            |
| May   | 49.1 | 161  | 1.6   | 57    | 84                | 651              | 485 000            |
| June  | 46.9 | 154  | 1.6   | 57    | 84                | 622              | 448 000            |
| July  | 35.7 | 117  | 1.6   | 57    | 84                | 473              | 353 000            |
| August  | 24.4 | 80   | 1.6   | 57    | 84                | 323              | 241 000            |
| September   | 21.6 | 71   | 1.6   | 57    | 84                | 287              | 207 000            |
| October   | 21.6 | 71   | 1.6   | 58    | 84                | 292              | 218 000            |
| November  | 21.3 | 70   | 1.7   | 60    | 84                | 298              | 215 000            |
| December  | 20.7 | 68   | 1.8   | 65    | 84                | 313              | 234 000            |
| Available Generation                                  |      |      |       |       |                   |                  | 3 610 000          |
| Less Scheduled Maintenance<br>(336 hours in December) |      |      |       |       |                   |                  | 128 000            |
| Total   |      |      |       |       |                   |                  | 3 482 000          |

New Power Plant Structures. A turbine and generator installed outside the lower outlet tunnel portal on an extension of the existing 914 mm (36 in) diameter pipe could use the 21 m to 49 m (70 ft to 160 ft) available head. This arrangement would result in a "Y" in the outlet pipe with one leg leading to the existing Lemoncove stilling well and the other leg to the new powerhouse (Figs. C-17B and C-17C).

The proposed power plant arrangement would include a 34 m (112 ft) extension of the 0.9 m (3 ft) pipe which would convey water to a vertical Francis turbine, and a tailrace channel about 20 m (66 ft) long that would discharge into the river. The turbine could develop 870 hp under a 31 m (102 ft) head and would be connected directly to a vertical, air-cooled synchronous generator with a rated output of 650 kW.


The operation of the power plant would be separated from the operation of the existing installation used to release water to Lemoncove Ditch by a butterfly valve installed upstream from the turbine. A second butterfly valve would be installed on the Lemoncove pipe about 6 m (20 ft) upstream of the stilling well. These valves would be used to regulate flows between Lemoncove Ditch and the new power plant.

A 13 kV transmission line, owned by PGandE, is located at the site. The only other transmission facilities required would be a transformer, protective equipment, and a short connecting line.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$1,074,300, based on January 1980 prices. About



Figure C-17C



STATE OF CALIFORNIA  
 THE RESOURCE AGENCY  
 DEPARTMENT OF WATER RESOURCES  
 U.S. ARMY CORPS OF ENGINEERS  
**LEMONCOVE DITCH  
 650kW POWER PLANT**  
 POWERHOUSE - PLAN AND SECTIONS

**NOTE.**  
 ALL DATA ARE IN THE METRIC SYSTEM EXCEPT DATA BETWEEN BRACKETS WHICH ARE IN THE ENGLISH SYSTEM.

36 months will be required for completing the feasibility study, obtaining approvals, design, and building. If the project were initiated in 1981, the work could be completed for first-year operation in 1984. The estimated capital cost in 1984, with 12 percent inflation, is \$1,790,400 (Table C-17B).

Table C-17B. Project Cost for Lemoncove Ditch Plant

| Cost Item                                     | Amount      |
|---|-------------|
| <b>Direct Cost</b>                            |             |
| Hydroelectric Plant Facilities                | \$ 784,300  |
| Transmission Facilities                       | 15,000      |
| Subtotal                                      | \$ 799,300  |
| Contingencies (20%)                           |             |
| Total   | \$ 159,900  |
| Engineering and Administration (12%)          |             |
| Total Construction Cost (January 1980 Prices) | \$1,074,300 |
| Escalation (4 yrs. at 12% per year)           |             |
| Total Construction Cost (January 1984 Prices) | \$1,690,400 |
| Studies, Licensing, Permits, and Approvals    |             |
| Total   | \$1,790,400 |
| Cost per kW (650 kW)                          | \$ 2,754    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-17C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-17C. Annual Operating Cost for Lemoncove Ditch Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 47,600 |
| Insurance                 | 25,500    |
| Interim Replacements      | 4,000     |
| Total                     | \$ 77,100 |

The annual cost of owning and operating the project would range between 15 and 22 percent of the direct project cost of \$1,790,400, depending on financing. The estimated cost of generation ranges between 7.7 cents and 11.4 cents per kWh (Table C-17D).



Table C-17D. Average Cost of Energy for Lemoncove Ditch Project


| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$223,800     | \$286,500 | \$318,600 |
| Operating Cost            | 77,100        | 77,100    | 77,100    |
| Total Annual Cost         | \$300,900     | \$363,600 | \$395,800 |
| Average Cost (per kWh)    | 8.6¢          | 10.4¢     | 11.4¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$189,800     | \$257,800 | \$290,000 |
| Operating Cost            | 77,100        | 77,100    | 77,100    |
| Total Annual Cost         | \$266,900     | \$334,900 | \$367,100 |
| Average Cost (per kWh)    | 7.7¢          | 9.6¢      | 10.5¢     |

Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydro-electric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Since the water used by the Lemoncove project could be composed--in full or in part--of minimum reservoir releases, it is possible that the project would have a capacity value in addition to the 11.1 cents per kWh of energy value. The theoretical study of water and power operations required by PGandE's proposed policy would determine if the project will have a capacity value.

Conclusions. For tax-exempt bond financing at 9 percent interest, the estimated minimum value of Lemoncove generation exceeds the estimated generation cost (7.7 to 11.4 cents per kWh). Thus, the project would be cost effective.

Figure C-18A Virginia Ranch Dam Powerplant



## 18. Merle Collins Reservoir (Virginia Ranch Dam)

Merle Collins Reservoir and Virginia Ranch Dam are owned and operated by the Browns Valley Irrigation District. It is located on Dry Creek near the community of Browns Valley in Yuba County (Fig. C-18A). In addition to providing part of the water supply for the District, stored water is carried by tunnel and open channel to Browns Valley where it is used for irrigation. The reservoir is also used for boating, fishing, picnicking, and camping. The project was constructed in 1963.

At present, water in the reservoir provides more head than is needed for irrigation releases to the District. However, head is dissipated and wasted by a discharge valve since the District's system is not under pressure. This study investigated the possibility of using hydroelectric facilities to generate energy using the reservoir releases now being wasted, and the spillway discharges that presently by-pass the irrigation tunnel and canal system.

Site Characteristics Water is released to the Browns Valley irrigation system through a manually operated valve. A 0.2 cms (6 cfs) release is made through a second valve to Dry Creek to enhance streamflow. An access road, available for operation and maintenance of the valves and outlet works, would be available for construction and operation of the hydroelectric facility.

A 13 kV single-phase transmission line, owned and operated by PGandE, is located about 1.6 km (1 mi) from the site. Energy generated at this site could be delivered to PGandE by building a 13 kV transmission line for a distance of 4.8 km (3 mi) to connect the existing PGandE line to the site and by installing a third conductor on the existing line.

Irrigation water is released between April and October with the largest releases occurring during July and August, the maximum discharge is about 4.5 cms (160 cfs). Most of the spillway discharge that now flows down Dry Creek could be carried through the District's tunnel and canals during winter months to produce electric power. Power can be generated for about 9 months during an average-water year. This would require that water be released for power production early in the year, when storage in the reservoir reaches 56 740 cubic dekametres (46,000 ac-ft).

Potential Generation. A vertical Francis turbine is being considered for use at this site, because the net operating head of 27.4 m to 37.8 m (90 ft to 124 ft) exceeds that which is usable for a tube-type turbine.

The potential generation capacity would be 900 kW, and the estimated annual generation is about 5.6 million kWh (Table C-18A).

Table C-18A. Energy Generation for Merle Collins Reservoir Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | --   | --   | 0.1   | 3     | --             | --            | --              |
| February  | 35.4 | 116  | 2.9   | 104   | 85             | 865           | 581 000         |
| March     | 38.7 | 127  | 2.9   | 104   | 85             | 947           | 705 000         |
| April     | 38.7 | 127  | 3.1   | 108   | 85             | 984           | 708 000         |
| May       | 37.5 | 125  | 3.1   | 108   | 85             | 968           | 720 000         |
| June      | 35.7 | 118  | 3.1   | 108   | 85             | 914           | 658 000         |
| July      | 32.0 | 108  | 3.3   | 118   | 85             | 914           | 680 000         |
| August    | 29.9 | 100  | 3.3   | 118   | 85             | 846           | 629 000         |
| September | 28.0 | 90   | 3.1   | 108   | 85             | 697           | 502 000         |
| October   | 27.4 | 80   | 3.1   | 108   | 85             | 620           | 461 000         |
| November  | --   | --   | 0.1   | 3     | --             | --            | --              |
| December  | --   | --   | 0.1   | 3     | --             | --            | --              |
| Total     |      |      |       |       |                |               | 5 644 000       |

Existing Structures. Virginia Ranch Dam is a 46 m high (150 ft) earth and rockfill dam with a crest 580 m (1900 ft) long. The reservoir has a total storage capacity of 70 310 cubic dekametres (57,000 ac-ft).

Controlled releases from the reservoir are made through an outlet low on the west side of the dam. This outlet consists of a concrete conduit, 1.2 m (4 ft) in diameter, for the first 82.3 m (270 ft) from the reservoir outlet to a gate chamber near the mid-point of the dam. Downstream from the gate chamber, for about 107 m (350 ft) to the valve house, the outlet consists of a 1.1 m (3.5 ft) diameter steel pipe inside a 2.1 m (7 ft) diameter horseshoe concrete conduit.


The main valve is a standard Howell-Bunger valve, which discharges the water into a stilling basin then through about 30.5 m (100 ft) of open channel into a tunnel 1158 m (3800 ft) long.

Upstream from the Howell-Bunger valve, a 381 mm (15 in) by-pass outlet pipe discharges water into the natural stream channel for fish and vegetation. The minimum flow to the channel is 0.2 cms (6 cfs).

New Power Plant Structures. A turbine-generator installed at the downstream end of the existing, lower-level conduit could use the 27.4 m to 37.8 m (90 ft to 124 ft) available head. The proposed generating facility would include a 1067 m (42 in) steel pipe by-pass which would carry water from about 3.1 m (10 ft) upstream of the existing valve building to a vertical Francis turbine (Figs. C-17B and C-17C). The turbine could develop 1160 hp at 720 rpm under a 32 m (105 ft) head and would be connected directly to a vertical, air-cooled synchronous generator with a rated output of 900 kW.



Figure C-18C



Downstream, the waterway would consist of a tailrace channel, about 16.8 m (55 ft) long, which would connect to the existing main channel that carries the water into the downstream tunnel.

The operation of the hydroelectric plant would be separated from that of the existing irrigation installation by a butterfly valve installed upstream from the turbine. Stop logs at the beginning of the new tailrace channel would separate it from the existing main channel so the turbine could be dewatered for maintenance.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$1,260,000, based on January 1980 prices. About 36 months will be required for completing the feasibility study, obtaining approvals, design, and building. Assuming that the project will be initiated early in 1981 and completed early in 1984, the estimated total project cost (with 12 percent annual inflation) is \$2,082,600 (Table C-18B).

Table C-18B. Project Cost for Merle Collins Reservoir Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 878,950  |
| Transmission Facilities                       | 58,550      |
| Subtotal                                      | \$ 937,500  |
| Contingencies (20%)                           | 187,500     |
| Total   | \$1,125,000 |
| Engineering and Administration (12%)          | 135,000     |
| Total Construction Cost (January 1980 Prices) | \$1,260,000 |
| Escalation (4 yrs. at 12% per year)           | 722,600     |
| Total Construction Cost (January 1984 Prices) | \$1,982,600 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$2,082,600 |
| Cost per kW (900 kW)                          | \$ 2,314    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-18C). The cost of operation would be insignificant since an operator must always be available to set the discharge valve for irrigation releases. Regular maintenance could be scheduled during the nonirrigation season when there would be no water for generation.

Table C-18C. Annual Operating Cost for Merle Collins Reservoir Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 34,000    |
| Interim Replacements      | 5,400     |
| Total                     | \$ 52,400 |

The annual cost of owning and operating the project would range between 13 and 20 percent of the direct project cost of \$2,082,600, depending on financing. The estimated cost of generation ranges between 4.8 cents and 7.5 cents per kWh (Table C-18D).


Table C-18D. Average Energy Cost of Merle Collins Reservoir Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$260,300     | \$333,200 | \$370,700 |
| Operating Cost            | 52,400        | 52,400    | 52,400    |
| Total Annual Cost         | \$312,700     | \$385,600 | \$423,100 |
| Average Cost (per kWh)    | 5.5¢          | 6.8¢      | 7.5¢      |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$220,800     | \$299,900 | \$337,400 |
| Operating Cost            | 52,400        | 52,400    | 52,400    |
| Total Annual Cost         | \$273,200     | \$352,300 | \$389,900 |
| Average Cost (per kWh)    | 4.8¢          | 6.2¢      | 6.9¢      |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is also assumed for the purpose of this study that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydro-electric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of Virginia Ranch generation in 1984 is 11.1 cents per kWh, using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of Virginia Ranch hydroelectric generation exceeds the estimated cost of generation (4.8 to 7.5 cents per kWh), the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The generation cost would change little from year to year, since only maintenance cost is subject to escalation.

Figure C-19A Mount Olivette Powerplant



## 19. Mount Olivette

The Mount Olivette site is a pipeline pressure break owned and operated by the city of Santa Monica in Los Angeles County (Fig. C-19A). Water is delivered to the site through a cast iron pipeline which is 457 mm (18 in) in diameter and 1067 m (3500 ft) long. The water is pressurized at the source of supply by the Metropolitan Water District of Southern California.

Site Characteristics. The Santa Monica water distribution system is divided into pressure zones for 150, 100, and 80 metres (500, 350, and 250 feet). About 20 percent of the water received at Mount Olivette by-passes the pressure break for distribution in the 150 m (500 ft) pressure zone. The remaining 80 percent passes through the pressure break valve to the Mount Olivette reservoir which, in turn, pressurizes the 100 m (350 ft) pressure zone. Water for the 80 m (250 ft) pressure zone is pumped from wells. The 4 kV transmission line located at the site is owned and operated by the Southern California Edison (SCE). The flow characteristics of the site are such that energy could be generated during all months of the year except February; the greatest flows occur during June, July, and August.


Potential Generation. The potential generation capacity of the Mount Olivette site would be about 150 kW; the estimated average annual output is 1.1 million kWh (Table C-19A).

Table C-19A. Energy Generation for Mount Olivette Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 59.1 | 194  | 0.3   | 9.7   | 79             | 126           | 94 000          |
| February  | 66.2 | 217  | 0.2   | 6.9   | --             | --            | --              |
| March     | 61.9 | 203  | 0.2   | 8.7   | 76             | 114           | 84 000          |
| April     | 61.0 | 200  | 0.3   | 9.0   | 77             | 117           | 84 000          |
| May       | 50.9 | 167  | 0.4   | 12.5  | 84             | 148           | 110 000         |
| June      | 47.0 | 154  | 0.4   | 13.7  | 84             | 150           | 108 000         |
| July      | 48.8 | 160  | 0.4   | 13.1  | 84             | 149           | 111 000         |
| August    | 48.8 | 160  | 0.4   | 13.1  | 84             | 149           | 111 000         |
| September | 57.6 | 189  | 0.3   | 10.3  | 80             | 132           | 95 000          |
| October   | 58.2 | 191  | 0.3   | 10.0  | 78             | 126           | 94 000          |
| November  | 55.8 | 183  | 0.3   | 10.9  | 82             | 138           | 100 000         |
| December  | 57.0 | 187  | 0.3   | 10.6  | 81             | 168           | 125 000         |
| Total     |      |      |       |       |                |               | 1 116 000       |

New Power Plant Structures. A turbine-generator installed at the site could use the 47 m to 66 m (154 ft to 217 ft) available head. The proposed generating facility would include a steel by-pass penstock to a horizontal Francis turbine which could develop 200 hp at 0.4 cms (13 cfs) under a 49 m (160 ft) head (Fig. C-19B). The turbine would be connected directly to a horizontal electric generator having a rated capacity of 150 kW. The operation of the hydroelectric facility would be separated from that of the

Figure C-19B



STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES  
 CITY OF SANTA MONICA  
 MOUNT OLIVETTE  
 150kW POWER PLANT  
 POWERHOUSE - PLAN AND SECTION

NOTE:  
 DIMENSIONS IN MILLIMETERS

existing operation by butterfly valves installed upstream and downstream from the turbine.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$315,800, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983 (with 12 percent annual inflation) is \$546,900 (Table C-19B).

Table C-19B. Project Cost for Mount Olivette Plant

| Cost Item                                     | Amount    |
|---|-----------|
| <b>Direct Cost</b>                            |           |
| Hydroelectric Plant Facilities                | \$220,000 |
| Transmission Facilities                       | 15,000    |
| Subtotal                                      | \$235,000 |
| Contingencies (20%)                           | 47,000    |
| Total   | \$282,000 |
| Engineering and Administration (12%)          | 33,800    |
| Total Construction Cost (January 1980 Prices) | \$315,800 |
| Escalation (4 yrs. at 12% per year)           | 181,100   |
| Total Construction Cost (January 1984 Prices) | \$496,900 |
| Studies, Licensing, Permits, and Approvals    | 50,000    |
| Total   | \$546,900 |
| Cost per kW (150 kW)                          | \$ 3,646  |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-19C). Regular maintenance could be scheduled during the winter months when water flow is at a minimum.

Table C-19C. Annual Operating Cost for Mount Olivette Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 20,400 |
| Insurance                 | 8,500     |
| Interim Replacements      | 1,500     |
| Total                     | \$ 30,400 |

The annual cost of owning and operating the project would range between 16 and 23 percent of the direct project cost of \$546,900, depending



on financing. The estimated cost of generation ranges between 7.9 cents and 11.4 cents per kWh (Table C-19D).


Table C-19D. Average Cost of Energy of Mount Olivette Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$ 68,400     | \$ 87,500 | \$ 97,300 |
| Operating Cost            | 30,400        | 30,400    | 30,400    |
| Total Annual Cost         | \$ 98,800     | \$117,900 | \$127,700 |
| Average Cost (per kWh)    | 8.8¢          | 10.6¢     | 11.4¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 58,000     | \$ 78,800 | \$ 88,600 |
| Operating Cost            | 30,400        | 30,400    | 30,400    |
| Total Annual Cost         | \$ 88,400     | \$109,200 | \$119,000 |
| Average Cost (per kWh)    | 7.9¢          | 9.8¢      | 10.7¢     |

Value of Generation. It is assumed that project generation would be sold to SCE under Section 210 of PURPA. The project would have a capacity value because flows would be available during on-peak hours in all months except February, when there is insufficient water for power generation. On this basis, the estimated value of project generation in 1984 is 13.3 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of Mount Olivette generation exceeds the estimated generation cost (7.9 to 11.4 cents per kWh), the project would be cost effective during its first year of operation. Additional benefits would accrue in subsequent years as the price of oil increases. The generation cost would change little from year to year, since only maintenance costs are subject to escalation.

Figure C-20A No. 8 Heading Powerplant



## 20. No. 8 Heading

The No. 8 Heading site, a check structure on the Westside Main Canal, is owned and operated by the Imperial Irrigation District. The site is about 8 km (5 mi) northwest of Imperial City in Imperial County (Fig. C-20A).

**Site Characteristics.** The existing concrete structure is about 25 m (82 ft) long, and discharges the streamflow into the canal over a 4.2 m (13.8 ft) drop. The structure has three separate bays, each 2.1 m (7 ft) wide and 3.7 m (12 ft) high. The water is discharged downstream through three 1.5 m (5 ft) diameter pipes approximately 15 m (50 ft) long. The installation also includes an automatic spillway about 6 m (20 ft) east of the main check structure. The spillway consists of a radial entrance gate 1.8 m (6 ft) wide by 2.2 m (7.3 ft) high and a 1.5 m (5 ft) diameter pipe about 30 m (100 ft) long.

**Potential Generation.** A horizontal tube-type turbine is considered for installation at No. 8 Heading because of the constantly low head which ranges between 4.0 m (13.2 ft) and 4.3 m (14.2 ft). Since the flows range between 14 cms and 22 cms (500 cfs and 775 cfs) for eight months of the year, a fixed propeller runner would generate about 87 percent of the potential energy of the site.


The potential installed capacity would be 750 kW; the estimated annual generation is about 3.9 million kWh (Table C-20A).

Table C-20A. Energy Generation of No. 8 Heading Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 4.4  | 14.5 | 3.54  | 125   | --             | --            | --              |
| February  | 4.3  | 14.1 | 10.62 | 375   | 60             | 268           | 180 000         |
| March     | 4.2  | 13.7 | 15.57 | 550   | 67             | 427           | 318 000         |
| April     | 4.0  | 13.2 | 21.95 | 775   | 84             | 727           | 523 000         |
| May       | 4.0  | 13.2 | 19.82 | 700   | 84             | 657           | 489 000         |
| June      | 4.0  | 13.2 | 21.95 | 775   | 84             | 727           | 523 000         |
| July      | 4.0  | 13.2 | 21.95 | 750   | 84             | 704           | 524 000         |
| August    | 4.0  | 13.2 | 19.82 | 700   | 84             | 657           | 489 000         |
| September | 4.1  | 13.5 | 18.41 | 650   | 78             | 579           | 417 000         |
| October   | 4.2  | 13.8 | 14.61 | 500   | 65             | 379           | 282 000         |
| November  | 4.3  | 14.2 | 9.91  | 350   | 55             | 231           | 166 000         |
| December  | 4.4  | 14.4 | 7.08  | 250   | --             | --            | --              |
| Total     |      |      |       |       |                |               | 3 911 000       |

**New Power Plant Structures.** A turbine and generator installed at No. 8 Heading could use the 4.2 m (13.8 ft) available head. The proposed generating facility includes an approach channel--3.5 m (11.5 ft) wide and 41 m (134.5 ft) long--on the left side of the canal, a horizontal tube-type turbine, and a short tailrace to return stream flows to the canal downstream from the check structure (Fig. C-20B). The turbine could develop 1000 hp under the available head and would be connected, through a speed increaser,

Figure C-20B



to a horizontal air-cooled synchronous generator with a rated output of 750 kW. An inlet gate would be installed in front of the turbine so that the turbine can be dewatered for maintenance.

The proposed arrangement of the power facility would by-pass the existing check structure, and the power plant could be built without affecting the existing water conveyance facilities.

A 13 kV transmission line is located at the site; the only other transmission facilities required are a transformer, protective equipment, and a short, connecting transmission line.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$1,570,600, based on January 1980 prices. Since the generating facility would be located on an installed conduit which is operated primarily for purposes other than power generation, the site would probably be exempt from federal licensing requirements. (The exemption provision is discussed in detail in Appendix C.) However, the District would have to comply with CEQA requirements and obtain other state approvals, if necessary.

If the project were initiated in 1981, and about 30 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work would be completed in late 1983 for operation in 1984. At a 12 percent inflation rate, the estimated project cost in late 1983 is \$2,521,400 (Table C-20B).

Table C-20B. Project Cost of No. 8 Heading Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$1,156,100 |
| Transmission Facilities                       | 12,500      |
| Subtotal                                      | \$1,168,600 |
| Contingencies (20%)                           | 233,700     |
| Total   | \$1,402,300 |
| Engineering and Administration (12%)          | 168,300     |
| Total Construction Cost (January 1980 Prices) | \$1,570,600 |
| Escalation (4 yrs. at 12% per year)           | 900,800     |
| Total Construction Cost (January 1984 Prices) | \$2,471,400 |
| Studies, Licensing, Permits, and Approvals    | 50,000      |
| Total   | \$2,521,400 |
| Cost per kW (750 kW)                          | \$ 3,362    |

Cost of Generation. Since the facility and an electric transmission and distribution system are owned and operated by the Imperial Irrigation District, it is assumed that the District would develop and use the power

in its own system. The annual costs of owning and operating the project would include debt repayment, the costs of operation and maintenance, insurance, replacements, administration, and overhead.

It is assumed that the District would finance construction by issuing tax-exempt revenue bonds, and that the bonds could be issued for a 35-year term at 9 percent interest. The actual interest rate would depend on financial conditions when the bonds were issued. It is expected that initial development would be financed from electric system revenues or short-term loans and that the bonds would not be issued until about 12 months before the project is completed. The additional cost of operating the plant would be insignificant, since the District already has a full staff of operating personnel. Regular maintenance could be scheduled during the nonirrigation season when there is insufficient water for power generation.

If the project were scheduled to be on-line late in 1983, the bond issue would be about \$3,050,000 based on January 1980 bid prices, with a 12 percent annual interest rate and a one-year construction period.

The estimated average generation cost, assuming 35-year bonds, is \$389,200 or 10 cents per kWh. For 20-year bonds, the estimated average generation cost would increase to 11.3 cents per kWh (Table C-20C).

Table C-20C. Average Energy Cost of No. 8 Heading Project

| Cost Item                       | Amount             |                    |
|---------------------------------|--------------------|--------------------|
|                                 | 20-year<br>Bonds   | 35-year<br>Bonds   |
| Project Cost                    | \$2,521,400        | \$2,521,400        |
| Capitalized Interest            | 226,900            | 226,900            |
| Interest Earnings               | (113,500)          | (113,500)          |
| <b>Total Capital Cost</b>       | <b>\$2,634,800</b> | <b>\$2,634,800</b> |
| Bond Reserve Fund               | 339,600            | 288,600            |
| Financing Cost                  | 125,600            | 126,600            |
| Bond Issue                      | \$3,100,000        | \$3,050,000        |
| Debt Service (9% interest)      | \$339,600          | \$288,600          |
| Operation and Maintenance       | 20,400             | 20,400             |
| Insurance                       | 100,200            | 100,200            |
| Interim Replacements            | 6,000              | 6,000              |
| Interest Earnings               | (26,000)           | (26,000)           |
| <b>Total Annual Cost</b>        | <b>\$ 440,200</b>  | <b>\$ 389,200</b>  |
| Annual Cost (% of Project Cost) | 17.4               | 15.4               |
| Average Cost (per kWh)          | 11.3¢              | 10.0¢              |

Since the District has experience with small hydroelectric facilities, it might elect to be self-insured--in full or in part--to reduce the annual

insurance premium it would pay on mechanical and electrical equipment. This would substantially reduce its annual generation cost.

Value of Generation. Since the District would probably use the energy produced in its own electric system, the value of such hydroelectric generation to the District would be equal to the cost of the fuel-generated energy it would replace. In addition to the District-owned and operated El Centro steam- electric plant, gas turbines, diesel units, and hydroelectric facilities, the District purchases power under contract from the WPRS and the Colorado River Storage Project.

Natural gas and oil are used for the El Centro steam-electric plant and for the gas turbines. The amount of natural gas burned to produce electricity has declined over the past few years, while the amount of oil burned has increased; this trend is expected to continue. Thus, the new hydroelectric generation would offset the use of oil and its true value would be equal to the cost of oil avoided.

A detailed computation of the avoided energy cost to the District is beyond the scope of this study. However, the average annual avoided energy cost can be estimated based on an average incremental heat rate for the District's generation and the projected price of oil. Assuming an average incremental heat rate of 10,000 Btu per kWh, system losses of 10 percent, and a 1980 oil price of \$26.30 per barrel (about \$4 per million Btu), the estimated avoided energy cost would be 4.5 cents per kWh. This cost is nearly the same as the SCE rate for mid-peak energy, and thus the projected value of avoided energy for the District can be taken from the partial-peak projection shown in Appendix G.

The District's cost of avoided capacity will depend on its long-range power supply program and the cost of adding generating capacity to its electric system. For the purpose of estimating the capacity value of new hydroelectric generation such as No. 8 Heading, an estimated value of \$100 per kW-year is considered appropriate for new capacity with a 35-year life and an initial year of operation in 1984, based on the cost of capacity to other electric utilities in California Volume I, Chapter 2, Table 9.

The estimated value of No. 8 Heading generation in 1984 is 11.7 cents per kWh (Table C-20D).




Table C-20D. Generation Value of No. 8 Heading Project

| Cost Item                    | Amount    |
|------------------------------|-----------|
| Capacity (August Capacity)   |           |
| 657 kW x \$100 per kW        | \$ 65,700 |
| Energy                       |           |
| 3 910 000 kWh at 10¢ per kWh | 391,100   |
| Total                        | \$456,800 |
| Average Value (per kWh)      | 11.7¢     |

Conclusions. Since the estimated value of No. 8 Heading generation exceeds the estimated cost of generation (10 to 11 cents per kWh), the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of No. 8 Heading generation would change little from year to year, since only the cost of maintaining the facility is subject to escalation.

Figure C-21A North Portal Tecolote Powerplant



## 21. North Portal Tecolote

The North Portal Tecolote site is located at the intake structure for the Tecolote Tunnel that diverts water from Lake Cachuma to the south coast area of Santa Barbara County (Fig. C-21A). The Cachuma Project, of which the Tecolote Tunnel is a part, was designed and constructed by the WPRS for the Santa Barbara County Water Agency. The Cachuma Operation and Maintenance Board operates the Cachuma facility for four county water districts and the city of Santa Barbara.

Lake Cachuma is formed by Bradbury Dam on the Santa Ynez River north-east of Santa Barbara. The Tecolote Tunnel from Lake Cachuma to its South Portal turnout is 10.3 km (6.4 mi) long and is presently experiencing groundwater infiltration at an average rate of 0.2 cms (5.5 cfs).

Site Characteristics. The hydraulic facility at the North Portal Tecolote site consists of an intake structure in Lake Cachuma and a reinforced-concrete tunnel 2.4 m (8 ft) in diameter and 244 m (800 ft) long. The tunnel carries water to an underground chamber containing a 914 mm (36 in) regulating valve, baffled energy dissipater, and chlorination equipment. The underground chamber can be reached by an elevator from the surface.

Potential Generation. The potential generation capacity of the site would be about 175 kW, and the estimated average annual output is about 720 000 kWh (Table C-21A).

Table C-21A. Energy Generation of North Portal Tecolote Project

| Month        | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|--------------|------|------|-------|-------|----------------|---------------|-----------------|
|              | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January      | 19.2 | 63   | 0.3   | 10.0  | --             | --            | --              |
| February     | 22.6 | 74   | 0.2   | 7.0   | --             | --            | --              |
| March        | 26.2 | 86   | 0.3   | 10.6  | --             | --            | --              |
| April        | 26.5 | 87   | 0.4   | 15.4  | 70             | 79            | 57 000          |
| May          | 26.2 | 86   | 0.7   | 24.9  | 84             | 152           | 113 000         |
| June         | 25.9 | 85   | 0.8   | 27.0  | 84             | 163           | 117 000         |
| July         | 24.4 | 80   | 0.9   | 32.4  | 84             | 159           | 118 000         |
| August       | 22.9 | 75   | 0.9   | 32.4  | 84             | 149           | 111 000         |
| September    | 21.0 | 69   | 0.7   | 26.1  | 84             | 128           | 92 000          |
| October      | 19.8 | 65   | 0.6   | 22.8  | 77             | 97            | 72 000          |
| November     | 19.2 | 63   | 0.4   | 14.8  | 71             | 56            | 40 000          |
| December     | 18.9 | 62   | 0.3   | 8.8   | --             | --            | --              |
| <b>Total</b> |      |      |       |       |                |               | <b>720 000</b>  |

New Power Plant Structures. A turbine-generator installed in an extension of the existing underground gate chamber could use the 19.2 m to 26.5 m (63 ft to 87 ft) available head at the Tecolote Intake site. The proposed generating facility would include a steel penstock, 457 mm (18 in) in diameter, connected through a T-connection to the existing water conduit to carry water to an inclined propeller turbine, a speed increaser, a generator, a 660 mm (26 in) diameter steel discharge pipe, and two butterfly

valves (Fig. C-21B). The turbine could develop 234 hp under a 26.5 m (87 ft) head and would be connected, through the gearbox speed increaser, to a generator rated at 175 kW. The operation of the hydroelectric facility would be separated from that of the existing facility by two butterfly valves installed upstream and downstream from the turbine.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$745,900, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983 (with 12 percent annual inflation) is \$1,223,700 (Table C-21B).

Table C-21B. Project Cost of North Portal Tecolote Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 545,000  |
| Transmission Facilities                       | 10,000      |
| Subtotal                                      | \$ 555,000  |
| Contingencies (20%)                           | 111,000     |
| Total   | \$ 666,000  |
| Engineering and Administration (12%)          | 79,900      |
| Total Construction Cost (January 1980 prices) | \$ 745,900  |
| Escalation (4 yrs. at 12% per year)           | 427,800     |
| Total Construction Cost (January 1984 prices) | \$1,173,700 |
| Studies, Licensing, Permits, and Approvals    | 50,000      |
| Total   | \$1,223,700 |
| Cost per kW (175 kW)                          | \$ 6,993    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-21C). Regular maintenance could be scheduled during the winter months.

Table C-21C. Annual Operating Cost of North Portal Tecolote Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 20,400 |
| Insurance                 | 8,500     |
| Interim Replacements      | 3,000     |
| Total                     | \$ 31,900 |





The annual cost of owning and operating the project would range between 13 and 20 percent of the direct project cost of \$1,223,700, depending on financing. The estimated cost of generation ranges between 22.4 cents and 34.7 cents per kWh (Table C-21D).


Table C-21D. Average Energy Cost of North Portal Tecolote Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$153,000     | \$195,800 | \$217,800 |
| Operating Cost            | 31,900        | 31,900    | 31,900    |
| Total Annual Cost         | \$184,900     | \$227,700 | \$249,700 |
| Average Cost (per kWh)    | 25.7¢         | 31.6¢     | 34.7¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$129,700     | \$176,200 | \$198,200 |
| Operating Cost            | 31,900        | 31,900    | 31,900    |
| Total Annual Cost         | \$161,600     | \$208,100 | \$230,100 |
| Average Cost (per kWh)    | 22.4¢         | 28.9¢     | 32.0¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydro-electric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh, using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of North Portal Tecolote generation is significantly less than the estimated cost of generation (22.4 to 34.7 cents per kWh), the project if constructed by 1984 would probably not be cost effective until 1990. This is based on the projected energy rates shown in Table 8, Chapter II.

Figure C-22A Parkview Station Powerplant



## 22. Parkview Station

Parkview Station is a spillway on the Anderson Canal in Redding in Shasta County (Fig. C-22A). The canal and the spillway are owned and operated by the Anderson-Cottonwood Irrigation District. At this point on the canal, the flow can be stopped by installing stoplogs and diverting all canal flow through the spillway into a ditch connected to the Sacramento River. In this way, the irrigation canal can serve as a forebay for a hydroelectric plant which can operate during the nonirrigation season between November and March.


Site Characteristics. The spillway outlet consists of a gate in the irrigation canal and a corrugated metal pipe, about 33.6 m (110 ft) long, which discharges into the lower ditch. Water taken from the Sacramento River for irrigation is returned to the river through this lower ditch. A 13 kV transmission line is located at the site.

Potential Generation. A flow of 4.3 cms (150 cfs) can be diverted through the Anderson Cottonwood Canal to the Parkview Station facility where a drop of 4.6 m (15 ft) is available. Based on this head and flow, the potential capacity during the five-month nonirrigation season would be 150 kW, and the estimated annual generation is 548 000 kWh.

New Power Plant Structures. A turbine-generator could be installed at this site. The proposed generating facility includes an improved intake, powerhouse, and tailrace channel discharging into the existing lower ditch (Fig. C-22B). Stoplogs could be used to shut off flow through the turbine during the irrigation season. The powerhouse would contain a vertical turbine which could develop 200 hp under the 4.6 m (15 ft) head. It would be connected, through a gear box speed increaser, to a horizontal generator with a rated output of 150 kW. The turbine would be provided with wicket gates, making an intake shutoff valve unnecessary.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$368,300, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$604,500 (Table C-22A).

Figure C-22B



STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES

ANDERSON COTTONWOOD IRRIGATION DISTRICT  
 PARKVIEW STATION  
 150 KW POWER PLANT  
 POWERHOUSE - PLAN AND SECTIONS

Table C-22A. Project Cost of Parkview Station Plant

| Cost Item                                     | Amount    |
|---|-----------|
| Direct Cost                                   |           |
| Hydroelectric Plant Facilities                | \$267,000 |
| Transmission Facilities                       | 7,000     |
| Subtotal                                      | \$274,000 |
| Contingencies (20%)                           | 54,800    |
| Total   | \$328,800 |
| Engineering and Administration (12%)          | 39,500    |
| Total Construction Cost (January 1980 prices) | \$368,300 |
| Escalation (4 yrs. at 12% per year)           | 211,200   |
| Total Construction Cost (January 1984 prices) | \$579,500 |
| Studies, Licensing, Permits, and Approvals    | 25,000    |
| Total   | \$604,500 |
| Cost per kW (150 kW)                          | \$ 4,030  |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-22B). Regular maintenance could be scheduled during the summer months when water would not be available for generation.

Table C-22B. Annual Operating Cost of Parkview Station Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 8,500     |
| Interim Replacements      | 1,300     |
| Total                     | \$ 22,800 |

The annual cost of owning and operating the project would range between 14 and to 22 percent of the direct project cost of \$604,500, depending on financing. The estimated cost of generation ranges between 15.8 cents and 23.8 cents per kWh (Table C-22C).




Table C-22C. Average Energy Cost of Parkview Station Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$ 75,600     | \$ 96,700 | \$107,600 |
| Operating Cost            | 22,800        | 22,800    | 22,800    |
| Total Annual Cost         | \$ 98,400     | \$119,500 | \$130,400 |
| Average Cost (per kWh)    | 18.0¢         | 21.8¢     | 23.8¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 64,100     | \$ 87,000 | \$ 97,900 |
| Operating Cost            | 22,800        | 22,800    | 22,800    |
| Total Annual Cost         | \$ 86,900     | \$109,800 | \$120,700 |
| Average Cost (per kWh)    | 15.8¢         | 20.0¢     | 22.0¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of Parkview Station generation is less than the estimated cost of generation (15.8 to 23.8 cents per kWh), the project would probably not be cost effective in the first three years of operation starting from 1984. This is based on the projected energy rate to be paid by PGandE under Section 210 of PURPA.

Figure C-23A Pumping Plant Lower Powerplant



### 23. Pumping Plant Lower

Pumping Plant Lower is a drop between two canals that are owned and operated by the Montague Water Conservation District. It is located about 6.4 km (4 mi) east of Montague in Siskiyou County (Fig. C-23A). The plant was constructed in the 1920s to harness the mechanical energy developed by water falling between the two canals and use it to pump part of the water to a higher elevation. However, the plant has not been used for that purpose, and the existing facility is in a deteriorated condition.

Site Characteristics. The original facility at the site consists of a 1219 mm (48 in) diameter riveted steel pipe that carried water from the upper canal to a horizontal turbine connected directly to a pump. The lower canal served as the tailrace for the turbine and as the source of water that was to be pumped to a higher elevation. The original facility was later modified by removing a section of the riveted-steel pipe and disconnecting the turbine. The pipe was capped and a 457 mm (18 in) diameter steel pipe by-pass was installed to carry the water directly to the lower canal. No energy dissipater was used. The gross head at the site is 12.6 m (41.5 ft). A 13 kV transmission line is adjacent to the site.





Potential Generation. The potential capacity would be 65 kW, and the estimated average annual output is 172 000 kWh (Table C-23A).

Table C-23A. Energy Generation of Pumping Plant Lower Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 12.2 | 40   | --    | --    | --             | --            | --              |
| February  | 12.2 | 40   | --    | --    | --             | --            | --              |
| March     | 12.2 | 40   | 0.1   | 5     | --             | --            | --              |
| April     | 12.2 | 40   | 0.3   | 9     | --             | --            | --              |
| May       | 12.2 | 40   | 0.5   | 17    | 65             | 37            | 27 500          |
| June      | 12.2 | 40   | 0.7   | 24    | 78             | 63            | 45 400          |
| July      | 12.2 | 40   | 0.6   | 22    | 76             | 57            | 42 400          |
| August    | 12.2 | 40   | 0.6   | 20    | 72             | 49            | 36 500          |
| September | 12.2 | 40   | 0.4   | 14    | 60             | 28            | 20 200          |
| October   | 12.2 | 40   | --    | --    | --             | --            | --              |
| November  | 12.2 | 40   | --    | --    | --             | --            | --              |
| December  | 12.2 | 40   | --    | --    | --             | --            | --              |
| Total     |      |      |       |       |                |               | 172 000         |

New Power Plant Structures. A turbine and generator installed at the Pumping Plant Lower site could use the 12.6 m (41.5 ft) available head. The proposed facility includes an intake structure on the upper canal to divert water into a new penstock, 762 mm (30 in) in diameter and about 180 m (590 ft) long, which would carry water to a vertical turbine (Fig. C-23B). The water would be discharged into the Lower Canal through a short tailrace channel. The turbine could develop 93 hp under the available head and would be connected, through a speed increaser, to a horizontal generator with a rated output of 65 kW.

Figure C-23B



STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES

MORTALE WATER CONSERVATION DISTRICT  
PUMPING PLANT LOWER  
65KW POWER PLANT  
POWERHOUSE - PLAN AND SECTIONS

NOTE:  
DIMENSIONS IN BRACKETS

EL. 850  
EL. 840  
EL. 830  
EL. 820

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$204,300, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build it, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent annual inflation, is \$346,500 (Table C-23B).

Table C-23B. Project Cost of Pumping Plant Lower Plant

| Cost Item                                     | Amount    |
|---|-----------|
| Direct Cost                                   |           |
| Hydroelectric Plant Facilities                | \$145,000 |
| Transmission Facilities                       | 7,000     |
| Subtotal                                      | \$152,000 |
| Contingencies (20%)                           | 30,400    |
| Total   | \$182,400 |
| Engineering and Administration (12%)          | 21,900    |
| Total Construction Cost (January 1980 prices) | \$204,300 |
| Escalation (4 yrs. at 12% per year)           | 117,200   |
| Total Construction Cost (January 1984 prices) | \$321,500 |
| Studies, Licensing, Permits, and Approvals    | 25,000    |
| Total   | \$346,500 |
| Cost per kW (65 kW)                           | \$ 5,331  |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-23C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-23C. Annual Operating Cost of Pumping Plant Lower Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 8,500     |
| Interim Replacements      | 1,000     |
| Total                     | \$ 22,500 |

The annual cost of owning and operating the project would range between 17 and 24 percent of the direct project cost of \$346,500, depending on financing. The estimated cost of generation ranges between 34.4 and 48.9 cents per kWh (Table C-23D).




Table C-23D. Average Energy Cost of Pumping Plant Lower Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$ 43,300     | \$ 55,400 | \$ 61,700 |
| Operating Cost            | 22,500        | 22,500    | 22,500    |
| Total Annual Cost         | \$ 65,800     | \$ 77,900 | \$ 84,200 |
| Average Cost (per kWh)    | 38.3¢         | 45.3¢     | 48.9¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$ 36,700     | \$ 49,900 | \$ 56,100 |
| Operating Cost            | 22,500        | 22,500    | 22,500    |
| Total Annual Cost         | \$ 59,200     | \$ 72,400 | \$ 78,600 |
| Average Cost (per kWh)    | 34.4¢         | 42.1¢     | 45.7¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE at its published price for small hydroelectric facilities of 100 kW or less. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh, using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of Pumping Plant Lower generation is considerably less than the estimated cost of generation (34.4 to 48.9 cents per kWh), the project if constructed by 1984 would probably not be cost effective until 1995. This is based on the projected energy rates shown in Table 8, Chapter II.

Figure C-24A Rocky Point Diversion Dam Powerplant



## 24. Rocky Point Diversion Dam

Rocky Point Dam is a diversion structure on the Kern River in Bakersfield in Kern County (Fig. C-24A). It is owned and operated by the City of Bakersfield, Kern Delta Water District, and North Kern Water District. The dam diverts water into a canal paralleling the south side of the Kern River. The site is characterized by a low head and relatively large flows during the summer months.

Site Characteristics. The dam is a wood timber structure about 120 m (394 ft) long and 4.5 m (14.8 ft) high. Timber was used for construction because of the sandy stream bed. A 13 kV transmission line is located near the site.

Potential Generation. The potential generation capacity of the facility would be about 300 kW; the estimated average annual output is about 663 000 kWh (Table 24A).


Table 24A. Energy Generation of Rocky Point Diversion Project

| Month        | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|--------------|------|------|-------|-------|----------------|---------------|-----------------|
|              | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January      | 3    | 10   | 6.3   | 221   | 61             | 114           | 85 000          |
| February     | 3    | 10   | 1.4   | 48    | --             | --            | --              |
| March        | 3    | 10   | --    | --    | --             | --            | --              |
| April        | 3    | 10   | --    | --    | --             | --            | --              |
| May          | 3    | 10   | --    | --    | --             | --            | --              |
| June         | 3    | 10   | 8.0   | 284   | 72             | 173           | 125 000         |
| July         | 3    | 10   | 14.2  | 501   | 84             | 300           | 233 000         |
| August       | 3    | 10   | 11.8  | 417   | 84             | 296           | 220 000         |
| September    | 3    | 10   | --    | --    | --             | --            | --              |
| October      | 3    | 10   | --    | --    | --             | --            | --              |
| November     | 3    | 10   | --    | --    | --             | --            | --              |
| December     | 3    | 10   | --    | --    | --             | --            | --              |
| <b>Total</b> |      |      |       |       |                |               | <b>663 000</b>  |

New Power Plant Structures. A hydraulic turbine and electric generator installed near the left abutment of the existing dam could use the 3 m (10 ft) head available at the site. The proposed generating facility would include an intake structure, a short 5.5 m (18 ft) concrete conduit, a turbine/generator, and a short tailrace channel to return the water to the river (Fig. C-24B). The turbine would be a standard, propeller-type with a runner of 1.8 m (6 ft) in diameter; it could develop 403 hp under the available head. The turbine would be connected, through a speed increaser, to a generator with a rated output of 300 kW. An inlet gate installed upstream from the turbine could be used to partially dewater the unit for inspection and maintenance. An outdoors powerhouse would be used.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$759,400, based on January 1980 prices. If the project were initiated in 1981 and about 30 to 36 months were required to complete

Figure C-24B



STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES

CITY OF BAKERSFIELD

ROCKY POINT DIVERSION  
 300kW POWER PLANT

POWERHOUSE - PLAN AND SECTION

NOTE:  
 ENGLISH UNITS IN BRACKETS

the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983 (with 12 percent annual inflation) is \$1,244,900 (Table C-24B).

Table C-24B. Project Cost of Rocky Point Diversion Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 540,000  |
| Transmission Facilities                       | 25,000      |
| Subtotal                                      | \$ 565,000  |
| Contingencies (20%)                           | 113,000     |
| Total   | \$ 678,000  |
| Engineering and Administration (12%)          | 81,400      |
| Total Construction Cost (January 1980 Prices) | \$ 759,400  |
| Escalation (4 yrs. at 12% per year)           | 435,500     |
| Total Construction Cost (January 1984 Prices) | \$1,194,900 |
| Studies, Licensing, Permits, and Approvals    | 50,000      |
| Total   | \$1,244,900 |
| Cost per kW (300 kW)                          | \$ 4,150    |

**Cost of Generation.** The generation cost includes the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-24C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-24C. Annual Cost of Rocky Point Diversion Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 17,000    |
| Interim Replacements      | 2,700     |
| Total                     | \$ 32,700 |

The annual cost of owning and operating the project would range between 13 and 20 percent of the direct project cost of \$1,244,900, depending on financing. The estimated cost of generation ranges between 24.8 cents and 38.4 cents per kWh (Table C-24D).




Table C-24D. Average Energy Cost of Rocky Point Diversion Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$155,600     | \$199,200 | \$221,600 |
| Operating Cost            | 32,700        | 32,700    | 32,700    |
| Total Annual Cost         | \$188,300     | \$231,900 | \$254,300 |
| Average Cost (per kWh)    | 28.4¢         | 35.0¢     | 38.4¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$132,000     | \$179,300 | \$201,700 |
| Operating Cost            | 32,700        | 32,700    | 32,700    |
| Total Annual Cost         | \$164,700     | \$212,000 | \$234,400 |
| Average Cost (per kWh)    | 24.8¢         | 32.0¢     | 35.4¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is also assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. The estimated value of energy generated at Rocky Point Diversion is significantly less than the estimated cost of generation (24.8 to 38.4 cents per kWh). The project if constructed by 1984 would probably not be cost effective until 1991. This is based on the projected energy rates shown in Table 8, Chapter II.

Figure C-25A Stumpy Meadows Powerplant



## 25. Stumpy Meadows Reservoir (Mark Edson Dam)

Stumpy Meadows Reservoir, formed by the Mark Edson Dam on Pilot Creek, is located about 8 km (5 mi) east of Quintette in El Dorado County (Fig. C-25A). The facility is owned and operated by the Georgetown Divide Public Utility District and is used to conserve water for domestic purposes and irrigation.

Site Characteristics. The reservoir capacity is 24 670 cubic dekametres (20,000 ac-ft) at the maximum water surface elevation of 1300 m (4,268 ft). In an average-water year, a constant flow of 0.8 cms (30 cfs) is available for power generation for about 9.5 months.

The dam is an earth structure approximately 50 m (164 ft) high. Controlled releases from the reservoir are made through the dam's lower outlet which is about 232 m (761 ft) long. The lower outlet consists of a concrete conduit, 0.9 m (36 in) in diameter, between the reservoir intake and a valve chamber, a distance of about 136 m (446 ft). Downstream from the valve chamber, for a distance of about 96 m (315 ft) to the control structure, the lower outlet consists of a 0.8 m (2.5 ft) steel pipe located within a horseshoe-shaped concrete tunnel having an inside diameter of 2 m (6.5 ft). A manually operated 0.8 m (2.5 ft) Howell-Bunger valve at the control structure controls discharges into a reinforced-concrete energy dissipater.

The nearest transmission line is a single-phase 35 kV line located about 6.4 km (4 mi) from the site.

Potential Generation. The potential capacity at Stumpy Meadows Reservoir would be 325 kW, and the estimated average annual output is 2.2 million kWh (Table C-25A).

Table C-25A. Energy Generation of Stumpy Meadows Project

| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 45.7 | 150  | 0.9   | 30    | 85             | 323           | 120 000         |
| February  | 46.0 | 151  | 0.9   | 30    | 85             | 325           | 218 000         |
| March     | 46.9 | 154  | 0.9   | 30    | 85             | 331           | 246 000         |
| April     | 46.9 | 154  | 0.9   | 30    | 85             | 331           | 238 000         |
| May       | 46.9 | 154  | 0.9   | 30    | 85             | 331           | 246 000         |
| June      | 46.0 | 151  | 0.9   | 30    | 85             | 325           | 234 000         |
| July      | 44.2 | 145  | 0.9   | 30    | 85             | 312           | 232 000         |
| August    | 42.0 | 138  | 0.9   | 30    | 85             | 297           | 221 000         |
| September | 40.2 | 132  | 0.9   | 30    | 85             | 284           | 204 000         |
| October   | 38.7 | 127  | 0.9   | 30    | 85             | 273           | 203 000         |
| November  | 39.6 | 130  | --    | --    | --             | --            | --              |
| December  | 40.8 | 134  | --    | --    | --             | --            | --              |
| Total     |      |      |       |       |                |               | 2 160 000       |

New Power Plant Structures. A turbine and generator installed at the downstream end of the existing lower outlet pipe could use the 38.7 m to 46 m (127 ft to 151 ft) available head at the site. The proposed generating facility includes a 0.8 m (2.5 ft) steel pipe by-pass starting about 5 m (16.5 ft) upstream from the existing outlet structure which carries water to a horizontal Francis turbine (Figs. C-25B and C-25C). The turbine could develop 437 hp under a 46 m (151 ft) head and would be connected directly to an air-cooled, synchronous generator with a rated output of 325 kW. The operation of the hydroelectric plant would be separated from that of the existing installation by a butterfly valve installed upstream from the turbine.


Cost of the New Power Plant. The estimated cost of building the new generating facility is \$897,200, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with a 12 percent annual inflation, is \$1,511,800 (Table C-25B).

Table C-25B. Project Cost of Stumpy Meadows Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 417,600  |
| Transmission Facilities                       | 250,000     |
| Subtotal                                      | \$ 667,600  |
| Contingencies (20%)                           | 133,500     |
| Total   | \$ 801,100  |
| Engineering and Administration (12%)          | 96,100      |
| Total Construction Cost (January 1980 prices) | \$ 897,200  |
| Escalation (4 yrs. at 12% per year)           | 514,600     |
| Total Construction Cost (January 1984 prices) | \$1,411,800 |
| Studies, Licensing, Permits, and Approvals    | 100,000     |
| Total   | \$1,511,800 |
| Cost per kW (325 kW)                          | \$ 4,652    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-25C). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Figure C-25B







STATE OF CALIFORNIA  
THE GOVERNMENT  
DEPARTMENT OF WATER RESOURCES


GEORGETOWN DIVISION PUBLIC UTILITY DISTRICT

**STUMPY MEADOWS  
325 KW POWER PLANT**

GENERAL PLAN



NEW POWERHOUSE PLAN



SECTION B-B

STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES

SECRETOWAN DIVIDE PUBLIC UTILITY DISTRICT  
**STUMPY MEADOWS  
 325 KW POWER PLANT**  
 POWERHOUSE PLAN AND SECTIONS

NOTE:  
 ENGLISH UNITS IN BRACKETS

Table C-25C. Annual Operating Cost of Stumpy Meadows Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 13,000 |
| Insurance                 | 8,500     |
| Interim Replacements      | 2,400     |
| Total                     | \$ 23,900 |

The annual cost of owning and operating the project would range between 12 and 19 percent of the direct project cost of \$1,511,800, depending on financing. The estimated cost of generation ranges between 8.5 cents and 13.6 cents per kWh (Table C-25D).

Table C-25D. Average Energy Cost of Stumpy Meadows Project

| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$189,000     | \$241,900 | \$269,100 |
| Operating Cost            | 23,900        | 23,900    | 23,900    |
| Total Annual Cost         | \$212,900     | \$265,800 | \$293,000 |
| Average Cost (per kWh)    | 9.9¢          | 12.3¢     | 13.6¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$160,300     | \$217,700 | \$244,900 |
| Operating Cost            | 23,900        | 23,900    | 23,900    |
| Total Annual Cost         | \$184,200     | \$241,600 | \$268,800 |
| Average Cost (per kWh)    | 8.5¢          | 11.2¢     | 12.4¢     |


Value of Generation. It is assumed that project generation would be sold to PGandE under Section 210 of PURPA. It is further assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.

Conclusions. Since the estimated minimum value of Stumpy Meadows generation is within the range of estimated cost of generation (8.5 to



13.6 cents per kWh), the project would probably be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The cost of Stumpy Meadows generation would change little from year to year since only the maintenance cost of the facility is subject to inflation.

Figure C-26A Uvas Dam Powerplant



## 26. Uvas Dam

Uvas Dam, owned and operated by the South Santa Clara Valley Water Conservation District, is located about 10 km (6 mi) northwest of Gilroy in Santa Clara County (Fig. C-26A). The dam and reservoir are used for water conservation. Water released during the irrigation season percolates into the ground water basin from where it is pumped through wells and used for irrigation.

Site Characteristics. The Dam is an earth structure about 47 m (155 ft) high with a crest about 314 m (1030 ft) long. Controlled releases are made from the reservoir through the dam's lower outlet, which is about 158 m (518 ft) long and consists of a 0.9 m (3 ft) diameter steel pipe encased in a concrete jacket. The control valve, a 0.8 m (2.5 ft) butterfly valve, is in an outlet control house.

A short distance upstream from the butterfly valve, a T-connection to a 0.9 m (3 ft) pipe with a gate valve diverts water via a 6.4 km (4 mi) concrete pipeline to Uvas Creek. A 13 kV transmission line is located about 152 m (500 ft) from the site.

Potential Generation. A horizontal Francis turbine installed at Uvas Dam could use water that is presently discharged into Uvas Creek. The potential installed capacity would be 300 kW, and the estimated average annual output is 1 million kWh (Table C-26A).

Table C-26A. Energy Generation of Uvas Dam Project

| Month        | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr)  |
|--------------|------|------|-------|-------|----------------|---------------|------------------|
|              | (m)  | (ft) | (cms) | (cfs) |                |               |                  |
| January      | 17.7 | 58   | 1.7   | 59    | 84             | 243           | 181 000          |
| February     | 23.2 | 76   | 2.0   | 72    | 84             | 300           | 202 000          |
| March        | 24.7 | 81   | 2.1   | 74    | 84             | 300           | 223 000          |
| April        | 25.0 | 82   | 0.7   | 26    | 66             | 119           | 86 000           |
| May          | 25.0 | 82   | 0.9   | 31    | 79             | 170           | 126 000          |
| June         | 23.2 | 76   | 0.9   | 33    | 79             | 168           | 121 000          |
| July         | 19.8 | 65   | 0.9   | 32    | 79             | 139           | 103 000          |
| August       | 15.2 | 50   | 0.6   | 20    | --             | --            | --               |
| September    | 10.4 | 34   | --    | --    | --             | --            | --               |
| October      | 10.4 | 34   | --    | --    | --             | --            | --               |
| November     | 10.4 | 34   | --    | --    | --             | --            | --               |
| December     | --   | --   | --    | --    | --             | --            | --               |
| <b>Total</b> |      |      |       |       |                |               | <b>1 042 000</b> |

New Power Plant Structures. A turbine and generator installed at the downstream end of the existing lower outlet pipe adjacent to the existing control house could use the 20 m to 26 m (65 ft to 85 ft) available head. The proposed generating facility includes a 0.9 m (3 ft) steel pipe by-pass, installed about 4 m (13 ft) upstream from the existing outlet control house, which carries water to a horizontal Francis turbine (Figs C-26B and C-26C). The turbine could develop 402 hp under a 26 m (85 ft) of head and

Figure C-26B





Figure C-26C



would be connected directly to a horizontal, air-cooled synchronous generator having a rated output of 300 kW.

The operation of the hydroelectric plant and of the existing installation would be kept separate by a butterfly valve installed upstream from the turbine.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$591,100, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work would be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent inflation, is \$980,100 (Table C-26B).

Table C-26B. Project Cost of Uvas Dam Plant

| <u>Cost Item</u>                              | <u>Amount</u> |
|---|---------------|
| Direct Cost                                   |               |
| Hydroelectric plant facilities                | \$ 424,800    |
| Transmission Facilities                       | 15,000        |
| Subtotal                                      | \$ 439,800    |
| Contingencies (20%)                           | 88,000        |
| Total   | \$ 527,800    |
| Engineering and Administration (12%)          | 63,300        |
| Total Construction Cost (January 1980 Prices) | \$ 591,100    |
| Escalation (4 yrs. at 12% per year)           | 339,000       |
| Total Construction Cost (January 1984 Prices) | \$ 930,100    |
| Studies, Licensing, Permits, and Approvals    | 50,000        |
| Total   | \$ 980,100    |
| Cost per kW (300 kW)                          | \$ 3,267      |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-26C). Regular maintenance could be scheduled during the autumn months when there is insufficient water for power generation.

Table C-26C. Annual Operating Cost of Uvas Dam Project

| Cost Item                 | Amount           |
|---------------------------|------------------|
| Operation and Maintenance | \$ 13,000        |
| Insurance                 | 17,000           |
| Interim Replacements      | 2,700            |
| <b>Total</b>              | <b>\$ 32,700</b> |

The annual cost of owning and operating the project would range between 14 and 21 percent of the direct project cost of \$980,100, depending on financing. The estimated cost of generation ranges between 13.1 cents and 19.9 cents per kWh (Table C-26D).

Table C-26D. Average Energy Cost of Uvas Dam Project


| Cost Item                 | Amount        |           |           |
|---------------------------|---------------|-----------|-----------|
|                           | Interest Rate |           |           |
|                           | 9%            | 12%       | 15%       |
| For 20-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%     | 17.8%     |
| Fixed Annual Cost         | \$122,500     | \$156,800 | \$174,500 |
| Operating Cost            | 32,700        | 32,700    | 32,700    |
| Total Annual Cost         | \$155,200     | \$189,500 | \$207,200 |
| Average Cost (per kWh)    | 14.9¢         | 18.2¢     | 19.9¢     |
| For 35-year term of debt: |               |           |           |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%     | 16.2%     |
| Fixed Annual Cost         | \$103,900     | \$141,100 | \$158,800 |
| Operating Cost            | 32,700        | 32,700    | 32,700    |
| Total Annual Cost         | \$136,600     | \$173,800 | \$191,500 |
| Average Cost (per kWh)    | 13.1¢         | 16.7¢     | 18.4¢     |

Value of Generation. It is assumed that the energy produced would be sold to PGandE under Section 210 of PURPA. It is further assumed, for the purpose of this study, that the project would have no capacity value pending the development of PGandE's proposed policy for the purchase of small hydroelectric generation and the outcome of a theoretical study of water and power operations acceptable to PGandE. On this basis, the estimated value of project generation in 1984 is 11.1 cents per kWh using the CEC median oil-cost projection as the basis for estimating the future cost of electrical energy.



Conclusions. The estimated value of Uvas Dam generation is less than the estimated generation cost (13.1 to 19.9 cents per kWh). The project costs would exceed revenues from sales the energy produced during the first year of operation. However, as the price of oil increases, the project would become cost effective in later years since only the cost of maintaining the facility is subject to inflation.

Figure C-27A Vail Heading Powerplant



## 27. Vail Heading

Vail Heading is a series of low check structures closely spaced in staircase fashion along the Vail Supply Canal and located about 6 miles east of Calipatria in Imperial County (Fig. C-27A). The canal is owned and operated by the Imperial Irrigation District and receives water from a turnout on the District's East Highline Canal.

Site Characteristics. The Vail Heading consists of eleven check structures that drop the flow 13.7 m (45 ft). The largest drops occur in the first 0.8 km (0.5 mi) at the rate of about 4.9 m (16 ft) per 305 m (1000 ft) of canal length.

Potential Generation. The potential installed capacity would be 225 kW, and the estimated average annual output is 1 million kWh (Table C-27A).

Table C-27A. Energy Generation of Vail Heading Project





| Month     | Head |      | Flow  |       | Efficiency (%) | Capacity (kW) | Energy (kWh/yr) |
|-----------|------|------|-------|-------|----------------|---------------|-----------------|
|           | (m)  | (ft) | (cms) | (cfs) |                |               |                 |
| January   | 4.9  | 16   | 1.0   | 34    | --             | --            | --              |
| February  | 4.9  | 16   | 3.2   | 113   | --             | --            | --              |
| March     | 4.9  | 16   | 4.7   | 166   | 80             | 180           | 134 000         |
| April     | 4.9  | 16   | 5.4   | 192   | 84             | 218           | 157 000         |
| May       | 4.9  | 16   | 4.5   | 160   | 79             | 171           | 127 000         |
| June      | 4.9  | 16   | 4.6   | 164   | 80             | 178           | 128 000         |
| July      | 4.9  | 16   | 5.6   | 198   | 84             | 225           | 168 000         |
| August    | 4.9  | 16   | 5.7   | 201   | 84             | 229           | 170 000         |
| September | 4.9  | 16   | 4.9   | 174   | 83             | 195           | 141 000         |
| October   | 4.9  | 16   | 2.9   | 103   | --             | --            | --              |
| November  | 4.9  | 16   | 2.4   | 84    | --             | --            | --              |
| December  | 4.9  | 16   | 1.3   | 45    | --             | --            | --              |
| Total     |      |      |       |       |                |               | 1 025 000       |

New Power Plant Structures. A turbine and generator could be installed at the first 4.9 m (16 ft) drop thereby using the shortest distance to develop the available head. The proposed generating facility includes an intake structure to divert water from the canal into a penstock which would then carry the water 450 m (1476 ft) to a hydraulic turbine (Fig. C-27B). The water would be returned to the canal through a short tailrace channel. The turbine could develop 335 hp under a 4.9 m (16 ft) head and would be connected, through a speed increaser, to a horizontal generator with a rated output of 225 kW. A 13 kV transmission line, owned and operated by the District, is located at the site.

Cost of the New Power Plant. The estimated cost of the new generating facility is \$850,100, based on January 1980 prices. About 24 to 36 months would be required for completing the feasibility study, obtaining approvals, and building. Since the generating facility would be located on an existing manmade conduit that is now operated primarily for purposes other than power generation, the Vail Heading site would probably be exempt from

Figure C-27B

STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES  
 IMPERIAL VALLEY IRRIGATION DISTRICT  
 VAIL HEADING  
 225 MW POWER PLANT  
 POWERHOUSE — PLAN AND SECTION



NOTE:  
 DIMENSION UNITS IN BRACKETS

federal licensing requirements. (The exemption provision is discussed in Appendix F.) However, the District would have to comply with the CEQA process and determine if other state approvals are necessary.

If the project were initiated in 1981, construction could be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent inflation, is \$1,387,600 (Table C-27B).

Table C-27B. Project Cost of Vail Heading Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 620,000  |
| Transmission Facilities                       | 12,500      |
| Subtotal                                      | \$ 632,500  |
| Contingencies (20%)                           | 126,500     |
| Total   | \$ 759,000  |
| Engineering and Administration (12%)          | 91,100      |
| Total Construction Cost (January 1980 Prices) | \$ 850,100  |
| Escalation (4 yrs. at 12% per year)           | 487,500     |
| Total Construction Cost (January 1984 Prices) | \$1,337,600 |
| Studies, Licensing, Permits, and Approvals    | 50,000      |
| Total   | \$1,387,600 |
| Cost per kW (225 kW)                          | \$ 6,167    |

Cost of Generation. Since this facility and the electric transmission and distribution system are owned and operated by the Imperial Irrigation District, it is assumed that the District would develop and use the power in its own electric system. The annual cost of owning and operating the project would include the debt repayment, operation and maintenance, insurance, replacements, administration, and overhead.

It is assumed that the District would finance construction by issuing tax-exempt revenue bonds, and that the bonds could be issued for a 35-year term at 9 percent interest. The actual interest rate would depend on financial conditions when the bonds were issued.

It is expected that the initial development would be financed from electric system revenues or short-term loans, and that the bonds would not be issued until about 12 months before the project is completed. The additional cost of operating the plant would be insignificant, since the District already has a full staff of operating personnel. Regular maintenance could be scheduled during the nonirrigation season when there would be no water for power generation.

The estimated average generation cost, assuming 35-year bonds, is \$182,400 or 17.8 cents per kWh (Table C-27C). With 20-year bonds, the estimated average generation cost increases to 20.6 cents per kWh.

Table C-27C. Annual Cost of Vail Heading Project

| Cost Item                       | Amount             |                    |
|---------------------------------|--------------------|--------------------|
|                                 | 20-year<br>Bonds   | 35-year<br>Bonds   |
| Studies, Approvals, etc.        | \$ 50,000          | \$ 50,000          |
| Construction Cost               | 1,387,600          | 1,387,600          |
| Capitalized Interest            | 128,800            | 128,800            |
| Interest Earnings               | (62,400)           | (62,400)           |
| <b>Total Capital Cost</b>       | <b>\$1,504,000</b> | <b>\$1,504,000</b> |
| Bond Reserve Fund               | 186,300            | 163,200            |
| Financing Costs                 | 63,900             | 61,900             |
| <b>Bond Issue</b>               | <b>\$1,754,200</b> | <b>\$1,729,100</b> |
| Debt Service (9% interest)      | \$192,200          | \$ 163,600         |
| Operation and Maintenance       | 13,000             | 13,000             |
| Insurance                       | 17,000             | 17,000             |
| Interim Replacements            | 3,500              | 3,500              |
| Interest Earnings               | (14,700)           | (14,700)           |
| <b>Total Annual cost</b>        | <b>\$ 211,000</b>  | <b>\$ 182,400</b>  |
| Annual Cost (% of Project Cost) | 15.2               | 13.1               |
| Average Cost (per kWh)          | 20.6¢              | 17.8¢              |

Since the District has experience with small hydroelectric facilities, it might elect to be self-insured--in full or in part--to reduce the annual insurance premium on mechanical and electrical equipment. This would substantially reduce its annual generation cost.

Value of Generation. Since the District would probably use the energy produced in its own electric system, the average estimated avoided cost is about 4.5 cents per kWh, at 1980 price levels. This was discussed in the study of the "No. 8 Heading" site which is also owned by the District. The projected value of energy is discussed in Appendix G, and the estimates of partial-peak energy are assumed to be applicable to the Vail Heading output. The assumed value for capacity is \$100 per kW per year.


Based on this, the estimated value of Vail Heading generation in 1984 is \$120,300 or 11.7¢ per kWh (Table C-27D).

Table C-27D. Generation Value of Vail Heading Project

| Item                         | Amount    |
|------------------------------|-----------|
| Capacity (June Capacity)     |           |
| 178 kW at \$100 per kW       | \$ 17,800 |
| Energy                       |           |
| 1 025 000 kWh at 10¢ per kWh | 102,500   |
| Total                        | \$120,300 |
| Average Value (per kWh)      | 11.7¢     |

Conclusions. Since the estimated value of Vail Heading generation in 1984 is less than the estimated cost of generation (17.8 to 20.6 cents per kWh), the project would not be cost effective during its first year of operation. With the projected increases in the price of oil, the project would be marginally cost effective after the third or fourth year of operation.

Figure C-28A West Coast Basin Barrier Powerplant



## 28. West Coast Basin Barrier

The West Coast Basin Barrier facility is a pressure-reducing vault owned and operated by the Los Angeles County Flood Control District. It is located under El Segundo Boulevard near Los Angeles International Airport (Fig. C-28A). The facility is part of the West Coast Basin Barrier Project to counteract seawater intrusion into the groundwater basin by injecting fresh water into wells along the coast line from the airport to Long Beach.


Site Characteristics. The hydraulic facility consists of four identical pressure-reducing valves; only two of the valves are in operation at any given time. The valves reduce the pressure of water from the Metropolitan Water District of Southern California distribution system from 1138 kilopascals to 552 kilopascals (165 psi to 80 psi) before injection into the wells. The physical dimensions of the vault were sized for the four valves with extra space allowed only for the maintenance, removal, and installation of equipment. The power distribution line is located adjacent to the site.

Potential Generation. The average flow is 1.1 cms (40 cfs) for 24 hours a day, 365 days a year. The potential capacity would be 500 kW, and the estimated annual output is about 4.2 million kWh, allowing 4 percent outage time for routine maintenance.

New Power Plant Structures. Turbines and generators installed at the facility could use the 56.4 m (185 ft) available head. The proposed generating facility includes a 5 m (16 ft) extension of the existing vault to accommodate two horizontal, modified pump-type turbines, each capable of developing 335 hp under the available head (Fig. C-28B). The turbines would be connected directly to horizontal generators having a rated output of 250 kW each. The operations of the hydroelectric plant and the existing system would be kept separate by two butterfly valves installed upstream and downstream from each turbine.

Cost of the New Power Plant. The estimated cost of building the new generating facility is \$689,500, based on January 1980 prices. If the project were initiated in 1981, and about 30 to 36 months were required to complete the feasibility study, obtain approvals, arrange financing, design, and build the project, the work should be completed in late 1983 for operation in 1984. The estimated project cost in late 1983, with 12 percent inflation, is \$1,134,900 (Table C-28A).

Figure C-28B



STATE OF CALIFORNIA  
 THE RESOURCES AGENCY  
 DEPARTMENT OF WATER RESOURCES  
 LOS ANGELES COUNTY FLOOD CONTROL DISTRICT  
 WEST COAST BASIN BARRIER  
 500kW POWER PLANT  
 POWERHOUSE - PLAN AND SECTION

NOTE:  
 DIMENSION UNITS IN BRACKETS

Table C-28A. Project Cost of West Coast Basin Barrier Plant

| Cost Item                                     | Amount      |
|---|-------------|
| Direct Cost                                   |             |
| Hydroelectric Plant Facilities                | \$ 488,000  |
| Transmission Facilities                       | 25,000      |
| Subtotal                                      | \$ 513,000  |
| Contingencies (20%)                           | 102,600     |
| Total   | \$ 615,600  |
| Engineering and Administration (12%)          | 73,900      |
| Total Construction Cost (January 1980 Prices) | \$ 689,500  |
| Escalation (4 yrs. at 12% per year)           | 395,400     |
| Total Construction Cost (January 1984 Prices) | \$1,084,900 |
| Studies, Licensing, Permits, and Approvals    | 50,000      |
| Total   | \$1,134,900 |
| Cost per kW (500 kW)                          | \$ 2,270    |

Cost of Generation. The generation cost would include the fixed annual cost of financing construction, the cost of labor and materials for operation and maintenance, insurance, and replacements (Table C-28B). Regular maintenance could be scheduled during the winter months when there is insufficient water for power generation.

Table C-28B. Annual Operating Cost of West Coast Basin Barrier Project

| Cost Item                 | Amount    |
|---------------------------|-----------|
| Operation and Maintenance | \$ 30,600 |
| Insurance                 | 17,000    |
| Interim Replacements      | 3,000     |
| Total                     | \$ 50,600 |

The annual cost of owning and operating the project would range between 15 and 22 percent of the direct project cost of \$1,134,900, depending on financing. The estimated cost of generation ranges between 4.1 cents and 6.0 cents per kWh (Table C-28C).

Table C-28C. Average Energy Cost of West Coast Basin Barrier Project

| Cost Item                 | Amount        |            |            |
|---------------------------|---------------|------------|------------|
|                           | Interest Rate |            |            |
|                           | 9%            | 12%        | 15%        |
| For 20-year term of debt: |               |            |            |
| Fixed Annual Cost Rate    | 12.5%         | 16.0%      | 17.8%      |
| Fixed Annual Cost         | \$ 141,900    | \$ 181,600 | \$ 202,000 |
| Operating Cost            | 50,600        | 50,600     | 50,600     |
| Total Annual Cost         | \$ 192,500    | \$ 232,200 | \$ 252,600 |
| Average Cost (per kWh)    | 4.6¢          | 5.5¢       | 6.0¢       |
| For 35-year term of debt: |               |            |            |
| Fixed Annual Cost Rate    | 10.6%         | 14.4%      | 16.2%      |
| Fixed Annual Cost         | \$ 120,300    | \$ 163,400 | \$ 183,900 |
| Operating Cost            | 50,600        | 50,600     | 50,600     |
| Total Annual Cost         | \$ 170,900    | \$ 214,000 | \$ 234,500 |
| Average Cost (per kWh)    | 4.1¢          | 5.1¢       | 5.6¢       |

Value of Generation. It is assumed that project generation would be sold to SCE under Section 210 of PURPA and that the value of generation would be determined by the SCE policy on the purchase of capacity and energy from small power facilities. The West Coast Basin Barrier site would have a capacity value since generation would be available at about a 96 percent capacity factor. On this basis, the estimated value of project generation in 1984 is 10.9 cents per kWh using the CEC median oil-cost projection for estimating the future cost of electrical energy.

Conclusions. Since the estimated value of West Coast Basin Barrier generation exceeds the estimated cost of generation (4.1 to 6.0 cents per kWh), the project would be cost effective during its first year of operation. Additional benefits would accrue during subsequent years as the price of oil increases. The generation cost would change little from year to year, since only the maintenance cost of the facility is subject to inflation.

APPENDIX D

Feasibility Studies for 42 Facilities, Prepared by Others



## APPENDIX D

### Summary of Feasibility Studies Prepared by Others

The Department did not conduct preliminary studies on sites where feasibility studies were either in progress or had already been completed by others. Copies of 42 such studies were obtained and evaluated. These included several earlier appraisal-level studies prepared by the Department on the State Water Project's facilities. The 42 studies varied in scope from simple preliminary investigations to full-fledged feasibility studies. Since they were conducted by several different engineering firms and site owners, there was no common basis among them, and they had to be evaluated individually to confirm or deny their feasibility. In addition, a 7 percent interest rate was usually used to determine annual cost; this is no longer valid and a much higher cost of raising capital must be used for an accurate economic comparison of projects.

To estimate the economic suitability of the 42 sites, project costs were taken from each of the reports and escalated for inflation to estimate the costs expected for 1984. Project costs include all direct costs such as studies, licensing, permits and approvals, and construction, but do not include financing cost or indirect cost of interest during construction; these are included in the fixed annual cost of owning and operating the project. Annual costs were determined using the fixed annual cost rates obtained in the Department's studies of the 28 representative sites. The computation of fixed annual cost is described in detail in Appendix H.

To determine the cost effectiveness of each proposed facility, the annual cost of energy generation was compared to the price utilities will pay for hydroelectric power based on the avoided cost required by PURPA. An interest rate of 9 percent and a 35-year debt were used for this comparison. Table 8 in Chapter II, shows the estimated rates Pacific Gas and Electric Company, Southern California Edison Company, and San Diego Gas and Electric Company, will pay for electric generation through the year 2000.

The estimated 1984 project costs for each facility are presented below with a brief summary of the specific characteristics of each site. This information is summarized in Table D.

Table D. Summary of 42 Feasibility Studies Prepared by Others

| Facility                | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | Project Cost<br>(\$/kW)<br>(Year) | 1984                       |                                      | 1984                       |                                      |      |      |
|-------------------------|------------------|--------------------|---------------------------|-----------------------------------|----------------------------|--------------------------------------|----------------------------|--------------------------------------|------|------|
|                         |                  |                    |                           |                                   | Project<br>Cost<br>(\$/kW) | Annual<br>Cost Rate<br>(%)<br>(High) | Project<br>Cost<br>(\$/kW) | Annual<br>Cost Rate<br>(%)<br>(High) |      |      |
| 1. Anderson Lake        | 500              | 2.2                | 50                        | 1,322                             | 1978                       | 2,610                                | 13.5                       | 20.5                                 | 8.0  | 12.2 |
| 2. Antelope Dam         | 450              | 1.4                | 35                        | 2,784                             | 1978                       | 5,200                                | 13.5                       | 20.5                                 | 22.8 | 34.6 |
| 3. Bowman Dam           | 3 000            | 14.7               | 56                        | 610                               | 1979                       | 1,080                                | 12.5                       | 19.5                                 | 2.7  | 4.3  |
| 4. Canal Creek          | 940              | 3.3                | 40                        | 1,227                             | 1982                       | 1,540                                | 13.0                       | 20.0                                 | 5.7  | 8.8  |
| 5. Castaic Dam          | 275              | 1.4                | 58                        | 2,156                             | 1978                       | 4,030                                | 13.5                       | 20.5                                 | 10.7 | 16.2 |
| 6. Combie Dam           | 525              | 2.9                | 63                        | 1,737                             | 1979                       | 3,060                                | 13.5                       | 20.5                                 | 7.5  | 11.3 |
| 7. Coyote Dam           | 600              | 1.3                | 24                        | 1,006                             | 1978                       | 1,990                                | 13.5                       | 20.5                                 | 12.4 | 18.9 |
| 8. Del Valle Dam        | 400              | 1.1                | 31                        | 1,848                             | 1978                       | 3,450                                | 13.5                       | 20.5                                 | 16.9 | 25.7 |
| 9. Escaladian Headworks | 270              | 0.8                | 34                        | 1,494                             | 1982                       | 1,870                                | 13.5                       | 20.5                                 | 8.3  | 12.6 |
| 10. Fairfield Drop      | 970              | 2.8                | 33                        | 1,104                             | 1982                       | 1,380                                | 13.0                       | 20.5                                 | 6.3  | 9.8  |
| 11. Frankenhimer Drop   | 4 700            | 17.0               | 41                        | 1,056                             | 1982                       | 1,320                                | 12.0                       | 19.0                                 | 4.4  | 7.0  |
| 12. Goodwin Dam         | 970              | 4.7                | 55                        | 1,363                             | 1982                       | 1,710                                | 13.0                       | 20.0                                 | 4.6  | 7.1  |
| 13. Jackson Meadows Dam | 4 000            | 8.9                | 25                        | 572                               | 1979                       | 1,010                                | 12.0                       | 19.0                                 | 5.4  | 8.6  |
| 14. Lake Berryessa      | 16 000           | 43.0               | 30                        | 330                               | 1975                       | 920                                  | 12.0                       | 19.0                                 | 4.1  | 6.5  |
| 15. Lake Davis          | 510              | 1.5                | 33                        | 1,807                             | 1978                       | 3,380                                | 13.5                       | 20.5                                 | 15.5 | 23.6 |
| 16. Lake Redding        | 14 500           | 79.0               | 62                        | 2,510                             | 1979                       | 4,390                                | 12.0                       | 19.0                                 | 9.7  | 15.3 |
| 17. Las Flores Turnout  | 210              | 0.7                | 38                        | 2,541                             | 1978                       | 4,750                                | 14.0                       | 21.0                                 | 20.0 | 29.9 |
| 18. Lytle Creek Turnout | 1 300            | 7.8                | 68                        | 1,079                             | 1978                       | 2,130                                | 13.0                       | 20.0                                 | 4.6  | 7.1  |
| 19. Madera Canal 980+65 | 2 000            | 5.5                | 31                        | 535                               | 1980                       | 840                                  | 12.5                       | 19.5                                 | 3.8  | 6.0  |
| 20. Millerton Lake      |                  |                    |                           |                                   |                            |                                      |                            |                                      |      |      |
| (a) Friant-Kern Canal   | 15 000           | 90.3               | 69                        | 670                               | 1975                       | 1,860                                | 12.0                       | 19.0                                 | 3.7  | 5.8  |
| (b) Madera Canal        | 5 000            | 30.6               | 70                        | 740                               | 1975                       | 2,050                                | 12.0                       | 19.0                                 | 4.0  | 6.4  |
| (c) San Joaquin River   | 2 700            | 9.9                | 42                        | 630                               | 1975                       | 1,750                                | 12.5                       | 19.5                                 | 5.9  | 10.1 |

1/ Annual cost as percentage of project cost, using Figure 9 in Chapter III.

Table D. Summary of 42 Feasibility Studies Prepared by Others (Continued)

| Facility                             | Capacity<br>(kw) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | Project Cost<br>(\$/kW) (Year) | 1984                    |                         | 1984                    |                 |      |      |
|--------------------------------------|------------------|--------------------|---------------------------|--------------------------------|-------------------------|-------------------------|-------------------------|-----------------|------|------|
|                                      |                  |                    |                           |                                | Project Cost<br>(\$/kW) | Annual<br>Cost Rate (%) | Energy Cost<br>(\$/kWh) | (High)<br>(Low) |      |      |
| 21. Modesto Reservoir                | 1 000            | 3.4                | 39                        | 1,425                          | 1979                    | 2,510                   | 13.0                    | 20.0            | 9.6  | 14.8 |
| 22. Mojave Siphon No. 1              | 6 000            | 47.0               | 89                        | 2,868                          | 1981                    | 4,030                   | 12.0                    | 19.0            | 6.2  | 9.8  |
| 23. Palermo Canal                    | 400              | 1.5                | 43                        | 2,863                          | 1981                    | 4,020                   | 13.5                    | 20.5            | 14.5 | 22.0 |
| 24. Paradise Dam                     | 300              | 1.2                | 46                        | 2,007                          | 1980                    | 3,160                   | 13.5                    | 20.5            | 10.7 | 16.1 |
| 25. Pyramid Dam                      | 1 000            | 3.2                | 37                        | 1,568                          | 1981                    | 2,200                   | 13.0                    | 20.0            | 9.0  | 13.8 |
| 26. Richard B. Parker                | 2 800            | 9.2                | 37                        | 1,113                          | 1982                    | 1,400                   | 12.5                    | 19.5            | 5.4  | 8.3  |
| 27. San Antonio Dam                  | 6 000            | 25.6               | 49                        | 2,126                          | 1978                    | 4,200                   | 12.0                    | 19.0            | 11.8 | 18.7 |
| 28. Santa Ana Low Turnout            | 1 400            | 3.8                | 31                        | 840                            | 1978                    | 1,660                   | 13.0                    | 20.0            | 8.0  | 12.2 |
| 29. Sly Creek Dam                    | 13 200           | 48.2               | 42                        | 773                            | 1979                    | 1,360                   | 12.0                    | 19.0            | 4.5  | 7.1  |
| 30. Stampede Dam                     | 3 000            | 16.0               | 61                        | 657                            | 1975                    | 1,820                   | 12.5                    | 19.5            | 4.3  | 6.7  |
| 31. Stone Drop                       | 1 000            | 4.0                | 46                        | 1,358                          | 1979                    | 2,390                   | 13.0                    | 20.0            | 9.6  | 12.0 |
| 32. Sweetwater Turnout               | 875              | 2.2                | 29                        | 934                            | 1978                    | 1,840                   | 13.0                    | 20.0            | 9.5  | 14.6 |
| 33. Thermalito Afterbay              | 13 000           | 42.6               | 37                        | 1,972                          | 1979                    | 3,290                   | 12.0                    | 19.0            | 12.1 | 19.1 |
| 34. Thermalito Diversion             | 3 500            | 23.0               | 75                        | 1,616                          | 1979                    | 2,700                   | 12.5                    | 19.5            | 5.1  | 8.0  |
| 35. Turlock Main Canal<br>Drop No. 1 | 3 260            | 12.2               | 43                        | 930                            | 1982                    | 1,170                   | 12.5                    | 19.5            | 3.9  | 6.1  |
| 36. Turlock Main Canal<br>Drop No. 2 | 660              | 2.1                | 36                        | 1,437                          | 1982                    | 1,800                   | 13.5                    | 20.5            | 7.6  | 11.6 |
| 37. Turlock Main Canal<br>Drop No. 6 | 920              | 2.9                | 36                        | 1,292                          | 1982                    | 1,620                   | 13.0                    | 20.0            | 6.7  | 10.3 |
| 38. Turlock Main Canal<br>Drop No. 7 | 700              | 2.1                | 34                        | 1,408                          | 1982                    | 1,770                   | 13.5                    | 20.5            | 8.0  | 12.1 |

Table D. Summary of 42 Feasibility Studies Prepared by Others (Continued)

| Facility                             | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | Project Cost<br>(\$/kW) (Year) | 1984                       |                              | 1984                         |                                 |                                  |
|--------------------------------------|------------------|--------------------|---------------------------|--------------------------------|----------------------------|------------------------------|------------------------------|---------------------------------|----------------------------------|
|                                      |                  |                    |                           |                                | Project<br>Cost<br>(\$/kW) | Annual<br>Cost Rate<br>(Low) | Annual<br>Rate (%)<br>(High) | Energy Cost<br>(¢/kWh)<br>(Low) | Energy Cost<br>(¢/kWh)<br>(High) |
| 39. Turlock Main Canal<br>Drop No. 9 | 1 070            | 4.7                | 50                        | 1,670 1982                     | 2,090                      | 13.0                         | 20.0                         | 6.2                             | 9.5                              |
| 40. Waterman Canyon Turnot           | 4 000            | 7.0                | 20                        | 551 1978                       | 1,090                      | 12.0                         | 19.0                         | 7.5                             | 11.8                             |
| 41. Whiskeytown Dam                  | 4 000            | 19.5               | 56                        | 528 1975                       | 1,460                      | 12.0                         | 19.0                         | 3.6                             | 5.7                              |
| 42. Woodward Dam                     | 2 300            | 6.9                | 34                        | 968 1982                       | 1,210                      | 12.5                         | 19.5                         | 5.0                             | 8.0                              |

1/ Annual cost as percentage of project cost, using Figure 9 in Chapter III.

## 1. Anderson Lake

Anderson Lake on Coyote Creek in Santa Clara County is owned and operated by the Santa Clara Valley Water District. In the report the "Hydroelectric Power Potential in the Santa Clara Valley," prepared by the Tudor Engineering Company in November 1978, a power plant was considered for installation at this site. It would develop 500 kW of hydroelectric capacity at a design head of 38.1 m (125 ft) and a design flow of 1.4 cms (50 cfs). A new power plant structure to be built would include an Ossberger turbine, a generator, power plant control and monitoring equipment, and a by-pass system. The estimated annual output is 2.2 million kWh.

The estimated cost of the Leroy Anderson power facility is \$661,000, at 1978 price levels. Table D-1 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$2,610 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 8.0 and 12.2 cents per kWh in 1984.

A power plant at Leroy Anderson Reservoir would be cost effective during its first year of operation (1984).

Table D-1  
Anderson Lake Cost Estimate

| Cost Item                                  | Amount     |
|--|------------|
| Project Facilities                         |            |
| Structures and Improvements                | \$ 105,000 |
| Reservoirs, Dams, and Waterways            | 10,000     |
| Turbine and Generator                      | 186,000    |
| Electrical Equipment                       | 78,000     |
| Miscellaneous Equipment                    | 42,000     |
| Subtotal                                   | 421,000    |
| Contingency                                | 105,000    |
| Administration and Management              | 135,000    |
| TOTAL PROJECT COST                         | \$ 661,000 |
| Average Cost per kW: ( $\$661,000/500$ kW) | \$1,322    |

## 2. Antelope Dam

Antelope Dam on Indian Creek in Plumas County is owned and operated by Department of Water Resources. An earlier study by the Department indicated that a power plant installed at this site would develop 450 kW of hydroelectric capacity at a design head of 23 m (75 ft) and a design flow of 2.4 cms (85 cfs). The estimated annual output is 1.4 million kWh.

The estimated cost of the Antelope Dam power facility is \$1,253,000, at 1978 price levels. Table D-2 is a summary of the cost estimate. If construction of the power plant were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$5,200 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 22.8 and 34.6 cents per kWh in 1984.

A power plant at Antelope Dam if operational in 1984, would be cost effective by 1990.

Table D-2  
Antelope Dam Cost Estimate

| Cost Item                                    | Amount      |
|--|-------------|
| Project Facilities                           |             |
| Civil Works                                  | \$ 164,000  |
| Electrical Equipment                         | 119,000     |
| Mechanical Equipment                         | 252,000     |
| Transmission Line                            | 360,000     |
| Subtotal                                     | 895,000     |
| Engineering                                  | 224,000     |
| Contingency                                  | 134,000     |
| TOTAL PROJECT COST                           | \$1,253,000 |
| Average Cost per kW: ( $\$1,253,000/450$ kW) | \$2,784     |

### 3. Bowman Dam

Bowman Dam on Canyon Creek in Nevada County is owned and operated by the Nevada Irrigation District. In a report, "Hydroelectric Power Potential: Nevada Irrigation District," prepared by the Tudor Engineering Company in February 1979, a power plant was considered for installation at this site; it would develop 3 MW of hydroelectric capacity at a design head of 41 m (134 ft) and a design flow of 8.5 cms (300 cfs). A new powerhouse would have to be built to house a vertical Francis turbine and a generator with a rated capacity of 3 MW. The estimated annual project output is 14.7 million kWh.

The estimated cost of the Bowman Dam power facility is \$1,831,000, at 1979 price levels. Table D-3 is a summary of the estimated cost. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,080 per kW.

The estimated annual cost of owning and operating the project would range between 12.5 and 19.0 percent of the project cost depending on financing. The energy cost would range between 2.7 and 4.2 cents per kWh in 1984.

A power plant at Bowman Dam would be cost effective during its first year of operation (1984).

Table D-3  
Bowman Dam Cost Estimate

| Cost Item   | Amount      |
|---|-------------|
| Project Facilities                                |             |
| Structures and Improvements                       | \$ 307,300  |
| Reservoir, Dams, and Waterways                    | 92,700      |
| Turbines and Generators                           | 631,000     |
| Miscellaneous Power Plant Equipment               | 225,000     |
| Subtotal  | 1,256,000   |
| Contingency                                       | 251,000     |
| Administrative, Engineering,<br>Legal, Management | 324,000     |
| TOTAL PROJECT COST                                | \$1,831,000 |
| Average Cost per kW: (\$1,831,000/3000 kW)        | \$610       |

#### 4. Canal Creek

This site is on Canal Creek in Merced County; it is owned and operated by the Merced Irrigation District. In a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant considered for installation at this site would develop 940 kW of hydroelectric capacity at a design head of 10 m (32.3 ft) and a design flow of 11 cms (380 cfs). A new drop structure would have to be built to house a bulb turbine and a generator; penstock and control gate modifications would also be necessary. The estimated annual output is 3.3 million kWh.

The estimated cost for the Canal Creek power facility is \$1,153,152, at 1982 price levels. Table D-4 is a summary of this cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,540 per kW.

The estimated annual cost of owning and operating the project would range between 13.0 and 20.5 percent of the project cost, depending on financing. The energy cost would range from 5.7 and 9.0 cents per kWh in 1984.

A power plant at Canal Creek would be cost effective during its first year of operation (1984).

Table D-4  
Canal Creek Cost Estimate

| Cost Item                                 | Amount      |
|---|-------------|
| Project Facilities                        |             |
| Electrical and Mechanical Equipment       | \$ 611,000  |
| Civil Construction and Installation       | 325,000     |
| Engineering and Management                | 112,320     |
| Subtotal                                  | 1,048,320   |
| Contingency                               | 104,832     |
| TOTAL PROJECT COST                        | \$1,153,152 |
| Average Cost per kW: (\$1,153,152/940 kW) | \$1,227     |

## 5. Castaic Dam (Stream Release)

Castaic Dam, at the confluence of Castaic Creek and Elizabeth Lake Canyon Creek in Los Angeles County, is owned and operated by the Department. An earlier study prepared by the Department indicated that a power plant installed at this site would develop 275 kW of hydroelectric capacity at a design head of 91.4 m (300 ft) and a design flow of 0.4 cms (15 cfs). The estimated annual project output is 1.4 million kWh.

The estimated cost the Castaic Dam power facility is \$593,000, at 1978 price levels. Table D-5 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$4,030 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 10.7 and 16.2 cents per kWh in 1984.

A power plant at Castaic Dam would be cost effective during its first year of operation (1984).

Table D-5  
Castaic Dam Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      |            |
| Civil Works                             | \$ 75,600  |
| Electrical Equipment                    | 120,000    |
| Mechanical Equipment                    | 192,000    |
| Transmission Line                       | 36,000     |
| Subtotal                                | 423,600    |
| Engineering                             | 105,900    |
| Contingency                             | 63,500     |
| TOTAL PROJECT COST                      | \$ 593,000 |
| Average Cost per kW: (\$593,000/275 kW) | \$2,156    |

## 6. Combie Dam

Combie Dam on the Combie North Aqueduct in Nevada County is owned and operated by the Nevada Irrigation District. In a report on the "Hydroelectric Power Potential: Nevada Irrigation District," prepared by the Tudor Engineering Company in February 1979, a power plant was considered for installation at this site; it would develop 525 kW of hydroelectric capacity at a design head of 11 m (35 ft) and a design flow of 6 cms (200 cfs). A new power plant would have to be built adjacent to the canal to house a tube-type turbine and a generator. The estimated annual project output is 2.9 million kWh.

The estimated cost of the Combie Dam power facility (canal installation) is \$912,000, at 1979 price levels. Table D-6 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$3,060 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 7.5 and 11.3 cents per kWh in 1984.

A power plant at Combie Dam would be cost effective during its first year of operation (1984).

Table D-6  
Combie Dam Cost Estimate

| Cost Item   | Amount     |
|---|------------|
| Project Facilities                                |            |
| Structures and Improvements                       | \$ 135,000 |
| Reservoir   | 22,000     |
| Turbines and Generators                           | 289,000    |
| Miscellaneous Power Plant Equipment               | 180,000    |
| Subtotal  | 626,000    |
| Contingency                                       | 125,000    |
| Administration, Engineering, Legal,<br>Management | 161,000    |
| TOTAL PROJECT COST                                | \$ 912,000 |
| Average Cost per kW: (\$912,000/525 kW)           | \$1,737    |

## 7. Coyote Dam

Coyote Dam on Coyote Creek in Santa Clara County is owned and operated by the Santa Clara Valley Water District. In the report, the "Hydroelectric Power Potential in the Santa Clara Valley," prepared by the Tudor Engineering Company in November 1978, a power plant was considered for installation at this site; it would develop 600 kW of hydroelectric capacity at a design head of 30.5 m (100 ft) and a design flow of 2.3 cms (80 cfs). The powerhouse would be located on a new penstock extending from the existing outlet conduit between the toe of the dam and the existing energy dissipation structure. About 0.5 km (0.3 mi) of transmission line will be needed to link the powerhouse with an existing PGandE line. The estimated annual project output is 1.3 million kWh.

The estimated cost of the Coyote Dam power facilities is \$586,700, at 1978 price levels. Table D-7 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,990 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 12.4 and 18.9 cents per kWh in 1984.

A power plant at Coyote Dam would be cost effective during its first year of operation (1984).

Table D-7  
Coyote Dam Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      |            |
| Structures and Improvements             | \$ 126,000 |
| Reservoirs, Dams and Waterways          | 30,000     |
| Turbine and Generator                   | 59,000     |
| Power Plant Equipment                   | 133,500    |
| Poles and Fixtures                      | 15,000     |
| Subtotal                                | 363,500    |
| Contingency                             | 90,900     |
| Administration and Management           | 132,300    |
| TOTAL PROJECT COST                      | \$ 586,700 |
| Average Cost per kW: (\$586,700/600 kW) | \$1,006    |

### 8. Del Valle Dam (Stream Release)

Del Valle Dam on Arroyo Del Valle in Alameda County is owned and operated by the Department. An earlier study prepared by the Department indicated that a power plant installed at this site would develop 400 kW of hydroelectric capacity at a design head of 36.6 m (120 ft) and a design flow of 1.4 cms (50 cfs). The estimated annual output is 1.1 million kWh.

The estimated cost of the Del Valle power facility is \$739,200, at 1978 price levels. Table D-8 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$3,450 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 17.0 and 25.7 cents per kWh in 1984.

A power plant at Del Valle Dam, if operational in 1984, would be cost effective by 1988.

Table D-8  
Del Valle Dam Cost Estimate

| Cost Item                                  | Amount     |
|--|------------|
| Project Facilities                         |            |
| Civil Works                                | \$ 153,000 |
| Electrical Equipment                       | 100,000    |
| Mechanical Equipment                       | 239,000    |
| Transmission Line                          | 36,000     |
| Subtotal                                   | 528,000    |
| Engineering                                | 132,000    |
| Contingency                                | 79,200     |
| TOTAL PROJECT COST                         | \$ 739,200 |
| Average Cost per kW: ( $\$739,200/400$ kW) | \$1,848    |

## 9. Escaladian Headworks

The Escaladian Headworks, a drop structure on the Main Canal in Merced County, is owned and operated by the Merced Irrigation District. In a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant considered for installation at this site would develop 270 kW of hydroelectric capacity at a design head of 4.6 m (15 ft) and a design flow of 6.5 cms (230 cfs). A structure would have to be built to house a tube-type turbine and a generator. The estimated annual output is 822 000 kWh.

The estimated cost of the Escaladian Headworks power facility is \$403,480, at 1982 price levels. Table D-9 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,870 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 8.3 and 12.6 cents per kWh in 1984.

A power plant at Escaladian Headworks would be cost effective during its first year of operation (1984).

Table D-9  
Escaladian Headworks Cost Estimate

| <u>Cost Item</u>                           | <u>Amount</u> |
|--|---------------|
| Project Facilities                         |               |
| Electrical and Mechanical Equipment        | \$ 202,500    |
| Civil Construction and Installation        | 125,000       |
| Engineering and Management                 | 39,300        |
| Subtotal                                   | 366,800       |
| Contingency                                | 36,680        |
| TOTAL PROJECT COST                         | \$ 403,480    |
| Average Cost per kW: ( $\$403,480/270$ kW) | \$1,494       |

## 10. Fairfield Drop

The Fairfield Drop site on the Fairfield Canal in Merced County is owned and operated by the Merced Irrigation District. In a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site; it would develop 970 kW of hydroelectric capacity at a design head of 9 m (30 ft) and a design flow of 12 cms (420 cfs). A new drop structure would have to be built to house a bulb turbine and a generator. The estimated annual output is 2.8 million kWh.

The estimated cost of the Fairfield Drop power facility is \$1,071,224, at 1982 price levels. Table D-10 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,380 per kW.

The estimated annual cost of owning and operating the project would range between 13.0 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 6.3 and 9.8 cents per kWh in 1984.

A power plant at Fairfield Drop would cost effective during its first year of operation (1984).

Table D-10  
Fairfield Drop Cost Estimate

| <u>Cost Item</u>                          | <u>Amount</u> |
|---|---------------|
| Project Facilities                        |               |
| Electrical and Mechanical Equipment       | \$ 630,500    |
| Civil Construction and Installation       | 239,000       |
| Engineering and Management                | 104,340       |
| Subtotal                                  | 973,840       |
| Contingency                               | 97,384        |
| TOTAL PROJECT COST                        | \$1,071,224   |
| Average Cost per kW: (\$1,071,224/970 kW) | \$1,104       |

## 11. Frankenheimer Drop

Frankenheimer Drop on the South San Joaquin Irrigation District's Main Canal in Stanislaus County is owned and operated by the District. In the report, a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site. It would develop 4.7 MW of hydroelectric capacity at a design head of 23.8 m (78 ft) and a design flow of 25.5 cms (900 cfs). The hydroelectric facility would consist of a conventional vertical Francis turbine and an overhead generator. The estimated annual output is 17 million kWh.

The estimated cost of the Frankenheimer Drop power facility is \$4,963,728, at 1982 price levels. Table D-11 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,320 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 4.4 and 7.0 cents per kWh in 1984.

A power plant at Frankenheimer Drop would be cost effective during its first year of operation (1984).

Table D-11  
Frankenheimer Drop Cost Estimate

| <u>Cost Item</u>                           | <u>Amount</u> |
|--|---------------|
| Project Facilities                         |               |
| Electrical and Mechanical Equipment        | \$1,410,000   |
| Civil Construction and Installation        | 2,619,000     |
| Engineering and Management                 | 483,480       |
| Subtotal                                   | 4,512,480     |
| Contingency                                | 451,248       |
| TOTAL PROJECT COST                         | 4,963,728     |
| Average Cost per kW: (\$4,963,728/4700 kW) | \$1,056       |

## 12. Goodwin Dam

Goodwin Dam on the Stanislaus River in Calaveras County is owned and operated jointly by the Oakdale Irrigation District and the South San Joaquin Irrigation District. In the report, a "Hydropower Feasibility Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site; it would develop 970 kW of hydroelectric capacity at a design head of 3 m (10 ft) and a design flow of 34 cms (1200 cfs). The existing outlet structure would house a bulb turbine and a generator. The estimated annual output is 4.7 million kWh.

The estimated cost of the Goodwin Dam power facility is \$1,322,160, at 1982 price levels. Table D-12 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,710 per kW.

The estimated annual cost of owning and operating the project would range between 13.0 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 4.6 and 7.3 cents per kWh in 1984.

A power plant at Goodwin Dam would be cost effective during its first year of operation (1984).

Table D-12  
Goodwin Dam Cost Estimate

| <u>Cost Item</u>                                       | <u>Amount</u> |
|--|---------------|
| Project Facilities                                     |               |
| Electrical and Mechanical<br>(including contingencies) | \$ 630,500    |
| Civil  | 550,000       |
| Engineering and Management                             | 141,660       |
| TOTAL PROJECT COST                                     | \$1,322,160   |
| Average Cost per kW: (\$1,322,160/970 kW)              | \$1,363       |

### 13. Jackson Meadows Dam

Jackson Meadows Reservoir on the Middle Yuba River in Nevada County is owned and operated by the Nevada Irrigation District. In a report, the "Hydroelectric Power Potential: Nevada Irrigation District," prepared by the Tudor Engineering Company in February 1979, a power plant was considered for installation at this site; it would develop 4 MW of hydroelectric capacity at a design head of 59.4 m (195 ft) and a design flow of 8.5 cms (300 cfs). A new powerhouse would have to be built on what is now a streambed to house a vertical Francis turbine and a generator. The estimated annual output is 8.9 million kWh.

The estimated cost of the Jackson Meadows Reservoir power facility is \$2,287,000, at 1979 price levels. Table D-13 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,010 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 5.4 and 8.6 cents per kWh in 1984.

A power plant at Jackson Meadows Dam would be cost effective during its first year of operation (1984).

Table D-13  
Jackson Meadows Dam Cost Estimate

| <u>Cost Item</u>                                 | <u>Amount</u> |
|--|---------------|
| Project Facilities                               |               |
| Structures and Improvements                      | \$ 332,000    |
| Reservoirs, Dams, and Waterways                  | 303,000       |
| Turbines and Generators                          | 693,000       |
| Miscellaneous Power Plant Equipment              | 250,000       |
| Subtotal   | 1,658,000     |
| Contingency                                      | 314,000       |
| Administration, Engineering, Legal<br>Management | 405,000       |
| TOTAL PROJECT COST                               | \$2,287,000   |
| Average Cost per kW: (\$2,287,000/4000 kW)       | \$572         |

#### 14. Lake Berryessa (Monticello Dam)

Lake Berryessa on Putah Creek in Napa County is owned and operated by WPRS. In the report, on "Adding Powerplants At Existing Federal Dams: California," prepared by the WPRS in July 1976, a power plant was considered for installation at this site. It would develop 16 MW of hydroelectric capacity at a design head of 60.4 m (198 ft) and a design flow of 31.2 cms (1100 cfs). A Francis turbine and a generator unit would be located at the existing outlet structure; a new electrical station and transmission facilities are also necessary. The estimated annual output is 42.7 million kWh.

The estimated cost of the Lake Berryessa power facility is \$5,283,000, at 1975 price levels. Table D-14 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$920 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 4.1 and 6.5 cents per kWh in 1984.

A power plant at Lake Berryessa would be cost effective during its first year of operation (1984).

Table D-14  
Lake Berryessa Cost Estimate

| Cost Item                                    | Amount      |
|--|-------------|
| Project Facilities                           | -           |
| Powerplant                                   | \$4,880,000 |
| Transmission Line                            | 403,000     |
| TOTAL PROJECT COST                           | \$5,283,000 |
| Average Cost per kW: (\$5,283,000/16 000 kW) | \$330       |

15. Lake Davis (Grizzly Valley Dam)

The Lake Davis site, located on Big Grizzly Creek in Plumas County, is owned and operated by the Department. An earlier study by the Department indicated that a power plant installed at this site would develop 510 kW of hydroelectric capacity at a design head of 33.5 m (110 ft) and a design flow of 1.8 cms (65 cfs). The estimated annual output is 1.5 million kWh.

The estimated cost of the Lake Davis power facility is \$921,600, at 1978 price levels. Table D-15 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$3,380 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 15.5 and 23.6 cents per kWh in 1984.

A power plant at Lake Davis, if operational by 1984, would be cost effective in 1986.

Table D-15  
Lake Davis Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      |            |
| Civil Works                             | 167,000    |
| Electrical Equipment                    | 175,000    |
| Mechanical Equipment                    | 281,000    |
| Transmission Line                       | 36,000     |
| Subtotal                                | 659,000    |
| Engineering                             | 164,000    |
| Contingency                             | 98,850     |
| TOTAL PROJECT COST                      | \$ 921,600 |
| Average Cost per kW: (\$921,600/510 kW) | \$1,807    |

## 16. Lake Redding

The Lake Redding site, on the Sacramento River in Shasta County, is owned and operated by the Anderson-Cottonwood Irrigation District. In a study entitled "Lake Redding Power Project," prepared by CH2M Hill for the city of Redding in 1979, a power plant at this site was considered. It would develop 14.5 MW of hydroelectric capacity, at a design head of 4.3 m (14 ft) and a design flow of 425 cms (15,000 cfs).

New power plant structures would include a powerhouse and dam; the development would also include channel modification, care of the river, and other miscellaneous items. The new power plant would contain five 2900 kW generators with 4.65 m (15.25 ft) inclined-shaft tube-type turbines. The estimated annual generation is 79 million kWh.

The estimated cost of the Lake Redding power facility is \$36.4 million, at 1979 price levels. Table D-16 is a summary of the estimated cost. If construction were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$4,388 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 9.7 and 15.3 cents per kWh in 1984.

A power plant at Lake Redding would be cost effective during its first year of operation (1984).

Table D-16  
Lake Redding Cost Estimate

| Cost Item                                     | Amount              |
|---|---------------------|
| <b>Powerhouse</b>                             |                     |
| Civil Works                                   | \$ 7,000,000        |
| Generating Equipment                          | 11,400,000          |
| Electrical Control and Transmission           | 700,000             |
| Building and Mechanical Equipment             | 400,000             |
| Trash Racks                                   | 500,000             |
| Upstream Gates                                | 600,000             |
| Subtotal                                      | 20,600,000          |
| <b>Diversion Facility</b>                     |                     |
| Bascule Gates                                 | 3,200,000           |
| Civil Works                                   | 1,200,000           |
| Subtotal                                      | 4,400,000           |
| Channel Modification                          | 1,100,000           |
| Care of the River                             | 3,300,000           |
| Miscellaneous                                 | 900,000             |
| Administration, Engineering, Legal, etc.      | 6,100,000           |
| <b>TOTAL PROJECT COST</b>                     | <b>\$36,400,000</b> |
| Average Cost per kW: (\$36,400,000/14 500 kW) | \$2,510             |

### 17. Las Flores Turnout

The Las Flores Turnout site is in San Bernardino County where the Mojave Siphon crosses the Mojave River; it is owned and operated by the Department. An earlier study prepared by the Department indicated that a power plant installed at this site would develop 210 kW of hydroelectric capacity at a design head of 67 m (220 ft) and a design flow of 0.4 cms (13 cfs). The estimated annual output is 700 000 kWh.

The estimated cost of the Las Flores power facility is \$533,700, at 1978 price levels. Table D-17 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$4,750 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 21.0 percent of the project cost, depending on financing. The energy cost would range between 19.2 and 29.9 cents per kWh in 1984.

A power plant at Las Flores Turnout, if operational in 1984, would be cost effective by 1988.

Table D-17  
Las Flores Turnout Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      |            |
| Civil Works                             | \$ 63,500  |
| Electrical Equipment                    | 130,400    |
| Mechanical Equipment                    | 151,300    |
| Transmission Line                       | 36,000     |
| Subtotal                                | 381,200    |
| Engineering                             | 95,300     |
| Contingency                             | 57,200     |
| TOTAL PROJECT COST                      | \$ 533,700 |
| Average Cost per kW: (\$533,700/210 kW) | \$2,541    |

### 18. Lytle Creek Turnout

Lytle Creek Turnout on the Lytle Creek Pipeline in San Bernardino County is owned and operated by the San Bernardino Valley Municipal Water District. In a report, the "Hydroelectric Power Potential on the Foothill and Lytle Creek Pipelines," prepared by the Tudor Engineering Company in August 1978, a power plant was considered for installation at this site. It would develop 1.3 MW of hydroelectric capacity at a design head of 111.3 m (365 ft) and a design flow of 2 cms (70 cfs). New hydroelectric facilities would include a 1300 kW vertical shaft Francis turbine and a generator. The estimated annual output is 7.8 million kWh.

The estimated cost of building the Lytle Creek Turnout power facility is \$1,402,000, at 1978 price levels. Table D-18 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$2,130 per kW.

The estimated annual cost of owning and operating the project would range between 13 and 20 percent of the project cost, depending on financing. The energy cost would range between 4.6 and 7.1 cents per kWh in 1984.

A power plant at Lytle Creek Turnout would be cost effective during its first year of operation (1984).

Table D-18  
Lytle Creek Turnout Estimated Cost

| Cost Item                                  | Amount      |
|--|-------------|
| Project Facilities                         |             |
| Structures and Improvements                | \$ 240,000  |
| Reservoirs, Dams, and Waterways            | 60,000      |
| Turbine and Generator                      | 513,000     |
| Accessory Electrical Equipment             | 131,000     |
| Miscellaneous Power Plant Equipment        | 72,000      |
| Subtotal                                   | 1,016,000   |
| Contingency (15%)                          | 152,000     |
| Management                                 | 234,000     |
| TOTAL PROJECT COST                         | \$1,402,000 |
| Average Cost per kW: (\$1,402,000/1300 kW) | \$1,079     |

19. Madera Canal Station 980+65

The site of Madera Canal Station 980+65, located on the Madera Canal, is owned by the WPRS. In a "Feasibility Report on the Potential Hydroelectric Development at Madera Canal Station 980+65," prepared by Stoddard & Associates and Ed Farmer & Associates, Inc. for the Chowchilla Water District in January 1980, a power plant was considered for installation at this site; it would develop 2 MW of hydroelectric capacity at a design head of 3 m (10 ft) and a design flow of 16.3 cms (575 cfs). Several structural modifications would be required at the site including constructing a new building to house a tube-type turbine and a generator. The estimated annual output is 5.5 million kWh.

The estimated cost of the power facility at Madera Canal Station 980+65 is \$1,069,400, at 1980 price levels. Table D-19 is a summary of this cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$840 per kW.

The estimated annual cost of owning and operating the project would range between 12.5 and 20.0 percent of the project cost, depending on financing. The energy cost would range between 3.8 and 6.1 cents per kWh in 1984.

A power plant at Madera Canal Station 980+65 project would be cost effective during its first year of operation (1984).

Table D-19  
Madera Canal Station 980+65 Cost Estimate

| Cost Item                                  | Amount      |
|--|-------------|
| Project Facilities                         |             |
| Civil Works                                | \$ 93,100   |
| Turbines and Generators                    | 369,405     |
| Accessory Electrical Equipment             | 127,381     |
| Miscellaneous Power Plant Equipment        | 38,214      |
| Transmission Line                          | 80,000      |
| Subtotal                                   | 708,100     |
| Contingency                                | 204,422     |
| Engineering and Administration             | 156,878     |
| TOTAL PROJECT COST                         | \$1,069,400 |
| Average Cost per kW: (\$1,069,400/2000 kW) | \$535       |

## 20. Millerton Lake (Friant Dam)

Millerton Lake on the San Joaquin River in Fresno County is owned and operated by WPRS. In the report, "Adding Powerplants At Existing Federal Dams: California," prepared by WPRS in July 1976, three outlet sites from Millerton Lake were identified as having hydroelectric power potential. These sites are discussed below.

Friant-Kern Canal Plant. This facility would have an estimated capacity of 15 MW. A Francis or adjustable-propeller turbine-generator unit installed here would have an estimated annual output of 90.3 million kWh.

The estimated cost of Friant Kern Canal power facility is \$10,030,000, at 1975 price levels. Table D-20A is a summary of the cost estimate. If construction of the project would be completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,860 per kW.

The estimated annual cost of owning and operating the project would range between 12 to 19 percent of the project cost, depending on financing. The energy cost would range between 3.7 and 5.8 cents per kWh in 1984.

Table D-20A  
Millerton Lake Cost Estimate  
(Friant-Kern Canal Plant)

| Cost Item                                     | Amount        |
|---|---------------|
| Project Facilities                            |               |
| Powerplant                                    | \$ 9,400,000  |
| Transmission Lines and Switchyard             | 630,000       |
| TOTAL PROJECT COST                            | \$ 10,030,000 |
| Average Cost per kW: (\$10,030,000/15 000 kW) | \$670         |

Madera Canal Plant. This plant would have an estimated capacity of 5 MW. A Francis turbine and a generator installed here would have an estimated annual output of 30.6 million kWh.

The estimated cost of the Madera Canal power facility is \$3,700,000, at 1975 price levels. Table D-20B is a summary of the cost estimate. If construction of the project would be completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$2,050 per kW.

The estimated annual cost of owning and operating the project would range between 12 to 19 percent of the project cost, depending on financing. The energy cost would range between 4.0 to 6.4 cents per kWh in 1984.

The three power plants at Millerton Lake would be cost effective during their first year of operation (1984).

Table D-20B  
Millerton Lake Cost Estimate  
(Madera Canal Plant)

| <u>Cost Item</u>                           | <u>Amount</u> |
|--|---------------|
| Project Facilities                         |               |
| Powerplant                                 | \$ 3,100,000  |
| Transmission Lines and Switchyard          | 600,000       |
| TOTAL PROJECT COST                         | \$ 3,700,000  |
| Average Cost per kW: (\$3,700,000/5000 kW) | \$740         |

San Joaquin River Plant. This plant would have an estimated capacity of 2.7 MW. A Francis turbine and a generator unit installed here would have an estimated annual output of 9.9 million kWh.

The estimated cost of the Friant downstream power facility is \$1,700,000, at 1975 price levels. Table D-20C is a summary of the cost estimate. If construction of the project would be completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,750 per kW.

The estimated annual cost of owning and operating the project would range between 12.5 and 19.5 percent of the project cost, depending on financing. The energy cost would range between 5.9 and 10.1 cents per kWh in 1984.

Table D-20C  
Millerton Lake Cost Estimate  
(San Joaquin River Plant)

| Cost Item                                  | Amount       |
|--|--------------|
| Project Facilities                         |              |
| Powerplant                                 | \$ 1,170,000 |
| Transmission Lines and Switchyard          | 530,000      |
| TOTAL PROJECT COST                         | \$ 1,700,000 |
| Average Cost per kW: (\$1,700,000/2700 kW) | \$630        |

## 21. Modesto Reservoir

The Modesto Reservoir site is on the Lower Main Canal, an irrigation distribution system in Stanislaus County; it is owned and operated by the Modesto Irrigation District. In a report on the "Lower Main Canal Hydro Stations," prepared by CH2M Hill for the District in November 1978, a power plant was considered for installation at this site; it would develop 1 MW of hydroelectric capacity at a design head of 5.5 m (18 ft) and a design flow of 23 cms (800 cfs). A new powerhouse would have to be built to house a 1000 kW turbine-generator unit. The estimated annual project output is 3.4 million kWh.

It would cost an estimated \$1,425,000 to build the Modesto Reservoir power facility, based on 1978 manufacturers' quotations and contractors' bid prices escalated to 1979 price levels. Table D-21 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$2,510 per kW.

The estimated annual cost of owning and operating the project would range between 13.0 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 9.6 and 15.2 cents per kWh in 1984.

A power plant at Modesto Reservoir would be cost effective during its first year of operation (1984).

Table D-21  
Modesto Reservoir Cost Estimate

| Cost Item                                  | Amount      |
|--|-------------|
| Project Facilities                         |             |
| Civil Works                                | \$ 350,000  |
| Turbine and Generator                      | 720,000     |
| Transmission                               | 30,000      |
| Subtotal                                   | 1,100,000   |
| Inflation (1 yr at 10%)                    | 110,000     |
| Engineering and Administration             | 180,000     |
| Legal and Miscellaneous                    | 35,000      |
| TOTAL PROJECT COST                         | \$1,425,000 |
| Average Cost per kW: (\$1,425,000/1000 kW) | \$1,425     |

## 22. Mojave Siphon No. 1

The Mojave Siphon forms a portion of the East Branch of the California Aqueduct in San Bernardino County. It is owned and operated by the Department. In the feasibility report entitled "Mojave Siphon Power Recovery Facility," prepared by the Department, a power plant installed at this site could develop 6 MW of hydroelectric capacity at a design head of 23.8 m (78 ft) and a design flow of 30.3 cms (1070 cfs). A turbine-generator unit rated at 6 MW, was planned for installation at this site. The estimated annual output is 47 million kWh.

The estimated cost of the Mojave Siphon power facility is \$17,208,400, at 1981 price levels. Table D-22 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation escalation) would be \$4,029 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 6.2 and 9.8 cents per kWh in 1984.

A power plant at Mojave Siphon would be cost effective during its first year of operation (1984).

Table D-22  
Mojave Siphon Cost Estimate

| <u>Cost Item</u>                            | <u>Amount</u> |
|---|---------------|
| Project Facilities                          |               |
| Civil Works                                 | \$ 6,627,900  |
| Mechanical Works                            | 2,270,000     |
| Electrical Works                            | 429,000       |
| Turbine and Generator                       | 4,284,000     |
| Transmission Line                           | 45,000        |
| Subtotal                                    | 13,655,900    |
| Engineering, Administration, etc.           | 1,510,800     |
| Contingency                                 | 2,041,700     |
| TOTAL PROJECT COST                          | \$17,208,400  |
| Average Cost per kW: (\$17,208,400/6000 kW) | \$ 2,868      |

### 23. Palermo Canal

The Palermo Canal site in Butte County is owned and operated by the Department. An earlier study by the Department indicated that a power plant installed at this site would develop 400 kW of hydroelectric capacity at a design head of 91.4 m (300 ft) and a design flow of 0.5 cms (19 cfs). The estimated annual output is 1.5 million kWh.

The estimated cost of the Palermo Canal power facility is \$1,145,000 at 1981 price levels. Table D-23 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$4,020 per kW. The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. This would result in a 1984 energy cost ranging between 14.5 and 22.0 cents per kWh.

A power plant at Palermo Canal would be cost effective during its first year of operation (1984).

Table D-23  
Palermo Canal Cost Estimate

| Cost Item                                    | Amount      |
|--|-------------|
| Project Facilities                           |             |
| Civil Works                                  | \$ 370,000  |
| Electrical Equipment                         | 210,000     |
| Turbine and Generator                        | 160,000     |
| Miscellaneous Mechanical Equipment           | 70,000      |
| Transmission Line                            | 22,000      |
| Subtotal                                     | 832,000     |
| Engineering                                  | 230,000     |
| Contingency                                  | 83,000      |
| TOTAL PROJECT COST                           | \$1,145,000 |
| Average Cost per kW: ( $\$1,145,000/400$ kW) | \$2,863     |

## 24. Paradise Dam

Paradise Dam on Little Butte Creek in Butte County is owned and operated by the Paradise Irrigation District. In a "Feasibility Report on the Potential Hydroelectric Development at Paradise Reservoir and Dam," prepared by the Tudor Engineering Company in 1980, a power plant was considered for installation at this site. It would develop 300 kW of hydroelectric capacity at a design head of 42.7 m (150 ft) and a design flow of 1.4 cms (50 cfs). A new structure would have to be built at the downstream end of the outlet works to house a Francis turbine and a generator. The estimated annual output is 1.2 million kWh.

The estimated cost of the Paradise Dam power facility is \$602,000, at 1980 price levels. Table D-24 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$3,160 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 10.7 and 16.1 cents per kWh in 1984.

A power plant at Paradise Dam would be cost effective during its first year of operation (1984).

Table D-24  
Paradise Dam Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      |            |
| Structures and Improvements             | \$ 38,000  |
| Reservoir, Dam, and Waterways           | 12,000     |
| Turbine and Generator                   | 208,000    |
| Station Equipment                       | 130,000    |
| Miscellaneous Power Plant Equipment     | 30,000     |
| Subtotal                                | 418,000    |
| Contingency                             | 84,000     |
| Indirect Construction Cost              | 100,000    |
| TOTAL PROJECT COST                      | \$ 602,000 |
| Average Cost per kW: (\$602,000/300 kW) | \$2,007    |

## 25. Pyramid Dam (Stream Release)

The Pyramid Dam on Piru Creek in Los Angeles County is owned and operated by the Department. An earlier study by the Department indicated that a power plant installed at this site would develop 1 MW of hydroelectric capacity at a design head of 91.4 m (300 ft) and a design flow of 1.1 cms (46 cfs). The estimated annual output is 4 million kWh.

The estimated cost of the Pyramid Dam power facility is \$1,568,000, at 1981 price levels. Table D-25 is a summary of the estimated cost. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$2,200 per kW.

The estimated annual cost of owning and operating the project would range between 13 and 20 percent of project cost, depending on financing. The energy cost would range between 7.1 and 11.0 cents per kWh in 1984.

A power plant at Pyramid Dam would be cost effective during its first year of operation (1984).

Table D-25  
Pyramid Dam Cost Estimate

| <u>Cost Item</u>                              | <u>Amount</u> |
|---|---------------|
| Project Facilities                            |               |
| Civil Works                                   | \$ 495,000    |
| Electrical Equipment                          | 275,000       |
| Turbine and Generator                         | 240,000       |
| Miscellaneous Mechanical Equipment            | - 80,000      |
| Transmission Line                             | 50,000        |
| Subtotal                                      | 1,140,000     |
| Engineering                                   | 314,000       |
| Contingency                                   | 114,000       |
| TOTAL PROJECT COST                            | \$1,568,000   |
| Average Cost per kW: ( $\$1,568,000/1000$ kW) | \$1,568       |

26. Richard B. Parker

The Parker site on the Merced Irrigation District's Main Canal in Merced County is owned and operated by the District. In a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site; it would develop 2.8 MW of hydroelectric capacity at a design head of 6 m (20 ft) and design flow of 54 cms (1900 cfs). A new drop structure would have to be built to house two bulb turbines and two generators rated at 1400 kW each. An estimated annual output of 9.2 million kWh could be produced from irrigation releases in the canal.

The estimated cost of the Parker power facility is \$3,115,481, at 1982 price levels. Table D-26 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,400 per kW.

The estimated annual cost of owning and operating the project would range between 12.5 and 19.5 percent of the project cost, depending on financing. The energy cost would range between 5.4 and 8.3 cents per kWh in 1984.

A power plant at the Richard B. Parker site would be cost effective during its first year of operation (1984).

Table D-26  
Richard B. Parker Cost Estimate

| Cost Item                                     | Amount             |
|---|--------------------|
| Project Facilities                            |                    |
| Electrical and Mechanical Equipment           | \$1,313,200        |
| Civil Construction and Installation           | 1,215,600          |
| Engineering and Management                    | 303,456            |
| Subtotal                                      | \$2,832,256        |
| Contingency                                   | 283,225            |
| <b>TOTAL PROJECT COST</b>                     | <b>\$3,115,481</b> |
| Average Cost per kW: ( $\$3,115,481/2800$ kW) | \$1,113            |

## 27. San Antonio Dam

The San Antonio Dam site is on the San Antonio River in Monterey County; it is owned and operated by the Monterey County Flood Control and Water Conservation District. In a report, the "San Antonio Power Project," prepared by the Tudor Engineering Company in November 1978, the installation of a power plant at this site was considered. It would develop 6 MW of hydroelectric capacity at a design head of 52 m (170 ft) and a design flow of 15 cms (540 cfs). The new power facility will contain four 2000 hp cross-flow (Ossberger) turbines in a semioutdoor structure. A tunnel would have to be built to connect Nacimiento Reservoir and San Antonio Reservoir. The estimated annual output is 25.6 million kWh.

The estimated cost of the San Antonio Dam power facility and tunnel is \$12,758,100, based on 1978 construction costs. Table D-27 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$4,200 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 11.8 and 18.7 cents per kWh in 1984.

A power plant at San Antonio Dam would be cost effective during its first year of operation (1984).

Table D-27  
San Antonio Dam Cost Estimate

| Cost Item                                      | Amount              |
|--|---------------------|
| <b>Tunnel</b>                                  |                     |
| Land and Land Rights                           | \$ 5,000            |
| Tunnel Construction                            | 7,062,000           |
| Contingency                                    | 1,413,400           |
| Subtotal                                       | 8,480,400           |
| <b>Power Plant</b>                             |                     |
| Structures and Improvements                    | \$ 144,000          |
| Penstock                                       | 56,000              |
| Turbines and Generators                        | 1,498,000           |
| Station Equipment                              | 340,000             |
| Miscellaneous Power Plant Equipment            | 140,000             |
| Contingency                                    | 835,600             |
| Subtotal                                       | 2,613,600           |
| <b>Total Cost</b>                              |                     |
| Tunnel   | \$ 8,480,400        |
| Power Plant                                    | 2,613,600           |
| Management                                     | 1,664,100           |
| <b>TOTAL PROJECT COST</b>                      | <b>\$12,758,100</b> |
| Average Cost per kW: ( $\$12,758,100/6000$ kW) | \$2,126             |

## 28. Santa Ana Low Turnout

The Santa Ana Low Turnout site is located on the Foothill Pipeline in San Bernardino County and is owned and operated by the San Bernardino Valley Municipal Water District. In the report, the "Hydroelectric Power Potential on the Foothill and Lytle Creek Pipelines," prepared by the Tudor Engineering Company in August 1978, a powerplant was considered for installation at this site. It would develop 1.4 MW of hydroelectric capacity at a design head of 67 m (220 ft) and a design flow of 2.8 cms (100 cfs). The new hydroelectric facility would include a vertical shaft Francis turbine and a generator adjacent to the existing dissipation vault of the turnout structure. The estimated annual output is 3.8 million kWh.

The estimated cost of the Santa Ana Low Turnout power facility is \$1,176,000, at 1978 price levels. Table D-28 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,660 per kW.

The estimated annual cost of owning and operating the project would range between 13 and 20 percent of the project cost, depending on financing. The energy cost would range between 8.0 and 12.2 cents per kWh in 1984.

A power plant at Santa Ana Low Turnout would be cost effective during its first year of operation (1984).

Table D-28  
Santa Ana Low Turnout Estimated Cost

| Cost Item                                     | Amount             |
|---|--------------------|
| <b>Project Facilities</b>                     |                    |
| Structures and Improvements                   | \$ 133,000         |
| Reservoirs, Dams and Waterways                | 86,000             |
| Turbine and Generator                         | 455,000            |
| Accessory Electrical Equipment                | 131,000            |
| Miscellaneous Power Plant Equipment           | 47,000             |
| Subtotal                                      | 852,000            |
| Contingency                                   | 128,000            |
| Management                                    | 196,000            |
| <b>TOTAL PROJECT COST</b>                     | <b>\$1,176,000</b> |
| Average Cost per kW: ( $\$1,176,000/1400$ kW) | \$840              |

## 29. Sly Creek Dam

Sly Creek Dam on Lost Creek in Butte County is owned and operated by the Oroville-Wyandotte Irrigation District. In the report, an "Application for Amendment of License for Project No. 2088: South Fork Project," prepared by the Tudor Engineering Company in November 1979, a power plant was considered for installation at this site. It would develop 13.2 MW of hydroelectric capacity at a design head of 68.6 m (225 ft) and a design flow of 22 cms (777 cfs). A new structure will have to be built to house a refurbished vertical Francis turbine and a generator which will be obtained from the Melones Dam Powerplant. The estimated annual output is 48.2 million kWh.

The estimated cost of the Sly Creek Dam power facility is \$10,202,000, at 1979 price levels. Table D-29 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,360 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 4.5 and 7.1 cents per kWh in 1984.

A power plant at Sly Creek Dam would be cost effective during its first year of operation (1984).

Table D-29  
Sly Creek Dam Cost Estimate

| Cost Item  | Amount       |
|--|--------------|
| Project Facilities                               |              |
| Construction Contract                            | \$6,557,000  |
| Contingency                                      | 658,000      |
| Design and Development                           | 650,000      |
| Construction Management                          | 495,000      |
| Surveys, Testing, Geological Studies             | 20,000       |
| Administration and Legal Expense                 | 240,000      |
| Financial Consulting and Bond Issue              | 200,000      |
| Securities Commission                            | 35,000       |
| Allowance for Discount Bid (10%)                 | 1,347,000    |
| TOTAL PROJECT COST                               | \$10,202,000 |
| Average Cost per kW: ( $\$10,202,000/13$ 200 kW) | \$773        |

### 30. Stampede Dam

Stampede Dam on the Little Truckee River in Sierra County is owned and operated by WPRS. In the report, "Adding Powerplants At Existing Federal Dams: California," prepared by the WPRS in July 1976, a power plant was considered for installation at this site. It would develop 3 MW of hydroelectric capacity at a design head of 55.8 m (183 ft) and a design flow of 6.8 cms (241 cfs). The new hydroelectric facilities needed would include transmission lines and a Francis turbine and a generator rated at 3000 kW. The estimated annual output is 16 million kWh.

The estimated cost of the Stampede Dam power facility is \$1,970,000, at 1975 price levels. Table D-30 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,820 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 4.1 and 6.5 cents per kWh in 1984.

A power plant at Stampede Dam would be cost effective during its first year of operation (1984).

Table D-30  
Stampede Dam Cost Estimate

| <u>Cost Item</u>                           | <u>Amount</u> |
|--|---------------|
| Project Facilities                         |               |
| Powerplant                                 | \$1,510,000   |
| Transmission Lines                         | 460,000       |
| TOTAL PROJECT COST                         | \$1,970,000   |
| Average Cost per kW: (\$1,970,000/3000 kW) | \$657         |

### 31. Stone Drop

The Stone Drop site on the Lower Main Canal, an irrigation distribution system in Stanislaus County, is owned and operated by the Modesto Irrigation District. In the report, "Lower Main Canal Hydro Stations," prepared by CH2M Hill in November 1978, a power plant was considered for installation at this site. It would develop 1 MW of hydroelectric capacity at a design head of 5.8 m (19 ft) and a design flow of 22.7 cms (800 cfs). A new powerhouse would have to be constructed to house a 1000 kW turbine-generator unit. The estimated annual project output is 4 million kWh.

The estimated cost of the Stone Drop power facility is \$1,358,000 based on 1978 manufacturers' quotations and contractors' bid prices escalated to 1979 price levels. Table D-31 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$2,390 per kW.

The estimated annual cost of owning and operating the project would range between 13.0 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 9.6 and 12.3 cents per kWh in 1984.

A power plant at Stone Drop would be cost effective during its first year of operation (1984).

Table D-31  
Stone Drop Cost Estimate

| <u>Cost Item</u>                           | <u>Amount</u>      |
|--|--------------------|
| Project Facilities                         |                    |
| Civil and Structural                       | \$ 340,000         |
| Turbine and Generator                      | 690,000            |
| Transmission and Miscellaneous             | 20,000             |
| Subtotal                                   | 1,050,000          |
| Escalation (1 yr @ 10%)                    | 105,000            |
| Engineering and Administration             | 170,000            |
| Legal and Miscellaneous Costs              | 33,000             |
| <b>TOTAL PROJECT COST</b>                  | <b>\$1,358,000</b> |
| Average Cost per kW: (\$1,358,000/1000 kW) | \$1,358            |

### 32. Sweetwater Turnout

Sweetwater Turnout on the Foothill Pipeline in San Bernardino County is owned and operated by the San Bernardino Valley Municipal Water District. In the report, the "Hydroelectric Power Potential on the Foothill and Lytle Creek Pipelines," prepared by the Tudor Engineering Company in August 1978, a power plant was considered for installation at this site. It would develop 875 kW of hydroelectric capacity at a design head of 61 m (200 ft) and a design flow of 2.4 cms (85 cfs). New hydroelectric facilities would include a vertical Francis turbine and a generator adjacent to the existing dissipation vault of the turnout structure. The estimated annual output is 2.2 million kWh.

The estimated cost of the Sweetwater Turnout facility is \$817,000, at 1978 price levels. Table D-32 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,840 per kW.

The estimated annual cost of owning and operating the project would range between 13.0 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 9.5 and 15.0 cents per kWh in 1984.

A power plant at Sweetwater Turnout would be cost effective during its first year of operation (1984).

Table D-32  
Sweetwater Turnout Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      | -          |
| Structures and Improvements             | \$ 95,000  |
| Reservoirs, Dams and Waterways          | 62,000     |
| Turbine and Generator                   | 298,000    |
| Accessory Electrical Equipment          | 77,500     |
| Miscellaneous Power Plant Equipment     | 60,000     |
| Subtotal                                | 592,500    |
| Contingency                             | 88,500     |
| Management                              | 136,000    |
| TOTAL PROJECT COST                      | \$ 817,000 |
| Average Cost per kW: (\$817,000/875 kW) | \$934      |

### 33. Thermalito Afterbay River Outlet

The Thermalito Afterbay is adjacent to the Feather River in Butte County; it is owned and operated by the Department. The feasibility study prepared in June 1979 by the International Engineering Company, Inc. and the Aerojet Manufacturing Company indicated that a power plant installed at this site would develop 13 MW of hydroelectric capacity at a design head of 9.1 m (30 ft) and a design flow of 184 cms (6500 cfs). The estimated annual output is 42.6 million kWh.

The estimated cost of the Thermalito Afterbay power facility is \$25,630,600, at 1979 price levels. Table D-33 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$3,290 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 12.1 and 19.1 cents per kWh in 1984.

A power plant at Thermalito Afterbay would be cost effective during its first year of operation (1984).

Table D-33  
Thermalito Afterbay River Outlet Cost Estimate

| Cost Item                                     | Amount       |
|---|--------------|
| Project Facilities                            |              |
| Civil Works                                   | \$10,214,000 |
| Mechanical Equipment                          | 9,858,000    |
| Electrical Equipment                          | 1,556,000    |
| Subtotal                                      | 21,628,000   |
| Labor, Overhead, Travel                       | 4,002,600    |
| TOTAL PROJECT COST                            | \$25,630,600 |
| Average Cost per kW: (\$25,630,600/13 000 kW) | \$1,972      |

#### 34. Thermalito Diversion Dam

Thermalito Diversion Dam on the Feather River in Butte County is owned and operated by the Department. An earlier study prepared by the Department indicated that a power plant installed at this site would develop 3.5 MW of hydroelectric capacity at a design head of 21.3 m (70 ft) and a design flow of 20 cms (700 cfs). The estimated annual output is 23 million kWh.

The estimated cost of the Thermalito Diversion Dam power facility is \$5,656,000, at 1979 price levels. Table D-34 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$2,700 per kW.

The estimated annual cost of owning and operating the project would range between 12.5 and 19.0 percent of the project cost, depending on financing. The energy cost would range between 5.1 and 7.9 cents per kWh in 1984. A power plant at Thermalito Diversion Dam would be cost effective during its first year of operation (1984).

Table D-34  
Thermalito Diversion Dam Cost Estimate

| <u>Cost Item</u>                              | <u>Amount</u> |
|---|---------------|
| Project Facilities                            |               |
| Civil Works                                   | \$1,944,000   |
| Mechanical Equipment                          | 1,140,000     |
| Electrical Equipment                          | 920,000       |
| Transmission Line                             | 36,000        |
| Subtotal                                      | 4,040,000     |
| Engineering                                   | 1,010,000     |
| Contingency                                   | 606,000       |
| TOTAL PROJECT COST                            | \$5,656,000   |
| Average Cost per kW: ( $\$5,656,000/3500$ kW) | \$1,616       |

### 35. Turlock Main Canal Drop No. 1

Canal Drop No. 1 on the Turlock Irrigation District's Main Canal is owned and operated by the District. In the report, a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site. It would develop 3260 kW of hydroelectric capacity, at a design head of 7.9 m (26 ft) and a design flow of 56.6 cms (2000 cfs). The planned power plant development would consist of three generating units next to the existing outlet structure. Each generating unit would be a Leffel turbine in a flume arrangement coupled to a General Electric Company generator and would be rated at 1086 kW. The estimated annual project output is 12.2 million kWh.

The estimated cost of the Canal Drop No. 1 power facility is \$3,030,207, at 1982 price levels. Table D-35 is a summary of the estimated cost.

Construction of Canal Drop No. 1 was completed in 1980.

Table D-35  
Turlock Main Canal Drop No. 1 Estimated Cost

| <u>Cost Item</u>                              | <u>Amount</u> |
|---|---------------|
| Project Facilities                            |               |
| Electrical and mechanical Equipment           | \$1,160,000   |
| Civil Construction and Installation           | 1,252,442     |
| Engineering and Management                    | 342,292       |
| Subtotal                                      | 2,754,734     |
| Contingency                                   | 275,473       |
| TOTAL PROJECT COST                            | \$3,030,207   |
| Average Cost per kW: ( $\$3,030,207/3260$ kW) | \$930         |

36. Turlock Main Canal Drop No. 2

Canal Drop No. 2 on the Main Canal in Stanislaus County is owned and operated by the Turlock Irrigation District. In the report, a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site. It would develop 660 kW of hydroelectric capacity at a design head of 1.8 m (6 ft) and a design flow of 48.1 cms (1700 cfs). A structure would have to be built to house two standard tube-type turbine/generators in a by-pass configuration. The estimated annual output is 2.1 million kWh.

The estimated cost of the Canal Drop No. 2 power facility is \$948,640, at 1982 price levels. Table D-36 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,800 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 7.6 and 11.6 cents per kWh in 1984.

A power plant at Canal Drop No. 2 would be cost effective during its first year of operation (1984).

Table D-36  
Turlock Main Canal Drop No. 2 Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      | -          |
| Electrical and Mechanical Equipment     | \$ 495,000 |
| Civil Construction and Installation     | 275,000    |
| Engineering and Management              | 92,400     |
| Subtotal                                | 862,400    |
| Contingency                             | 86,240     |
| TOTAL PROJECT COST                      | \$ 948,640 |
| Average Cost per kW: (\$948,640/660 kW) | \$1,437    |

### 37. Turlock Main Canal Drop No. 6

Canal Drop No. 6 on the Main Canal in Stanislaus County is owned and operated by the Turlock Irrigation District. In the report, a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site. It would develop 920 kW of hydroelectric capacity at a design head of 2.4 m (8 ft) and a design flow of 48 cms (1700 cfs). The hydroelectric facility would consist of two turbine-generator units, each rated at 460 kW. The estimated annual output is estimated at 2.9 million kWh.

The estimated cost of the Canal Drop No. 6 power facility is \$1,188,880, at 1982 price levels. Table D-37 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,620 per kW.

The estimated annual cost of owning and operating the project would range between 13.0 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 6.7 and 10.5 cents per kWh in 1984.

A power plant at Canal Drop No. 6 would be cost effective during its first year of operation (1984).

Table D-37  
Turlock Main Canal Drop No. 6 Cost Estimate

| Cost Item                                 | Amount           |
|---|------------------|
| <b>Project Facilities</b>                 |                  |
| Electrical and Mechanical Equipment       | \$ 690,000       |
| Civil Construction and Installation       | 275,000          |
| Engineering and Management                | 115,800          |
| Subtotal                                  | 1,080,800        |
| Contingency                               | 109,080          |
| <b>TOTAL PROJECT COST</b>                 | <b>1,188,880</b> |
| Average Cost per kW: (\$1,188,880/920 kW) | \$1,292          |

### 38. Turlock Main Canal Drop No. 7

Canal Drop No. 7 is located on the Main Canal Drop No. 7 in Stanislaus County and is owned and operated by the Turlock Irrigation District. In the report, a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site. It would develop 700 kW of hydroelectric capacity at a design head of 2.4 m (8 ft) and a design flow of 37 cms (1300 cfs). A new structure would have to be built to house two tube-type turbine-generators. The estimated annual project output is 2.1 million kWh.

The estimated cost of the Canal Drop No. 7 power facility is \$985,600, at 1982 price levels. Table D-38 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,770 per kW.

The estimated annual cost of owning and operating the project would range between 13.5 and 20.5 percent of the project cost, depending on financing. The energy cost would range between 8.0 and 12.1 cents per kWh in 1984.

A power plant at Canal Drop No. 7 would be cost effective during its first year of operation (1984).

Table D-38  
Turlock Main Canal Drop No. 7 Cost Estimate

| Cost Item                               | Amount     |
|---|------------|
| Project Facilities                      | -          |
| Electrical and Mechanical Equipment     | \$ 525,000 |
| Civil Construction and Installation     | 275,000    |
| Engineering and Management              | 96,000     |
| Subtotal                                | 896,000    |
| Contingency                             | 89,600     |
| TOTAL PROJECT COST                      | \$ 985,600 |
| Average Cost per kW: (\$985,600/700 kW) | \$1,408    |

39. Turlock Main Canal Drop No. 9

Canal Drop No. 9 on the Turlock Irrigation District's Main Canal, and is owned and operated by the District. In the report, a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc., in February 1979, a power plant was considered for installation at this site. It would develop 1070 kW of hydroelectric capacity at a design flow of 28.3 cms (1000 cfs). A new drop structure would have to be built to house two Leffel turbines and generators in a flume arrangement. The estimated annual output is 4.7 million kWh.

The estimated cost of the Canal Drop No. 9 power facility is \$1,786,400, at 1982 price levels. Table D-39 is a summary of the cost estimate.

Construction of Canal Drop No. 9 was completed in 1979.

Table D-39  
Turlock Main Canal Drop No. 9 Cost Estimate

| Cost Item                                  | Amount      |
|--|-------------|
| Project Facilities                         |             |
| Electrical and Mechanical Equipment        | \$ 805,000  |
| Civil Construction and Installation        | 645,000     |
| Engineering and Management                 | 174,000     |
| Subtotal                                   | 1,624,400   |
| Contingency                                | 162,400     |
| TOTAL PROJECT COST                         | \$1,786,400 |
| Average Cost per kW: (\$1,786,400/1070 kW) | \$1,670     |

#### 40. Waterman Canyon Turnout

Waterman Canyon Turnout on the Foothill Pipeline in San Bernardino County is owned and operated by the San Bernardino Valley Municipal Water District. In the report, the "Hydroelectric Power Potential on the Foothill and Lytle Creek Pipelines," prepared by the Tudor Engineering Company in August 1978, a power plant was considered for installation at this site. It would develop 4 MW of hydroelectric capacity at a design head of 154 m (505 ft) and a design flow of 3.3 cms (115 cfs). The new hydroelectric facility would include a vertical Francis turbine and a generator adjacent to the existing dissipation vault of the turnout structure. The estimated annual output is 7 million kWh.

The estimated cost of the Waterman Canyon Turnout power facility is \$2,202,000, at 1978 price levels. Table D-40 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,090 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 7.5 and 11.8 cents per kWh in 1984.

A power plant at Waterman Canyon Turnout would be cost effective during its first year of operation (1984).

Table D-40  
Waterman Canyon Turnout Cost Estimate

| <u>Cost Item</u>                           | <u>Amount</u> |
|--|---------------|
| Project Facilities                         |               |
| Structures and Improvements                | \$ 105,000    |
| Reservoirs, Dams and Waterways             | 159,000       |
| Turbine and Generator                      | 1,074,000     |
| Accessory Electrical Equipment             | 135,000       |
| Miscellaneous Power Plant Equipment        | 123,000       |
| Subtotal                                   | 1,596,000     |
| Contingency                                | 239,000       |
| Management                                 | 367,000       |
| TOTAL PROJECT COST                         | \$2,202,000   |
| Average Cost per kW: (\$2,202,000/4000 kW) | \$551         |

#### 41. Whiskeytown Dam

Whiskeytown Dam on Clear Creek in Shasta County is owned and operated by WPRS. In the report, "Adding Powerplants At Existing Federal Dams: California," prepared by WPRS in July 1976, a power plant was considered for installation at this site. It would develop 4 MW of hydroelectric capacity at a design head of 68.6 m (225 ft) and a design flow of 7.0 cms (247 cfs). The new hydroelectric facility would include a 4000 kW semi-automatic plant. The present outlet works could be used to deliver downstream releases to the plant. The estimated annual output is 19.5 million kWh.

The estimated cost of the Whiskeytown Dam power facility is \$2,110,000, at 1975 price levels. Table D-41 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,460 per kW.

The estimated annual cost of owning and operating the project would range between 12 and 19 percent of the project cost, depending on financing. The energy cost would range between 3.6 and 5.7 cents per kWh in 1984.

A power plant at Whiskeytown Dam would be cost effective during its first year of operation (1984).

Table D-41  
Whiskeytown Dam Cost Estimates

| <u>Cost Item</u>                           | <u>Amount</u> |
|--|---------------|
| Project Facilities                         |               |
| Powerplant                                 | \$1,650,000   |
| Transmission Lines                         | 400,000       |
| TOTAL PROJECT COST                         | \$2,110,000   |
| Average Cost per kW: (\$2,110,000/4000 kW) | \$528         |

#### 42. Woodward Dam

Woodward Dam on the South San Joaquin Irrigation District's Main Canal is owned and operated by the District. In the report, a "Hydropower Assessment Study," prepared by Fluid Energy Systems, Inc. in February 1979, a power plant was considered for installation at this site. It would develop 2.3 MW of hydroelectric capacity at a design head of 12.2 m (40 ft) and a design flow of 22.7 cms (800 cfs). The hydroelectric facility would consist of either one bulb turbine and a generator, or two tube-type turbines and two generators placed at the existing outlet structure for the Woodward Reservoir. The estimated annual project output is 9 million kWh.

The estimated cost of the Woodward Dam power facility is \$2,225,608, at 1982 price levels. Table D-42 is a summary of the cost estimate. If construction of the project were completed for first-year operation in 1984, the estimated project cost (with 12 percent annual inflation) would be \$1,210 per kW.

The estimated annual cost of owning and operating the project would range between 12.5 and 19.5 percent of the project cost, depending on financing. The energy cost would range between 5.0 and 8.0 cents per kWh in 1984.

A power plant at Woodward Dam would be cost effective during its first year of operation (1984).

Table D-42  
Woodward Dam Cost Estimate

| <u>Cost Item</u>                           | <u>Amount</u> |
|--|---------------|
| Project Facilities                         |               |
| Electrical and Mechanical Equipment        | \$ 981,500    |
| Civil Construction and Installation        | 825,000       |
| Engineering and Management                 | 216,780       |
| Subtotal                                   | 2,023,280     |
| Contingency                                | 202,328       |
| TOTAL PROJECT COST                         | \$ 2,225,608  |
| Average Cost per kW: (\$2,225,608/2300 kW) | \$968         |

APPENDIX E

Capacity, Energy, and Cost Data on  
Facilities Grouped into Six Categories



## APPENDIX E

### Capacity, Energy, and Cost Data on Facilities Grouped into Six Categories

Facilities were grouped into six categories based on the type of facility studied (dam, canal, or pipeline) and the estimated installed capacity (greater than 500 kW, or 500 kW or less).

#### Section E-1. Facilities Studied by the Department of Water Resources

Table E-1.1 Comparison of All Categories

Table E-1.2 Dams

Table E-1.3 Canals

Table E-1.4 Pipelines

#### Section E-2. Facilities Studied by Others

Table E-2.1 Comparison of All Categories

Table E-2.2 Dams

Table E-2.3 Canals

Table E-2.4 Pipelines

#### Section E-3. Facilities With Only Limited Data (Questionnaire Responses)

Table E-3.1 Comparison of All Categories

Table E-3.2 Dams

Table E-3.3 Canals

Table E-3.4 Pipelines

## Section E-1

## Facilities Studied by the Department of Water Resources

Table E-1.1. Comparison of All Categories

| Type of Facility               | Number of Facilities | Capacity (kW) | Energy (GWh/yr) |
|--------------------------------|----------------------|---------------|-----------------|
| Dams: Greater than 500 kW      | 7                    | 17 450        | 61              |
| 500 kW or less                 | 6                    | 1 725         | 8               |
| Subtotal                       | 13                   | 19 175        | 69              |
| Canals: Greater than 500 kW    | 3                    | 2 950         | 17              |
| 500 kW or less                 | 6                    | 1 290         | 4               |
| Subtotal                       | 9                    | 4 240         | 21              |
| Pipelines: Greater than 500 kW | 0                    | 0             | 0               |
| 500 kW or less                 | 6                    | 1 825         | 12              |
| Subtotal                       | 6                    | 1 825         | 12              |
| TOTAL                          | 28                   | 25 240        | 102             |

Table E-1.2. DAMS

| Facility  | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(%) | 1984<br>Energy Cost<br>(\$/kWh) |
|---|------------------|--------------------|---------------------------|---------------------------------|--|---------------------------------|
| <u>Capacities greater than 500 kW</u>           |                  |                    |                           |                                 |  |                                 |
| Black Butte                                     | 9 200            | 31.7               | 39                        | 1,717                           | 12.7                                     | 6.4                             |
| Clear Lake                                      | 2 000            | 7.5                | 43                        | 2,469                           | 12.5                                     | 8.2                             |
| Gould Weir                                      | 850              | 3.5                | 47                        | 7,499                           | 13.0                                     | 23.7                            |
| Indian Valley                                   | 3 200            | 7.2                | 26                        | 1,648                           | 14.3                                     | 10.5                            |
| Jenkinson Lake<br>(Sly Park Dam)                | 650              | 1.8                | 32                        | 2,208                           | 14.1                                     | 10.9                            |
| Lemoncove Ditch                                 | 650              | 3.5                | 61                        | 2,754                           | 14.9                                     | 7.7                             |
| Merle Collins Reservoir<br>(Virginia Ranch Dam) | 900              | 5.6                | 71                        | 2,314                           | 13.1                                     | 4.9                             |
| Subtotal  | 17 450           | 60.8               |                           |                                 |  |                                 |
| <u>Capacities of 500 kW or less</u>             |                  |                    |                           |                                 |  |                                 |
| Chesbro   | 100              | 0.2                | 23                        | 5,343                           | 14.9                                     | 36.8                            |
| Frenchman                                       | 450              | 1.0                | 25                        | 3,657                           | 13.1                                     | 20.0                            |
| Lake Amador<br>(Jackson Creek Dam)              | 350              | 2.5                | 82                        | 2,631                           | 14.1                                     | 5.1                             |
| Lake Shastina<br>(Shasta River Dam)             | 200              | 0.7                | 40                        | 3,608                           | 13.8                                     | 13.4                            |
| Stumpy Meadows Reservoir<br>(Mark Edson Dam)    | 325              | 2.2                | 77                        | 4,652                           | 12.2                                     | 8.5                             |
| Uvas  | 300              | 1.0                | 38                        | 3,267                           | 13.1                                     | 13.1                            |
| Subtotal  | 1 725            | 7.6                |                           |                                 |  |                                 |
| TOTAL   | 19 175           | 68.4               |                           |                                 |  |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-1.3. CANALS

| Facility                              | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(\$) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kWh) |
|---------------------------------------|------------------|--------------------|----------------------------|---------------------------------|---|---------------------------------|
| <u>Capacities greater than 500 kW</u> |                  |                    |                            |                                 |   |                                 |
| Alamo Drop 3A                         | 1 200            | 6.7                | 64                         | 2,312                           | 13.6                                      | 6.4                             |
| Harding Canal                         | 1 000            | 6.6                | 75                         | 2,077                           | 14.2                                      | 4.5                             |
| No. 8 Heading                         | 750              | 3.9                | 59                         | 3,362                           | 15.4                                      | 10.0                            |
| Subtotal                              | 2 950            | 17.2               |                            |                                 |   |                                 |
| <u>Capacities of 500 kW or less</u>   |                  |                    |                            |                                 |   |                                 |
| Anderson Flume Division               | 50               | 0.2                | 41                         | 5,518                           | 19.5                                      | 28.5                            |
| Beardsley Diversion                   | 500              | 1.7                | 39                         | 8,062                           | 13.6                                      | 31.5                            |
| Parkview Station                      | 150              | 0.5                | 38                         | 4,030                           | 14.4                                      | 15.8                            |
| Pumping Plant Lower                   | 65               | 0.2                | 35                         | 5,331                           | 17.1                                      | 34.4                            |
| Rocky Pt. Diversion                   | 300              | 0.7                | 27                         | 4,150                           | 13.2                                      | 24.8                            |
| Vail Heading                          | 225              | 1.0                | 51                         | 6,167                           | 13.1                                      | 17.8                            |
| Subtotal                              | 1 290            | 4.3                |                            |                                 |   |                                 |
| TOTAL                                 | 4 240            | 21.5               |                            |                                 |   |                                 |

Table E-1.4. PIPELINES (All have Capacities of 500 kW or less)

| Facility                 | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(\$) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kWh) |
|--------------------------|------------------|--------------------|----------------------------|---------------------------------|---|---------------------------------|
| Buckeye Conduit          | 350              | 2.4                | 78                         | 2,451                           | 15.3                                      | 5.4                             |
| Del Loma Tunnel          | 250              | 1.9                | 87                         | 5,130                           | 15.1                                      | 10.2                            |
| Glendale Dist. System    | 400              | 2.0                | 57                         | 2,558                           | 13.0                                      | 6.9                             |
| Mount Olivette           | 150              | 1.2                | 84                         | 3,646                           | 16.2                                      | 7.9                             |
| North Portal Tecolote    | 175              | 0.7                | 46                         | 6,993                           | 13.2                                      | 22.4                            |
| West Coast Basin Barrier | 500              | 4.2                | 96                         | 2,270                           | 15.1                                      | 4.1                             |
| TOTAL                    | 1 825            | 12.3               |                            |                                 |   |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

## Section E-2

## Facilities Studied by Others

Table E-2.1. Comparison of All Categories

| Type of Facility               | Number of Facilities | Capacity (kW) | Energy (GWh/yr) |
|--------------------------------|----------------------|---------------|-----------------|
| Dams: Greater than 500 kW      | 19                   | 110 405       | 477             |
| 500 kW or less                 | 5                    | 1 825         | 7               |
| Subtotal                       | 24                   | 112 230       | 484             |
| Canals: Greater than 500 kW    | 11                   | 17 950        | 61              |
| 500 kW or less                 | 1                    | 270           | 1               |
| Subtotal                       | 12                   | 18 220        | 62              |
| Pipelines: Greater than 500 kW | 5                    | 13 575        | 68              |
| 500 kW or less                 | 1                    | 210           | 1               |
| Subtotal                       | 6                    | 13 785        | 69              |
| TOTAL                          | 42                   | 144 235       | 615             |

Table E-2.2. DAMS

| Facility                              | Capacity<br>(kW) | Energy<br>(Gwh/yr) | Capacity<br>Factor<br>(\$) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kwh) |
|---------------------------------------|------------------|--------------------|----------------------------|---------------------------------|---|---------------------------------|
| <u>Capacities greater than 500 kW</u> |                  |                    |                            |                                 |   |                                 |
| Bowman                                | 3 000            | 14.7               | 56                         | 1,080                           | 12.5                                      | 2.7                             |
| Comble                                | 525              | 2.9                | 63                         | 3,060                           | 13.5                                      | 7.5                             |
| Coyote                                | 600              | 1.3                | 24                         | 1,990                           | 13.5                                      | 12.4                            |
| Goodwin                               | 970              | 4.7                | 55                         | 1,710                           | 13.0                                      | 4.6                             |
| Jackson Meadows                       | 4 000            | 8.9                | 25                         | 1,010                           | 12.0                                      | 5.4                             |
| Lake Berryessa<br>(Monticello Dam)    | 16 000           | 43.0               | 30                         | 920                             | 12.0                                      | 4.1                             |
| Lake Davis<br>(Grizzly Valley Dam)    | 510              | 1.5                | 34                         | 3,380                           | 13.5                                      | 15.5                            |
| Lake Redding                          | 14 500           | 79.0               | 62                         | 4,390                           | 12.0                                      | 9.7                             |
| Leroy Anderson                        | 600              | 1.3                | 25                         | 2,610                           | 13.5                                      | 8.0                             |
| <u>Millerton Lake (Friant Dam)</u>    |                  |                    |                            |                                 |   |                                 |
| San Joaquin River                     | 2 700            | 9.9                | 42                         | 1,750                           | 12.5                                      | 5.9                             |
| Friant - Kern Canal                   | 15 000           | 90.3               | 69                         | 1,060                           | 12.0                                      | 3.7                             |
| Madera Canal                          | 5 000            | 30.6               | 70                         | 2,050                           | 12.0                                      | 4.0                             |
| Modesto Reservoir                     | 1 000            | 3.4                | 39                         | 2,510                           | 13.0                                      | 9.6                             |
| Pyramid                               | 1 000            | 4.0                | 46                         | 2,208                           | 13.0                                      | 9.0                             |
| San Antonio                           | 6 000            | 25.6               | 49                         | 4,200                           | 12.0                                      | 11.8                            |
| Sly Creek                             | 13 200           | 48.2               | 42                         | 1,360                           | 12.0                                      | 4.5                             |
| Stamper                               | 3 000            | 16.0               | 61                         | 1,820                           | 12.0                                      | 4.3                             |
| Thermalito Afterbay                   | 13 000           | 42.6               | 37                         | 3,290                           | 12.0                                      | 12.1                            |
| Thermalito Diversions                 | 3 500            | 23.0               | 75                         | 2,700                           | 12.5                                      | 5.1                             |
| Whiskeytown                           | 4 000            | 19.5               | 56                         | 1,460                           | 12.0                                      | 3.6                             |
| Woodward                              | 2 300            | 6.9                | 34                         | 1,210                           | 5.0                                       | 6.9                             |
| Subtotal                              | 110 405          | 477.3              |                            |                                 | -   |                                 |
| <u>Capacities of 500 kW or less</u>   |                  |                    |                            |                                 |   |                                 |
| Antelope                              | 450              | 1.4                | 35                         | 5,200                           | 13.5                                      | 22.8                            |
| Castaic                               | 275              | 1.4                | 58                         | 4,030                           | 20.5                                      | 10.7                            |
| Del Valle                             | 400              | 1.1                | 31                         | 3,450                           | 13.5                                      | 16.0                            |
| Palermo                               | 400              | 1.5                | 43                         | 4,023                           | 13.5                                      | 14.5                            |
| Paradise                              | 300              | 1.2                | 46                         | 3,160                           | 13.5                                      | 10.7                            |
| Subtotal                              | 1 825            | 6.6                |                            |                                 |   |                                 |
| TOTAL                                 | 112 230          | 483.9              |                            |                                 |   |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate.

Table E-2.3. CANALS

| Facility                              | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kWh) |
|---------------------------------------|------------------|--------------------|---------------------------|---------------------------------|---|---------------------------------|
| <u>Capacities greater than 500 kW</u> |                  |                    |                           |                                 |   |                                 |
| Canal Creek                           | 940              | 3.3                | 40                        | 1,540                           | 13.0                                      | 5.7                             |
| Fairfield Drop                        | 970              | 2.8                | 33                        | 1,380                           | 13.0                                      | 6.3                             |
| Frankenheimer Drop                    | 4,700            | 17.0               | 41                        | 1,320                           | 12.0                                      | 4.4                             |
| Madera Canal<br>Station 980+65        | 2,000            | 5.5                | 31                        | 840                             | 12.5                                      | 3.8                             |
| Richard B. Parker<br>(Main Canal)     | 2,800            | 9.2                | 38                        | 1,400                           | 12.5                                      | 5.4                             |
| Stone Drop                            | 1,000            | 4.0                | 46                        | 2,390                           | 13.0                                      | 9.6                             |
| Turlock Main Canal                    | 3,260            | 12.2               | 43                        | 1,170                           | 12.0                                      | 3.7                             |
| Drop No. 2                            | 660              | 2.1                | 36                        | 1,800                           | 13.5                                      | 7.6                             |
| Drop No. 6                            | 920              | 2.9                | 36                        | 1,620                           | 13.0                                      | 6.7                             |
| Drop No. 7                            | 700              | 2.1                | 34                        | 1,770                           | 13.5                                      | 8.0                             |
| Subtotal                              | 17 950           | 61.1               |                           |                                 |   |                                 |
| <u>Capacities 500 kW or less</u>      |                  |                    |                           |                                 |   |                                 |
| Escaladlan Headworks                  | 270              | 0.8                | 34                        | 1,870                           | 13.5                                      | 8.3                             |
| Subtotal                              | 270              | 0.8                |                           |                                 |   |                                 |
| TOTAL                                 | 18 220           | 61.9               |                           |                                 |   |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-2.4. PIPELINES

| Facility                              | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(\$) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kWh) |
|---------------------------------------|------------------|--------------------|----------------------------|---------------------------------|---|---------------------------------|
| <u>Capacities greater than 500 kW</u> |                  |                    |                            |                                 |   |                                 |
| Lytle Creek                           | 1 300            | 7.8                | 68                         | 2,130                           | 13.0                                      | 4.6                             |
| Mojave Siphon No. 1                   | 6 000            | 47.0               | 89                         | 4,030                           | 12.0                                      | 6.2                             |
| Santa Ana Low                         | 1 400            | 3.8                | 31                         | 1,660                           | 13.0                                      | 8.0                             |
| Sweetwater Turnout                    | 875              | 2.2                | 29                         | 2,350                           | 13.0                                      | 12.2                            |
| Waterman Canyon                       | 4 000            | 7.0                | 20                         | 1,090                           | 12.0                                      | 7.5                             |
| Subtotal                              | 13 575           | 67.8               |                            |                                 |   |                                 |
| <u>Capacity of 500 kW or less</u>     |                  |                    |                            |                                 |   |                                 |
| Las Flores Turnout                    | 210              | 0.7                | 38                         | 4,750                           | 13.5                                      | 20.0                            |
| Subtotal                              | 210              | 0.7                |                            |                                 |   |                                 |
| TOTAL                                 | 13 785           | 68.5               |                            |                                 |   |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

## Section E-3

## Facilities With Only Limited Data (Questionnaire Responses)

Table E-3.1. Comparison of All Categories

| Type of Facility               | Number of Facilities | Capacity (kW) | Energy (GWh/yr) |
|--------------------------------|----------------------|---------------|-----------------|
| Dams: Greater than 500 kW      | 49                   | 176 820       | 523             |
| 500 kW or less                 | 51                   | 8 125         | 36              |
| Subtotal                       | 100                  | 184 945       | 559             |
| Canals: Greater than 500 kW    | 18                   | 65 170        | 363             |
| 500 kW or less                 | 14                   | 3 395         | 16              |
| Subtotal                       | 32                   | 68 565        | 379             |
| Pipelines: Greater than 500 kW | 42                   | 107 030       | 597             |
| 500 kW or less                 | 41                   | 7 285         | 36              |
| Subtotal                       | 83                   | 114 315       | 633             |
| TOTAL                          | 215                  | 367 825       | 1 571           |

Table E-3.2. DAMS

| Facility   | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(%) | 1984<br>Energy Cost<br>(\$/kwh) |
|--|------------------|--------------------|---------------------------|---------------------------------|--|---------------------------------|
| <u>Capacities greater than 500 kW</u>            |                  |                    |                           |                                 |  |                                 |
| Bear Valley Powerplant<br>Rehabilitation         | 700              | 3.7                | 60                        | 2 600                           | 13.5                                     | 6.6                             |
| Boca   | 2 000            | 5.6                | 32                        | 1,900                           | 12.5                                     | 8.5                             |
| Bucks Lake (Bucks Storage)                       | 740              | 3.2                | 49                        | 2,550                           | 13.5                                     | 8.0                             |
| Calaveras  | 700              | 3.2                | 52                        | 2,600                           | 13.5                                     | 7.7                             |
| Camanche   | 10 680           | 35.0               | 37                        | 1,500                           | 12.0                                     | 5.5                             |
| Camp Far West                                    | 6 800            | 26.9               | 45                        | 1,550                           | 12.0                                     | 4.7                             |
| Casitas  | 700              | 2.0                | 33                        | 2,600                           | 13.5                                     | 12.3                            |
| Cogswell   | 500              | 3.0                | 68                        | 3,100                           | 13.5                                     | 7.0                             |
| Early Intake                                     | 1 300            | 8.7                | 76                        | 2,050                           | 13.0                                     | 4.0                             |
| East Park  | 900              | 2.0                | 25                        | 2,300                           | 13.0                                     | 13.5                            |
| Farmington                                       | 1 400            | 2.0                | 21                        | 2,100                           | 13.0                                     | 15.0                            |
| Gibraltar  | 1 500            | 4.0                | 30                        | 2,000                           | 13.0                                     | 9.8                             |
| Grant Lake                                       | 1 500            | 3.0                | 23                        | 2,000                           | 13.0                                     | 13.0                            |
| Hell Hole Reservoir                              | 550              | 3.0                | 62                        | 2,975                           | 13.5                                     | 7.4                             |
| Hensley Lake (Hidden Dam)                        | 1 300            | 4.0                | 35                        | 2,050                           | 13.0                                     | 8.7                             |
| Hetch Hetchy Reservoir<br>(O'Shaughnessy Dam)    | 1 600            | 6.0                | 43                        | 2,000                           | 13.0                                     | 6.9                             |
| Hume Lake  | 1 050            | 4.6                | 50                        | 2,150                           | 13.0                                     | 6.4                             |
| H. V. Eastman Lake<br>(Buchanan Dam)             | 3 000            | 9.0                | 34                        | 1,700                           | 12.5                                     | 7.1                             |
| Ice House Reservoir                              | 10 000           | 22.0               | 25                        | --                              | --                                       | --                              |
| Isabella   | 13 000           | 45.0               | 39                        | 1,400                           | 12.0                                     | 4.6                             |
| Lake Clementine<br>(North Fork Dam)              | 12 000           | 63.5               | 60                        | 1,400                           | 12.0                                     | 3.1                             |
| Lake Fordyce                                     | 900              | 4.0                | 51                        | 2,300                           | 13.0                                     | 6.7                             |
| Lake Hennessey<br>(Conn Creek Dam)               | 500              | 2.3                | 53                        | 3,100                           | 13.5                                     | 9.1                             |
| Lake Kaweah<br>(Terminus Dam)                    | 4 000            | 20.0               | 57                        | 1,650                           | 12.0                                     | 4.0                             |
| Lake Mendocino<br>(Coyote Dam)                   | 4 000            | 21.0               | 60                        | 1,650                           | 12.0                                     | 3.8                             |
| Lake Pillsbury<br>(Scott Dam)                    | 5 000            | 15.0               | 34                        | 1,600                           | 12.0                                     | 6.4                             |
| Lake Piru<br>(Santa Felicia Dam)                 | 3 600            | 7.8                | 25                        | 1,650                           | 12.0                                     | 9.1                             |
| Lake Siskiyou<br>(Box Canyon Dam)                | 6 000            | 21.9               | 42                        | 1,600                           | 12.0                                     | 5.3                             |
| Lake Thomas A. Edison<br>(Vermillion Valley Dam) | 2 000            | 8.6                | 49                        | 1,900                           | 12.5                                     | 5.5                             |
| Lake Yosemite                                    | 1 200            | 2.3                | 22                        | 2,050                           | 13.0                                     | 13.9                            |
| Lexington  | 500              | 2.9                | 66                        | 3,100                           | 13.5                                     | 7.2                             |
| Little Grass Valley                              | 2 600            | 6.5                | 29                        | 1,750                           | 12.5                                     | 8.8                             |
| Los Angeles Reservoir                            | 6 200            | 37.0               | 68                        | 1,600                           | 12.0                                     | 3.2                             |
| Matilija   | 700              | 2.0                | 33                        | 2,600                           | 13.5                                     | 12.3                            |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-3.2. DAMS (Continued)

| Facility  | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(%) | 1984<br>Energy Cost<br>(\$/kWh) |
|---|------------------|--------------------|---------------------------|---------------------------------|--|---------------------------------|
| <u>Capacities greater than 500 kW (continued)</u> |                  |                    |                           |                                 |  |                                 |
| McCloud   | 1 200            | 5.4                | 51                        | 2,050                           | 13.0                                     | 5.9                             |
| Moccasin Lower                                    | 1 600            | 7.0                | 50                        | 1,950                           | 13.0                                     | 5.8                             |
| New Hogan   | 2 250            | 9.5                | 48                        | 1,850                           | 12.5                                     | 5.5                             |
| Palo Verde Diversion                              | 8 700            | 65.0               | 85                        | 1,500                           | 13.0                                     | 2.6                             |
| Ponderosa Diversion                               | 3 300            | 14.0               | 48                        | 1,700                           | 12.5                                     | 5.0                             |
| Prosser Creek                                     | 1 000            | 3.5                | 40                        | 2,150                           | 13.0                                     | 8.0                             |
| Red Bluff Diversion                               | 14 000           | 70.0               | 73                        | 1,400                           | 12.0                                     | 3.4                             |
| Rindge  | 600              | 0.9                | 17                        | 2,850                           | 13.5                                     | 25.7                            |
| Robert A. Skinner                                 | 1 400            | 6.3                | 51                        | 2,000                           | 13.0                                     | 5.8                             |
| Ruth Reservoir<br>(Robert W. Matthews Dam)        | 4 600            | 14.2               | 41                        | 1,650                           | 12.0                                     | 5.6                             |
| Sand Bar Project                                  | 12 000           | 70.0               | 67                        | 1,400                           | 12.0                                     | 2.9                             |
| San Gabriel Dam                                   | 500              | 3.0                | 68                        | 3,100                           | 13.5                                     | 7.0                             |
| Scotts Flat Dam                                   | 1 300            | 5.5                | 48                        | 2,050                           | 13.0                                     | 6.3                             |
| Spicers Meadows                                   | 750              | 3.3                | 50                        | 2,550                           | 13.5                                     | 7.8                             |
| Stony Gorge Dam                                   | 6 000            | 18.0               | 27                        | 1,600                           | 12.0                                     | 6.4                             |
| Success   | 4 000            | 12.0               | 34                        | 1,650                           | 12.0                                     | 6.6                             |
| Tinemaha  | 1 600            | 8.3                | 59                        | 1,950                           | 13.0                                     | 4.9                             |
| Warm Springs                                      | 3 000            | 15.0               | 57                        | 1,700                           | 12.5                                     | 4.3                             |
| West Valley                                       | 900              | 3.8                | 48                        | 2,300                           | 13.0                                     | 7.1                             |
| Subtotal  | 176 820          | 523.2              |                           |                                 |  |                                 |
| <u>Capacities 500 kW or less</u>                  |                  |                    |                           |                                 |  |                                 |
| Alamitos  | 300              | 1.0                | 38                        | 3,900                           | 13.5                                     | 15.8                            |
| Allsal Creek                                      | 50               | 0.2                | 46                        | 5,600                           | 19.5                                     | 27.3                            |
| Anthony House                                     | 50               | 0.2                | 46                        | 5,600                           | 19.5                                     | 27.3                            |
| Barrett   | 60               | 0.2                | 38                        | 5,600                           | 19.5                                     | 32.8                            |
| Big Dalton  | 50               | 0.1                | 23                        | 5,600                           | 19.0                                     | 53.2                            |
| Big Sage  | 175              | 0.7                | 46                        | 4,700                           | 14.0                                     | 16.5                            |
| Big Tujunga No. 1                                 | 300              | 1.3                | 49                        | 3,900                           | 13.5                                     | 12.2                            |
| Calero  | 100              | 0.5                | 57                        | 5,450                           | 15.0                                     | 16.4                            |
| Clear Lake  | 430              | 1.9                | 50                        | 3,350                           | 13.5                                     | 10.2                            |
| Concow  | 130              | 0.4                | 35                        | 5,100                           | 14.5                                     | 24.0                            |
| Coyote Creek                                      | 90               | 0.4                | 51                        | 5,450                           | 15.0                                     | 18.3                            |
| Doris   | 50               | 0.1                | 23                        | 5,600                           | 19.5                                     | 54.6                            |
| Farmington  | 400              | 2.0                | 57                        | 3,450                           | 13.5                                     | 9.3                             |
| French Lake                                       | 200              | 0.8                | 46                        | 4,500                           | 14.0                                     | 15.8                            |
| Guadalupe   | 60               | 0.3                | 57                        | 5,600                           | 19.5                                     | 21.8                            |
| Hell Hole Reservoir                               | 550              | 3.0                | 86                        | 2,985                           | 13.5                                     | 7.4                             |
| Henshaw   | 200              | 1.0                | 57                        | 4,500                           | 14.0                                     | 12.6                            |
| Hour House  | 100              | 0.3                | 34                        | 5,450                           | 15.0                                     | 27.3                            |
| Indian Creek Dam                                  | 50               | 0.1                | 23                        | 5,600                           | 19.5                                     | 54.6                            |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-3.2. DAMS (Continued)

| Facility                               | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(%) | 1984<br>Energy Cost<br>(\$/kWh) |
|--|------------------|--------------------|---------------------------|---------------------------------|--|---------------------------------|
| Capacities 500 kW or less (continued)  |                  |                    |                           |                                 |  |                                 |
| Jameson Lake (Juncal Dam)              | 60               | 0.4                | 76                        | 5,550                           | 19.0                                     | 15.8                            |
| Kent Lake (Peters Dam)                 | 150              | 0.4                | 30                        | 4,950                           | 14.0                                     | 26.0                            |
| Lake Arrowhead                         | 75               | 0.3                | 46                        | 5,500                           | 17.5                                     | 24.1                            |
| Lake Eleanor                           | 60               | 0.3                | 57                        | 5,550                           | 19.0                                     | 21.1                            |
| Lake Hemet                             | 75               | 0.1                | 15                        | 5,500                           | 17.5                                     | 72.2                            |
| Lake Hodges                            | 270              | 1.2                | 51                        | 4,150                           | 13.5                                     | 12.6                            |
| Lake Loveland                          | 100              | 0.5                | 57                        | 5,450                           | 15.0                                     | 16.4                            |
| Lake Valley                            | 75               | 0.3                | 46                        | 5,500                           | 17.5                                     | 24.1                            |
| Littlerock Dam                         | 50               | 0.2                | 46                        | 5,600                           | 19.5                                     | 27.3                            |
| Lopez                                  | 50               | 0.4                | 91                        | 5,600                           | 19.5                                     | 13.7                            |
| Los Banos Detention                    | 100              | 0.5                | 57                        | 5,450                           | 15.0                                     | 16.4                            |
| Los Padres                             | 75               | 0.3                | 46                        | 5,500                           | 17.5                                     | 24.1                            |
| Lyons                                  | 300              | 1.5                | 57                        | 3,900                           | 13.5                                     | 10.5                            |
| Martis Creek                           | 250              | 1.1                | 50                        | 4,200                           | 13.5                                     | 12.9                            |
| McCoy Flat                             | 50               | 0.2                | 46                        | 5,600                           | 19.5                                     | 27.3                            |
| Nicasio                                | 400              | 1.7                | 49                        | 3,450                           | 13.5                                     | 11.0                            |
| Pacheco Lake<br>(North Fork Dam)       | 60               | 0.3                | 57                        | 5,600                           | 19.5                                     | 21.8                            |
| Pacolma                                | 400              | 1.0                | 29                        | 3,450                           | 13.5                                     | 18.6                            |
| Pilarcitos                             | 200              | 0.8                | 46                        | 4,500                           | 14.0                                     | 15.8                            |
| Rector Creek                           | 100              | 0.5                | 57                        | 5,450                           | 15.0                                     | 16.4                            |
| Round Valley                           | 90               | 0.4                | 51                        | 5,450                           | 15.0                                     | 18.4                            |
| Salt Spring Valley<br>Reservoir        | 90               | 0.4                | 51                        | 5,450                           | 15.0                                     | 18.4                            |
| San Dimas                              | 100              | 0.3                | 34                        | 5,450                           | 15.0                                     | 27.3                            |
| Santa Anita                            | 300              | 0.7                | 27                        | 3,900                           | 13.5                                     | 22.6                            |
| Schaads Reservoir<br>(Middle Fork Dam) | 75               | 0.4                | 57                        | 5,500                           | 15.5                                     | 16.0                            |
| Slab Creek                             | 400              | 3.0                | 86                        | 3,450                           | 13.5                                     | 6.2                             |
| Stevens Creek                          | 75               | 0.3                | 46                        | 5,500                           | 17.5                                     | 24.1                            |
| Stone Canyon                           | 300              | 2.0                | 76                        | 3,900                           | 13.5                                     | 7.9                             |
| Tule Lake                              | 75               | 0.3                | 46                        | 5,500                           | 17.5                                     | 24.1                            |
| Vail                                   | 200              | 0.9                | 51                        | 4,500                           | 14.0                                     | 14.0                            |
| Webber                                 | 75               | 0.3                | 46                        | 5,500                           | 17.5                                     | 24.1                            |
| White Pines                            | 100              | 0.4                | 46                        | 5,450                           | 15.0                                     | 20.4                            |
| Subtotal                               | 8 125            | 35.9               |                           |                                 |  |                                 |
| TOTAL                                  | 184 945          | 559.1              |                           |                                 |  |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-3.3. CANALS

| Facility                               | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(%) | 1984<br>Energy Cost<br>(¢/kWh) |
|--|------------------|--------------------|---------------------------|---------------------------------|--|--------------------------------|
| <u>Capacities greater than 500 kW</u>  |                  |                    |                           |                                 |  |                                |
| All American Canal<br>Drop No. 1       | 4 700            | 27.0               | 66                        | 1,600                           | 12.0                                     | 3.3                            |
| All American Canal<br>Drop No. 5       | 5 000            | 24.0               | 55                        | 1,600                           | 12.0                                     | 4.0                            |
| Ceres Spillway                         | 2 100            | 4.5                | 24                        | 1,850                           | 12.5                                     | 10.8                           |
| Cottonwood No. 1                       | 17 000           | 115.0              | 77                        | 1,650                           | 12.0                                     | 2.9                            |
| Cottonwood No. 2                       | 12 000           | 90.0               | 86                        | 1,400                           | 12.0                                     | 2.2                            |
| East Highline Canal                    | 1 800            | 10.0               | 63                        | 1,950                           | 12.5                                     | 4.4                            |
| Fresno Main Canal                      |                  |                    |                           |                                 |  |                                |
| Headworks                              | 650              | 2.6                | 46                        | 2,700                           | 13.5                                     | 9.1                            |
| Boos Check                             | 650              | 2.6                | 46                        | 2,700                           | 13.5                                     | 9.1                            |
| Dresser Check                          | 650              | 2.6                | 46                        | 2,700                           | 13.5                                     | 9.1                            |
| Hickman Spillway                       | 2 100            | 4.5                | 24                        | 1,850                           | 12.5                                     | 10.8                           |
| Kern Island Canal<br>Control Structure | 700              | 3.1                | 51                        | 2,600                           | 13.5                                     | 7.9                            |
| Madera Canal                           |                  |                    |                           |                                 |  |                                |
| Station 1064+67                        | 560              | 1.9                | 39                        | 2,975                           | 13.5                                     | 11.8                           |
| Station 1910+60                        | 650              | 2.6                | 46                        | 2,700                           | 13.5                                     | 9.1                            |
| New Siphon Drop                        | 1 410            | 11.3               | 92                        | 2,000                           | 13.0                                     | 3.2                            |
| People's Weir                          | 2 200            | 3.5                | 18                        | 1,850                           | 12.5                                     | 14.5                           |
| South Canal                            | 8 000            | 37.0               | 53                        | 1,550                           | 12.0                                     | 4.0                            |
| Upper Dawson Power Plant               | 4 000            | 15.9               | 45                        | 1,650                           | 12.0                                     | 5.0                            |
| Volta No. 2 Powerhouse                 | 1 000            | 5.0                | 57                        | 2,150                           | 13.0                                     | 6.0                            |
| Subtotal                               | 65 170           | 363.1              |                           |                                 |  |                                |
| <u>Capacities of 500 kW or less</u>    |                  |                    |                           |                                 |  |                                |
| Ash Main Canal                         | 150              | 0.7                | 53                        | 4,950                           | 14.0                                     | 14.9                           |
| Beardsley Canal Control<br>Structure   | 260              | 1.1                | 48                        | 4,200                           | 13.5                                     | 13.4                           |
| Buhach Drop                            | 60               | 0.3                | 57                        | 5,600                           | 19.5                                     | 21.8                           |
| Califa                                 | 200              | 0.9                | 51                        | 4,500                           | 14.0                                     | 14.0                           |
| Chowchilla Main Canal                  |                  |                    |                           |                                 |  |                                |
| Station 0+00                           | 250              | 1.1                | 50                        | 4,200                           | 13.5                                     | 12.9                           |
| Station 101+80                         | 250              | 1.1                | 50                        | 4,200                           | 13.5                                     | 12.9                           |
| Station 175+00                         | 250              | 1.1                | 50                        | 4,200                           | 13.5                                     | 12.9                           |
| Dehlia Drop                            | 225              | 1.0                | 51                        | 4,350                           | 13.5                                     | 13.2                           |
| Dodge Ave Check                        | 475              | 2.4                | 58                        | 3,200                           | 13.5                                     | 8.6                            |
| Fisher Drop                            | 75               | 0.3                | 46                        | 5,500                           | 17.5                                     | 24.1                           |
| Newside Drop                           | 200              | 0.9                | 51                        | 4,500                           | 14.0                                     | 14.0                           |
| Parker Drop                            | 300              | 0.8                | 30                        | 3,900                           | 13.5                                     | 19.7                           |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-3.3. CANALS (Continued)

| Facility  | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kWh) |
|---|------------------|--------------------|---------------------------|---------------------------------|---|---------------------------------|
| <u>Capacities of 500 kW or less (continued)</u> |                  |                    |                           |                                 |   |                                 |
| Sand Creek Check                                | 200              | 1.5                | 86                        | 4,500                           | 14.0                                      | 8.4                             |
| Tuberoso Check                                  | 200              | 1.3                | 74                        | 4,500                           | 14.5                                      | 10.0                            |
| Upper Main Canal                                | 200              | 0.9                | 51                        | 4,500                           | 14.0                                      | 14.0                            |
| Youd Drop                                       | 100              | 0.5                | 57                        | 5,450                           | 15.0                                      | 16.4                            |
| Subtotal  | 3 395            | 15.9               |                           |                                 |   |                                 |
| TOTAL   | 68 565           | 379.0              |                           |                                 |   |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-3.4. PIPELINES

| Facility                              | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(%) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kwh) |
|---------------------------------------|------------------|--------------------|---------------------------|---------------------------------|---|---------------------------------|
| <b>Capacities greater than 500 kW</b> |                  |                    |                           |                                 |   |                                 |
| Alvarado Treatment Plant              | 1 700            | 8.4                | 56                        | 1,950                           | 13.0                                      | 5.1                             |
| Azusa Flow Control<br>Structure       | 740              | 3.2                | 49                        | 2,550                           | 13.5                                      | 8.0                             |
| Balboa                                | 1 200            | 9.1                | 87                        | 2,050                           | 13.0                                      | 3.5                             |
| Big Creek Hydroelectric<br>Plant      | 800              | 3.0                | 43                        | 2,450                           | 13.5                                      | 8.8                             |
| Cache Slough                          | 600              | 4.1                | 50                        | 2,850                           | 13.5                                      | 5.6                             |
| Carneros Power Project                | 700              | 1.6                | 26                        | 2,600                           | 13.5                                      | 15.4                            |
| Conejo Pump Station                   | 600              | 3.0                | 57                        | 2,850                           | 13.5                                      | 7.7                             |
| City Creek Turnout                    | 2 000            | 3.0                | 17                        | 1,900                           | 12.5                                      | 15.8                            |
| Corona                                | 2 800            | 13.0               | 73                        | 1,700                           | 12.5                                      | 3.3                             |
| Covina                                | 2 500            | 16.9               | 77                        | 1,800                           | 12.5                                      | 3.3                             |
| Coyote Creek                          | 2 900            | 19.6               | 77                        | 1,700                           | 12.5                                      | 3.1                             |
| Dominguez Gap Barrier                 | 500              | 2.0                | 46                        | 3,100                           | 13.5                                      | 10.5                            |
| Eastside Pipeline                     | 1 000            | 3.0                | 34                        | 2,150                           | 13.0                                      | 9.3                             |
| El Segundo Distribution<br>System     | 500              | 3.9                | 89                        | 3,100                           | 13.5                                      | 5.4                             |
| Folsom Lake Pipeline                  | 500              | 2.4                | 55                        | 3,100                           | 13.5                                      | 8.7                             |
| Franklin Inlet                        | 800              | 6.8                | 97                        | 2,450                           | 13.5                                      | 3.9                             |
| Highland Avenue Pumping<br>Plant      | 600              | 2.6                | 49                        | 2,850                           | 13.5                                      | 8.9                             |
| Irvine Lake Pipeline                  | 500              | 1.0                | 23                        | 3,100                           | 13.5                                      | 20.9                            |
| Lateral A                             | 1 600            | 7.0                | 50                        | 1,950                           | 13.0                                      | 5.8                             |
| Lateral B                             | 900              | 4.0                | 51                        | 2,300                           | 13.0                                      | 6.7                             |
| Los Angeles Distribution System       |                  |                    |                           |                                 |   |                                 |
| Location 1                            | 610              | 3.3                | 62                        | 2,850                           | 13.5                                      | 7.1                             |
| Location 15                           | 1 000            | 8.2                | 94                        | 2,150                           | 13.0                                      | 3.4                             |
| Location 16                           | 1 800            | 9.0                | 57                        | 1,950                           | 12.5                                      | 4.9                             |
| Miramar Treatment Plant               | 1 300            | 5.7                | 50                        | 2,050                           | 13.0                                      | 6.1                             |
| Mojave Siphon No. 2                   | 10 000           | 78.0               | 89                        | 1,500                           | 12.0                                      | 2.3                             |
| Orange County 28                      | 6 300            | 12.0               | 22                        | 1,600                           | 12.0                                      | 10.1                            |
| Orange County 59                      | 5 000            | 9.4                | 21                        | 1,600                           | 12.0                                      | 10.2                            |
| Perris Power Project                  | 7 900            | 40.3               | 58                        | 1,550                           | 12.0                                      | 3.6                             |
| Point Loma Treatment Plant            | 1 200            | 8.0                | 76                        | 2,050                           | 13.0                                      | 4.0                             |
| Reservoir A                           | 730              | 3.2                | 50                        | 2,550                           | 13.5                                      | 7.9                             |
| Rio Hondo                             | 2 000            | 12.3               | 70                        | 1,900                           | 13.0                                      | 4.0                             |
| San Dieguito Treatment<br>Plant       | 1 000            | 4.5                | 51                        | 2,150                           | 13.0                                      | 6.2                             |
| San Dimas                             | 9 900            | 68.2               | 79                        | 1,500                           | 12.0                                      | 2.6                             |
| Santiago Creek                        | 3 000            | 15.6               | 59                        | 1,700                           | 12.5                                      | 4.1                             |
| San Vicente Reservoir                 | 850              | 3.4                | 46                        | 2,375                           | 13.0                                      | 7.7                             |
| Sepulveda Canyon                      | 8 600            | 56.2               | 75                        | 1,500                           | 12.0                                      | 2.8                             |
| Sweetwater Treatment<br>Plant         | 1 400            | 6.3                | 51                        | 1,840                           | 13.0                                      | 9.5                             |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-3.4. PIPELINES (Continued)

| Facility  | Capacity<br>(kW) | Energy<br>(Gwh/yr) | Capacity<br>Factor<br>(\$) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kWh) |
|---|------------------|--------------------|----------------------------|---------------------------------|---|---------------------------------|
| <u>Capacities greater than 500 kW (continued)</u> |                  |                    |                            |                                 |   |                                 |
| Temescal  | 2 800            | 18.0               | 73                         | 1,700                           | 12.5                                      | 3.3                             |
| Valley View                                       | 2 400            | 14.2               | 68                         | 1,800                           | 12.5                                      | 3.8                             |
| Van Owen Regulating Dam                           | 600              | 5.0                | 95                         | 2,850                           | 13.5                                      | 4.6                             |
| Venice  | 10 100           | 60.0               | 68                         | 1,500                           | 12.0                                      | 3.0                             |
| Yorba Linda Feeder                                | 5 100            | 33.5               | 75                         | 1,600                           | 12.0                                      | 2.9                             |
| Subtotal  | 107 030          | 596.9              |                            |                                 |   |                                 |
| <u>Capacities of 500 kW or less</u>               |                  |                    |                            |                                 |   |                                 |
| Big Dalton Station                                | 280              | 1.2                | 49                         | 4,150                           | 13.5                                      | 13.1                            |
| Buffalo Hill Siphon                               | 160              | 0.5                | 36                         | 4,950                           | 14.0                                      | 22.2                            |
| Central Amador<br>Water Project                   | 250              | 0.7                | 32                         | 4,200                           | 13.5                                      | 20.3                            |
| Deer Creek Collection                             | 200              | 1.0                | 57                         | 4,500                           | 14.0                                      | 12.2                            |
| El Dorado Dist. System                            |                  |                    |                            |                                 |   |                                 |
| Reservoir 2                                       | 50               | 0.2                | 46                         | 5,600                           | 19.5                                      | 27.3                            |
| Reservoir 2A                                      | 480              | 2.1                | 50                         | 3,200                           | 13.5                                      | 9.9                             |
| Reservoir 2A-3                                    | 360              | 1.6                | 51                         | 3,650                           | 13.5                                      | 11.1                            |
| Reservoir 3                                       | 200              | 0.9                | 51                         | 4,500                           | 14.0                                      | 14.0                            |
| Reservoir 5                                       | 60               | 0.3                | 57                         | 5,600                           | 19.5                                      | 21.8                            |
| Reservoir 6                                       | 80               | 0.3                | 43                         | 5,500                           | 16.5                                      | 22.7                            |
| Reservoir 8                                       | 175              | 0.8                | 52                         | 4,700                           | 14.0                                      | 14.4                            |
| Reservoir 9A                                      | 175              | 0.8                | 52                         | 4,700                           | 14.0                                      | 14.4                            |
| Reservoir 9B                                      | 90               | 0.4                | 51                         | 5,450                           | 16.0                                      | 18.4                            |
| Reservoir 10A                                     | 175              | 0.8                | 52                         | 4,700                           | 14.0                                      | 14.4                            |
| Reservoir 10B                                     | 60               | 0.3                | 57                         | 5,600                           | 19.5                                      | 21.8                            |
| Emerald Pressure Reducing<br>Station              | 340              | 1.5                | 50                         | 3,700                           | 13.5                                      | 11.3                            |
| Etiwanda Pressure Reducing<br>Station             | 250              | 1.1                | 50                         | 4,200                           | 13.5                                      | 12.9                            |
| Jackson-Sutter Creek<br>Outfall Pipeline          | 60               | 0.2                | 38                         | 5,550                           | 19.0                                      | 31.6                            |
| Kaiser Pipeline                                   | 120              | 0.3                | 29                         | 5,100                           | 14.5                                      | 29.1                            |
| Lake Curry  | 50               | 0.2                | 46                         | 5,600                           | 19.5                                      | 27.3                            |
| Lake Davis-Portola Pipeline                       | 60               | 0.3                | 57                         | 5,600                           | 19.5                                      | 21.8                            |
| Lake Eleanor                                      | 60               | 0.3                | 57                         | 5,600                           | 19.5                                      | 21.8                            |
| Lake Mary & Twin Lakes<br>Open Diversion          | 300              | 0.8                | 30                         | 3,900                           | 13.5                                      | 19.7                            |
| Los Angeles Dist. System                          |                  |                    |                            |                                 |   |                                 |
| Location 2  | 270              | 2.2                | 93                         | 4,150                           | 13.5                                      | 6.9                             |
| Location 3  | 420              | 2.1                | 57                         | 3,400                           | 13.5                                      | 9.1                             |
| Location 4  | 270              | 1.8                | 76                         | 4,150                           | 13.5                                      | 8.4                             |

<sup>1/</sup> For a 35-year term at 9 percent interest rate

Table E-3.4. PIPELINES (Continued)

| Facility  | Capacity<br>(kW) | Energy<br>(GWh/yr) | Capacity<br>Factor<br>(\$) | 1984<br>Project Cost<br>(\$/kW) | Annual<br>Cost Rate <sup>1/</sup><br>(\$) | 1984<br>Energy Cost<br>(\$/kWh) |
|---|------------------|--------------------|----------------------------|---------------------------------|---|---------------------------------|
| <u>Capacities of 500 kW or less (Continued)</u> |                  |                    |                            |                                 |   |                                 |
| Los Angeles Dist. System (Continued)            |                  |                    |                            |                                 |   |                                 |
| Location 5                                      | 140              | 1.2                | 98                         | 4,950                           | 14.0                                      | 8.1                             |
| Location 6                                      | 190              | 1.1                | 72                         | 4,600                           | 14.0                                      | 11.1                            |
| Location 7                                      | 120              | 1.0                | 95                         | 5,150                           | 14.5                                      | 9.0                             |
| Location 8                                      | 130              | 0.8                | 70                         | 5,000                           | 14.5                                      | 11.8                            |
| Location 9                                      | 70               | 0.6                | 98                         | 5,500                           | 18.0                                      | 11.6                            |
| Location 10                                     | 100              | 0.6                | 68                         | 5,450                           | 15.0                                      | 13.6                            |
| Location 11                                     | 70               | 0.6                | 98                         | 5,500                           | 18.0                                      | 11.6                            |
| Location 12                                     | 100              | 0.6                | 68                         | 5,450                           | 15.0                                      | 13.6                            |
| Location 13                                     | 60               | 0.5                | 95                         | 5,550                           | 19.0                                      | 12.7                            |
| Location 14                                     | 60               | 0.5                | 95                         | 5,550                           | 19.0                                      | 12.7                            |
| Mallard Reservoir                               | 200              | 0.9                | 51                         | 4,500                           | 14.0                                      | 14.0                            |
| Redlands Water Treatment<br>Plant               | 200              | 0.9                | 51                         | 4,500                           | 14.0                                      | 14.0                            |
| Sidney N. Peterson Water<br>Treatment Plant     | 175              | 0.4                | 26                         | 4,700                           | 14.0                                      | 28.8                            |
| South Portal Doulton Tunnel                     | 200              | 0.5                | 29                         | 4,500                           | 14.0                                      | 25.2                            |
| Terminal Reservoir Inlet                        | 75               | 0.6                | 91                         | 5,500                           | 15.5                                      | 10.7                            |
| Whitewater Canyon                               | 400              | 2.5                | 71                         | 3,450                           | 13.5                                      | 7.5                             |
| Subtotal  | 7 285            | 36.0               |                            |                                 |   |                                 |
| TOTAL   | 114 315          | 632.9              |                            |                                 |   |                                 |

<sup>1/</sup> For a 35-year term at 9 percent interest rate



APPENDIX F

Permits, Licenses, Certificates, and Other Approvals

Attachments

|   |     |
|---|-----|
| 1. License Exemptions . . . . .   | 347 |
| Exemption of Small Conduit Hydroelectric Facilities . . . . .   | 348 |
| Exemption of Small Hydroelectric Power Projects of<br>5 megawatts or Less (Case-by-Case Basis) . . . . .                        | 354 |
| Exemption of Small Hydroelectric Power Projects of<br>5 megawatts or Less (Proposed Categorical Exemption) . . . . .            | 366 |
| 2. Preliminary Permit . . . . .   | 377 |
| 3. Minor (Short-Form) License . . . . .   | 382 |
| 4. Major Project--Existing Dam . . . . .  | 391 |
| 5. Dredge and Fill Permit . . . . .   | 407 |
| 6. State Water Resources Control Board (Division of Water Rights)   | 411 |
| 7. Application for Approval of Plans and Specifications for the<br>Repair or Alteration of a Dam and Reservoir. . . . .         | 423 |
| 8. Application for Approval of Plans and Specifications for the<br>Construction or Enlargement of a Dam and Reservoir . . . . . | 427 |
| 9. Application for Approval of Plans and/or Recroachment Permit .   | 431 |
| 10. Application for Dredging Permit or Lease of State Lands. . . .  | 435 |
| 11. Notification of Removal of Materials and/or Alteration of<br>of Lake, River, or Streambed Bottom, or Margin . . . . .       | 443 |



## APPENDIX F

### Permits, Licenses, Certificates and Other Approvals

Currently ten or more federal, state, and local agencies have the authority to require and issue permits, licenses, and certificates before a proposed small hydroelectric project can be built and operated. Other federal, state, and local agencies have review privileges over plans for construction and operation and can provide comments to both the site developer and the approving agencies. The site developer must also comply with the provisions of the California Environmental Quality Act of 1970 (CEQA).

If electric generating facilities are to be added to existing dams and other hydraulic structures, some of the authorizing approvals may not be necessary. However, since the approving agency is authorized to decide whether or not its particular permit, license, or certificate is required, the site developer must still provide information to all agencies in each case.

Recent Federal Energy Regulatory Commission (FERC) rules have set alternative licensing procedures for small hydroelectric projects and for installing hydroelectric facilities at existing dams if no significant environmental impact would result from the project. As the lead agency for implementing the National Environmental Policy Act of 1969 (NEPA) with respect to hydroelectric development, FERC also determines if a particular project must have an Environmental Impact Statement (EIS). A project without a significant environmental impact would not need an EIS, and the approval processing period would be shortened significantly.

For similar reasons, building and operating hydroelectric facilities at existing dam or other hydraulic structures in California would usually not require an Environmental Impact Report (EIR). The CEQA process would, however, require an Initial Study to determine whether a Negative Declaration or an EIR should be prepared for the project.

Most approving agencies have rules which determine the type information that an application must contain, and most agencies have forms or formats that must be followed. The permits, licenses, and certificates needed for the construction and operation of a small hydroelectric facility in California and the application procedures for obtaining those approvals are described in this Appendix.


The approving agencies and the subject of their authority are listed in Table F-1, and the general procedures for obtaining the required approvals to develop a site are shown in Figure F.

Table F-1. Agencies Involved in Small Hydroelectric Development

| Agency                                  | Authority   |
|---|---|
| Federal Energy Regulatory Commission    | <ul style="list-style-type: none"> <li>- License Exemptions<br/>(Conduits below 15 MW)<br/>(Projects of 5 MW or less)<br/>(Categorical exemptions.<br/>Category I, greater than<br/>100 kW but not more than<br/>5 MW. Category II, less<br/>than 100 kW.)<sup>1/</sup></li> <li>- Preliminary Permit</li> <li>- Minor License (New or existing -<br/>1.5 MW or less)</li> <li>- Major License (Existing dam<br/>above 1.5 MW.</li> </ul> |
| U. S. Army Corps of Engineers           | <ul style="list-style-type: none"> <li>- Dredge and Fill Permit</li> </ul>  |
| U. S. Forest Service                    | <ul style="list-style-type: none"> <li>- Special Use Permit</li> </ul>  |
| U. S. Bureau of Land Management         | <ul style="list-style-type: none"> <li>- Right-of-Way Permit</li> </ul>   |
| U. S. Water and Power Resources Service | <ul style="list-style-type: none"> <li>- Right-of-Entry Permit</li> </ul>   |
| Lead Agency (Environmental)             | <ul style="list-style-type: none"> <li>- Environmental Impact Report</li> <li>- Negative Declaration</li> </ul>   |
| State Water Resources Control Board     | <ul style="list-style-type: none"> <li>- Water Rights Permit</li> <li>- Water Quality Certificate</li> </ul>  |
| Department of Water Resources           | <ul style="list-style-type: none"> <li>- Dam Safety Approval</li> <li>- Floodway Permit</li> </ul>  |
| State Lands Commission                  | <ul style="list-style-type: none"> <li>- Land Use Lease</li> <li>- Dredging Permit</li> </ul>   |
| Department of Fish and Game             | <ul style="list-style-type: none"> <li>- Stream or Lake<br/>Alteration Permit</li> </ul>  |
| Office of State Treasurer               | <ul style="list-style-type: none"> <li>- Financial Supervision</li> </ul>   |
| Counties or Special Districts           | <ul style="list-style-type: none"> <li>- General Plan Amendments,<br/>Rezoning, Use Permits<br/>and Variances</li> <li>- Grading Permits</li> <li>- Building Permits</li> </ul>   |

<sup>1/</sup> FERC proposed rulemaking issued December 22, 1980, Docket No. RM81-7.

**Figure F**  
**Approval Process for Small Hydroelectric Projects at Existing Facilities**



## FEDERAL APPROVAL PROCESSES

### FERC Licensing Process

The rules and regulations for the FERC licensing process are set forth in Chapter I of Title 18 of the Code of Federal Regulations. A copy of Title 18 is published each April and can be obtained from:

Superintendent of Documents  
U. S. Government Printing Office  
Washington D.C. 20402.

Since 1978, FERC has thoroughly reformed its requirements and procedures for license applications. These changes resulted from the enactment of the Public Utility Regulatory Policies Act of 1978 (PURPA).

The FERC licensing process applies to any proposed hydroelectric project to be located on federal lands or facilities, on a stream that is on or may affect a navigable waterway, or transmission of power across, along, from or in any streams, bodies of water or land under the jurisdiction of United States. The possibility that a project may affect the navigable waterways of the United States, subjects nearly every proposed hydroelectric development to FERC licensing.

The first step in the FERC licensing process may be to obtain a Preliminary Permit. The Preliminary Permit secures for the permittee priority of license application for a project while the permittee obtains data and determines the feasibility of the project and prepares an application for a license. The Preliminary Permit is not a prerequisite to a license. FERC will not accept applications for license from other developers until the permittee has submitted an application for license or has notified FERC that it will not seek a license. The Permit is issued for a period not to exceed three years.

If two or more applications are submitted for a Preliminary Permit, the FERC will favor the applicant with the better adapted plans to develop, conserve, and utilize, in the public interest, the water resources of the region, taking into consideration the ability of each applicant to carry out its plans. If the plans of the applicants are equally well adapted, the FERC will favor the applicant whose application was first accepted for filing. If a municipality or a state is one of the applicants and the others are not, and the municipality or state's plans are at least as well adapted as the others, the FERC will favor the municipality or the state. Also, the municipality or the state will be given the opportunity to make their plans as well adapted as the others.

Public agencies or private developers applying for loans from the U. S. Department of Energy (DOE) under Title IV of PURPA for a feasibility studies or licensing loans must possess or have filed for a License Exemption or a Preliminary Permit with FERC.

Section 213 of PURPA and Title IV of the Energy Security Act of 1980 authorizes FERC to exempt certain small hydroelectric projects from part or all of Part I of the Federal Power Act, including any licensing

requirement. In April 1980, FERC published its Final Rule (Docket No. RM79-35) exempting small conduit hydroelectric facilities. In November 1980, FERC published its Final Rule (Docket No. RM80-65) exempting small hydroelectric power projects with an installed capacity of 5 MW or less on a case-by-case basis. In December 1980 FERC issued a proposed rulemaking for a generic exemption for two categories with specified characteristics. The first category applies to projects with an installed capacity of less than 100 kW. The second category applies to projects with an installed capacity of more than 100 kW and less than 5 MW. This generic exemption differs from the case-by-case exemption of projects of less than 5 MW. Only projects with specified characteristics, which will not significantly affect the quality of the human environment, are generically exempted. The case-specific procedures address both exemption from licensing and exemption from provisions of Part I of the Act other than licensing.

Projects that are not exempt require applications for a license. To provide the information required for a license application, the site developer must have completed a feasibility study and an environmental assessment. The feasibility study must be detailed enough to include preliminary layout and design drawings, construction cost estimate using the FERC Uniform System of Accounts, proposed project operation procedures, dependable capacity, and the cost of generation. Projects with an installed capacity of 1500 kW or less are considered as minor projects, and require a simpler application. While making the environmental assessments, the site developer must consult with agencies having jurisdiction over recreation, fish and wildlife, historic sites, archaeology, water quality, water rights, and regional planning.

The FERC staff will review an application for its contents and completeness. The applicant can expect to receive a letter from FERC specifying the deficiencies to be corrected. Few applications are complete when initially filed. However, an important aspect of all this is that the original date of filing establishes priority for receiving the permit or license. Supplemental information or corrections will probably have to be filed within 90 days or on some other schedule established by the applicant and FERC.

The processing time for an FERC application will depend on the complexity of the project, whether construction and operation of the project would result in significant environmental impacts, whether there are competing applications and protests, and how fast they can be satisfied. For small hydroelectric projects proposed for existing hydraulic structures, environmental impacts would probably be minimal, if any, thus speeding up the FERC processing time. If FERC determines that the project would result in significant environmental impact, FERC would prepare an EIS in accordance with NEPA. To prepare the EIS, FERC will use information furnished by the applicant in the permit and license applications, and the FERC staff will make an on-site investigation.

The FERC license, when issued, will contain certain conditions that must be met by the site developer. The extent of the conditions will depend on the complexity of the project, and could include minimum fish releases, water discharge restrictions, reservoir level limitations, and construction constraints.

License Exemptions. Developers may apply to FERC for exemption from licensing. The application requirements are substantially less than those for a license application. The exemption application ensures that FERC can discharge its regulatory obligations under Section 213 of PURPA and under NEPA.

Conduits. A hydroelectric facility is eligible for a conduit exemption if it meets the following criteria:

- (1) If it is built, operated, or maintained for the generation of electric power;
- (2) If it is used for the generation of electric power, only the hydroelectric potential of a manmade conduit operated primarily for distributing water for purposes other than generation electricity;
- (3) If it has an installed capacity no greater than 15 MW; and
- (4) If it is located on non-federal lands.

The definition of a "small conduit hydroelectric facility" is a key element in qualifying for an exemption. The facility must discharge the water it uses for power generation:

- (1) into a conduit,
- (2) directly to a point of agricultural, municipal, or industrial use, or
- (3) into a natural water body and an amount of water equal to or greater than the amount discharged from the hydroelectric facility is withdrawn from the water body downstream into a conduit that is part of the same water supply system as the conduit on which the hydroelectric facility is located.

A hydroelectric plant installed at an irrigation dam may or may not be an exemptible facility depending on whether all or a part of the water released for electric generation is also used for agriculture, municipal, and industrial purposes.

An example of an exemptible facility is a hydroelectric plant on a canal where all water flow is used for irrigation, such as the canal owned and operated by the Turlock Irrigation District. A hydroelectric plant installed at a flood control dam would not be an exemptible facility.

After accepting an exemption application, FERC will circulate a notice to responsible parties, including fish and wildlife agencies. Within 90 days after notifying an applicant that his application is acceptable, FERC will grant the exemption as requested, grant an exemption with modifications to the request, deny the exemption, or suspend the 90-day period. If FERC denies the exemption, the applicant can convert the application to a preliminary permit or license application. If FERC does not take any specific action, the application will be considered granted as requested.

The pertinent portions of Code of Federal Regulations governing conduit exemptions (Subpart J) are reproduced in Attachment No. 1.

Projects of 5 MW or Less. Projects meeting the following criteria are eligible to file for a 5 MW exemption from licensing for hydroelectric projects:

- (1) If the project is located entirely on federal lands any person may apply for an exemption.
- (2) If the project is located on non-federal lands, only a person, or group of persons holding all of the real property interests necessary to develop and operate that project (such as ownership in fee, a leasehold, easement, right-of-way, or an option to obtain such interest) may apply for an exemption from licensing.

FERC will not accept for filing an exemption application for any project that is only part of a licensed water project.

The pertinent portions of Code of Federal Regulations governing 5 MW facility exemptions (Subpart K) are reproduced in Attachment No. 1.

Categorical Exemption, 5 MW or less. If the proposed rulemaking (Docket No. RM81-7) is adopted by FERC the provisions for categorical exemptions will be added to the Code of Federal Regulations, Subpart K. The proposed categorical exemptions are reproduced in Attachment No. 1.

Preliminary Permits. In 1979, FERC revised its regulations for filing and processing preliminary permit applications to simplify the application and to provide FERC with sufficient information to reduce the processing time (Order No. 54, Docket No. RM79-23). In order to prepare an application for a preliminary permit, the site developer will need to make a preliminary assessment of the project and its potential generation.

The pertinent portions of Code of Federal Regulations governing preliminary permits (Subpart I) are reproduced in Attachment No. 2.

Minor Licenses. In 1978, the FERC revised its regulations for filing and processing license applications for small hydroelectric projects where the total generating capacity would be 1500 kW or less (Order No. 11, Docket No. RM78-9). The "Application for Short-Form License (Minor)" was designed to simplify the application and reduce the processing time. To prepare an application for a minor project, the developer will need to make a feasibility study and an environmental assessment for the proposed project.

The pertinent portions of Code of Federal Regulations governing minor licenses (Section 131.6) are reproduced in Attachment No. 3.

Major Licenses at Existing Dams. In 1979, FERC revised its regulations for filing and processing license applications for hydroelectric projects where total generating capacities would be greater than 1500 kW (Order No. 59, Docket No. RM79-36). The developer can use this application form where a new hydroelectric facility is proposed for an existing dam provided that

the development will not significantly change the normal maximum surface area of the impoundment and will not make changes in project operation which would result in significant environmental impacts.

The pertinent portions of Code of Federal Regulations governing major licenses (Subpart F) are reproduced in Attachment No. 4.

Inquiries and requests for more information on the various FERC permit and license applications should be directed to

Federal Energy Regulatory Commission  
333 Market Street, Sixth Floor  
San Francisco, CA 94105  
(415) 764-7137

#### U. S. Army Corps of Engineers

Dredge and Fill Permit. The Corps of Engineers is responsible for protecting navigable waters under Section 10 of the River and Harbor Act of 1889 and under the Dredge/Fill and Discharge Program of Section 404 of the Clean Water Act of 1977. The Dredge and Fill Permits protect the quality of water resources, marshes, swamps, and wetlands, and prevent the alteration or obstruction of navigable waterways. A permit is required if a structure, excavation, or discharge of dredged or fill materials will be located in waters of the United States. Not all potential hydroelectric sites at existing hydraulic structures will require a Dredge and Fill Permit; the decision on the need for the permit is made by the District Engineer.

When a Dredge and Fill Permit is required, the applicant must complete ENG Form 4345 available from the Corps of Engineers office in the district where the proposed project will be located. The Corps of Engineers districts in California are defined by watershed. They are: Central Valley and Northern Sierra Mountains, with offices in Sacramento; Northern and Central Coastal Ranges, with offices in San Francisco; and Southern California with offices in Los Angeles.

The Dredge and Fill Permit application is reproduced in Attachment No. 5.

The Corps of Engineers encourages applicants to contact the District Engineer's Office that has jurisdiction over the specific geographic location of the structure or activity before submitting an application. Correspondence should be addressed to the District Engineer, U. S. Army Engineer District, as follows:

|  |  |
|--|--|
| Central Valley and<br>Northern Sierra Mts. | 650 Capitol Mall<br>Sacramento, CA 95814<br>(916) 440-2327   |
| Northern and Central<br>Coastal Ranges     | 211 Main Street<br>San Francisco, CA 94105<br>(415) 556-2752 |

Southern California      P. O. Box 2711  
Los Angeles, CA 90053  
(213) 688-5607

Other Federal Agencies

U. S. Bureau of Land Management. The bureau is a land management agency responsible for all public lands except withdrawals for National parks, for the Forest Service, for the Military, and for others. Hydroelectric projects located on lands administered by the bureau will require rights-of-way.

Information regarding required permits or agreements for hydroelectric projects can be obtained from:

U. S. Bureau of Land Management  
2800 Cottage Way  
Sacramento, CA 95825  
(916) 484-4515

U. S. Forest Service. The Forest Service is also a land management agency and is responsible for National Forest lands. Hydroelectric projects in the National Forests must have a Special Use Permit. Applications for this permit should be submitted to the Forest Supervisor for the National Forest in which the project is located. The information in the FERC license application is generally sufficient for the Special Use Permit.

Inquiries and information regarding the location of the headquarters of each National Forest Supervisor can be obtained from:

Regional Forester  
U. S. Forest Service  
630 Sansome Street  
San Francisco, CA 94111  
(415) 556-0122

U. S. Water and Power Resources Service (WPRS). Non-federal development of WPRS facilities will require Right-of-Entry Permits, and possibly Operational and Reimbursable Agreements with WPRS. These would be in addition to the conditions contained in the FERC license for the project.

Information regarding non-federal development of WPRS facilities can be obtained from:

Northern California

U. S. Water and Power Resources  
Service  
2800 Cottage Way  
Sacramento, CA 95825  
(916) 484-4228

Southern California

U. S. Water and Power Resources  
Service  
P. O. Box 427  
Nevada Highway & Park Street  
Boulder City, NV 89005  
(702) 293-2161

## STATE APPROVAL PROCESS

A developer must comply with the California Environmental Quality Act of 1970 (CEQA) and may be required to obtain certain permits or certificates with respect to water rights, water quality, dam safety, flood plain, and fish and game management. The state agency having jurisdiction will review the developer's plans and determine if a permit is required.

### CEQA Compliance

The first steps in obtaining the basic information needed to comply with CEQA are completing the studies of the projects technical and economic feasibility, and an Initial Study, as set forth in the CEQA Guidelines (California Administrative Code, Title 14, Chapter 3). The Initial Study can be prepared from the environmental assessment used to prepare the environmental report for the FERC licensing process. The environmental assessment is based on the construction and operation of the proposed project as determined in the feasibility study. Generally, the information needed for applications to state agencies that have jurisdiction over a project can be taken from both the feasibility study and the environmental assessment.

In the CEQA process, the lead agency is the public agency which has the principal responsibility for carrying out or approving a project. For private development of a small hydroelectric project at an existing facility, the lead agency shall be the public agency with the greatest responsibility for supervising or approving the project as a whole. If the project is to be carried out by a public agency, the lead agency shall be the public agency which proposes to carry out the project. Each state agency and some local agencies have a list of the information required for an acceptable permit application and the criteria used to decide if an application is complete. Within 30 days of receiving a permit application, the state or local agency must inform the applicant, in writing, whether the application is complete and accepted for filing. If incomplete, the agency must specify the deficiencies and the additional information required. If complete, the agency proceeds with the evaluation. If the agency fails to notify the applicant of deficiency or acceptance within 30 days of receipt, the application is deemed sufficient and accepted.

For projects subject to CEQA requirements, the lead agency must conduct an initial study to determine if the project would have a significant adverse effect on the environment unless the lead agency can determine that the project will clearly have a significant effect. The Initial Study provides a written determination of whether a Negative Declaration or an EIR is required for a proposed project. If any aspect(s) of the project, either individually or cumulatively, may significantly effect the environment, an EIR must be prepared.

The Initial Study serves many purposes:

- (1) To facilitate environmental assessment early in the design of a project,
- (2) To identify environmental impacts, if any

- (3) To focus on potentially significant environmental impacts, if any
- (4) To enable project modifications to be made to eliminate or mitigate adverse impacts,
- (5) To eliminate unnecessary EIRs, and
- (6) To provide documentation for the finding in a Negative Declaration, that a project will not have a significant effect on the environment.

The Initial Study would:

- (1) describe the project,
- (2) identify the environmental setting,
- (3) identify environmental effects by using a checklist, matrix, or other method,
- (4) discuss ways to mitigate any significant effects which are identified, if any
- (5) examine whether the project is compatible with existing zoning and plans, and
- (6) name the person(s) who prepared or participated in the Initial Study.

If on the basis of the Initial Study, the lead agency determines that the proposed project will not have a significant effect(s) on the environment, the lead agency will prepare a Negative Declaration which shall include:

- (1) a brief description of the project including its commonly-used name, if any;
- (2) the location of the project and the name of the project proponent;
- (3) a decision that the project will not have significant effect(s) on the environment;
- (4) an attached copy of the Initial Study documenting reasons to support finding(s);
- (5) mitigation measures, if any, included in the project to avoid potentially significant effects.

The lead agency must make a Negative Declaration available early enough to provide an opportunity for public response before a decision is made to approve the project. The lead agency will file a Notice of Determination which would include:

- (1) the agency's decision to approve the project,
- (2) the agency's determination of whether the project will significantly effect the environment,
- (3) a statement that no EIR has been prepared pursuant to the provisions of CEQA, and
- (4) the location where a copy of the Negative Declaration may be examined.

The Resources Agency, State of California is knowledgeable in the CEQA process and will assist hydroelectric developers to understand and meet CEQA requirements. Further information can be obtained from

The Resources Agency  
1416 - 9th Street, Room 1311  
Sacramento, CA 95814  
(916) 445-9134

#### State Water Resources Control Board

Water Rights Permits. For a new hydroelectric facility at an existing dam or other hydraulic structure, the State Water Resources Control Board may require either an application for new water rights or a petition to change existing water rights. A petition to change existing rights may be filed when the operation of the turbine is strictly incidental to water use under existing permits and licenses. Otherwise, a new application will be required unless the water flowing through the turbine is fully used under riparian claim or pre-1914 appropriate claim, or is groundwater which was not flowing in a known and definite underground channel before extraction. The Board amended its regulations so that incidental power generation can be added, by petition, to existing permits and licenses for consumptive uses.

The application form and supplemental forms for a water rights permit are reproduced in Attachment No. 6.

Inquiries and applications for permits should be directed to:

State Water Resources Control Board  
Division of Water Rights  
77 Cadillac Drive  
Sacramento, CA 95825  
(916) 920-6301

Water Quality Certificates. The responsibility for water quality (under Section 401 of the Clean Water Act of 1977) has been delegated to state regulation by the Environmental Protection Agency. In California, a Regional Water Quality Control Board will decide if a proposed hydroelectric project will affect water quality and will respond to the project developer accordingly. If an application for license or exemption has been made to the FERC, they will require either a copy of the water quality certificate or evidence that such a certificate is not required.

The project developer should submit a copy of the FERC license application for the project to the Regional Water Quality Control Board for the region where the project will be located and request a determination on the effect of the project on water quality.

The Regional Water Quality Control Boards are located at:

Northern Coast Region  
1000 Coddington Center  
Santa Rosa, CA 95401  
(707) 545-2620

Redding Branch Office  
1815 Sacramento Street  
Redding, CA 96001  
(916) 442-6276

San Francisco Bay Region  
1111 Jackson Street, Room 6040  
Oakland, CA 94607  
(415) 464-1255

Lahontan Region  
2092 Lake Tahoe Boulevard  
P. O. Box 14367  
South Lake Tahoe, CA 95702  
(916) 544-3481

Central Coast Region  
1122-A Laurel Lane  
San Luis Obispo, CA 93401  
(805) 549-3147

Victorville Branch Office  
15371 Bonanza Road  
Victorville, CA 92392  
(714) 245-6585

Los Angeles Region  
107 South Broadway, Room 4027  
Los Angeles, CA 90012  
(213) 620-4460

Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260  
(714) 346-7497

Central Valley Region  
3201 S Street  
Sacramento, CA 95816  
(916) 445-0270

Santa Ana Region  
6833 Indiana Avenue, Suite 1  
Riverside, CA 92506  
(714) 684-9330

Fresno Branch Office  
3374 East Shields Avenue  
Fresno, CA 93726  
(209) 488-5116

San Diego Region  
6154 Mission Gorge Road  
Suite 205  
San Diego, CA 92120  
(714) 286-5114

#### Department of Water Resources

Dam Safety Approval. If a hydroelectric facility will require the alteration of an existing dam, the Division of Safety of Dams, Department of Water Resources, will require an "Application for Approval of Plans and Specifications for the Repair or Alteration of a Dam and Reservoir". An Alteration Application (Form DWR-4) is reproduced in Attachment No. 7.

If the installation of a hydroelectric facility will increase the water storage elevation of the reservoir, the developer must file an "Application for Approval of Plans and Specifications for the Construction or Enlargement of a Dam and Reservoir" with detailed plans and specifications showing the modifications. A filing fee based on the estimated cost of the modifications is required for construction or enlargement

applications. A licensed engineer must prepare the plans and specifications for alterations or modifications to a dam. A Construction Application (Form DWR-3) is reproduced in Attachment No. 8.

Project sponsors should direct inquires and applications to

Department of Water Resources  
 Division of Safety of Dams  
 P. O. Box 388  
 Sacramento, CA 95802  
 (916) 445-1816

Floodway Permit. If the hydroelectric facility is located on a river or waterway that is contained by project levees or is within a designated floodway, The Reclamation Board will require an application for approval of plans and specifications. Application forms for floodway approval are available from The Reclamation Board's Office in Sacramento. The application should contain or be accompanied by information, description, and drawings to permit the Board to make flood control and environmental assessments of the project. The Application for Approval of Plans and/or Encroachment Permit is reproduced in Attachment No. 9.

The waterways that have been designated by The Reclamation Board as requiring a floodway permit are listed in Table F-2.

Table F-2. Streams Requiring Floodway Permit

| Stream           | County                       | Location                             |
|------------------|------------------------------|--------------------------------------|
| American River   | Sacramento                   | Mayhew Road to Nimbus Dam            |
| Ash Slough       | Madera                       | Chowchilla to Chowchilla River       |
| Berenda Slough   | Madera                       | Avenue 21-1/2 to Ash Slough          |
| Chowchilla River | Madera<br>Merced<br>Mariposa | Eastside Bypass to Buchanan Dam Site |
| Clear Creek      | Shasta                       | Sacramento River to Whiskeytown Dam  |
| Colusa Drain     | Glenn<br>Colusa<br>Yolo      | Knights Landing to Willows           |

Table F-2. Streams Requiring Floodway Permit (Continued)

| Stream           | County              | Location  |
|------------------|---------------------|---|
| Cosumnes River   | Sacramento          | Mokelumne River to State Highway 99   |
| Cosumnes River   | Sacramento          | Highway 99 to El Dorado County Line   |
| Cottonwood Creek | Shasta & Tehama     | Confluence Sacramento River to the proposed Dutch Gulch Dam site and 7 miles of the South Fork  |
| Cow Creek System | Shasta              | Lower reaches of the following creeks: Cow, Little Cow, Dry, Oak Run and Clover   |
| Dry Creek        | Sacramento & Placer | Natomas East Drainage Canal to the City of Roseville Sewage Treatment Plant   |
| Dry Creek        | Stanislaus          | Tuolumne River to AT&SF Railroad  |
| Feather River    | Butte               | Honcut Creek to Oroville Fish Hatchery Dam  |
| Fresno River     | Madera              | AT&SF Railroad to Road 22-1/2   |
| Fresno River     | Madera              | AT&SF Railroad to Hidden Dam Site   |
| Kaweah River     | Tulare              | Middle Fork: Kaweah Lake to Ash Mountain<br>North Fork: 2.5 miles upstream from Middle Fork<br>South Fork: 1.75 miles upstream from Middle Fork |
| Kern River       | Kern                | Tupman to Golden State Highway  |
| Kern River       | Kern & Kings        | Tupman to Tulare Lake   |
| Kern River       | Kern                | Golden State Highway to Isabella Dam  |
| Kings River      | Fresno              | Reedley to Piedra<br>Dutch John Cut<br>Cole Slough<br>Excelsior Road to Layton<br>McMullen Grade Crossing to Parkhurst-Excelsior Avenue         |
| Kings River      | Tulare              | Highway 99 to Reedley   |

Table F-2. Streams Requiring Floodway Permit (Continued)

| Stream            | County                            | Location  |
|-------------------|-----------------------------------|---|
| Kings River       | Fresno                            | Mendota Pool to McMullin Grade Crossing                       |
| Kings River       | Fresno                            | Piedra to Pine Flat Dam                                       |
| Kings River       | Fresno                            | Cameron & Byrd Sloughs  |
| Kings River       | Kings                             | Kings River and distributaries within Kings County            |
| Merced River      | Merced                            | San Joaquin River to Merced Falls                             |
| Mokelumne River   | San Joaquin & Sacramento          | Cosumnes River to Highway 99                                  |
| Porter Slough     | Tulare                            | Road 192 to Tulare River                                      |
| Sacramento River  | Glenn                             | Ord Ferry Road to Glenn County-Tehama County Line             |
| Sacramento River  | Butte                             | South Parrott Grant Line to Butte County-Tehama County Line   |
| Sacramento River  | Tehama                            | Tehama County   |
| Sacramento River  | Shasta                            | Keswick Dam to Cottonwood Creek                               |
| San Joaquin River | Merced                            | Merced River to Salt Slough                                   |
| San Joaquin River | Madera & Fresno                   | Gravelly Ford Area to Friant Dam                              |
| San Joaquin River | San Joaquin, Stanislaus, & Merced | Airport Way to Merced River                                   |
| Tule River        | Tulare                            | Road 192 to Road 224  |
| Tule River        | Tulare                            | Road 224 to Success Dam                                       |
| Tule River        | Tulare                            | Springville Area  |
| Tuolumne River    | Stanislaus                        | Mitchell Road to Whitmore Road (Extension of Whitmore Avenue) |

Table F-2. Streams Requiring Floodway Permit (Continued)

| Stream         | County     | Location  |
|----------------|------------|---|
| Tuolumne River | Stanislaus | San Joaquin River to extension of Whitmore Avenue |
| Tuolumne River | Stanislaus | Mitchell Road to LaGrange Dam                     |
| Yuba River     | Sutter     | Highway 70 to Daguerre Point Dam                  |

For more information, contact The Reclamation Board at:

Department of Water Resources  
 The Reclamation Board  
 Floodway Permit Section  
 1416 Ninth Street, Room 335-10  
 Sacramento, CA 95814  
 (916) 445-9225

State Lands Commission

Small hydroelectric projects located on state-owned lands or waterways (Except for projects on the State Water Project and the Central Valley Project) will require a land use lease from the State Lands Commission. If the project requires dredging in state-owned swamps, overflows, marshes, tidelands, and/or submerged lands, or in the beds of navigable waters where the state has mineral rights, a Dredging Permit will be required.

The Commission has an "Application Requirements Checklist" (Form 54.1) and a "General Data" (Form 54.1) that serves the Commission in its efforts. Since leases, licenses, permits, land sales, or other entitlements to use state lands under the jurisdiction of the Commission can only be authorized after compliance with the California Environmental Quality Act (CEQA), the Commission also has an "Environmental Data" (Form 54.3) and "Environmental Information Form" (EIF) which specify the format and detail of the data that must be supplied when applying for Commission action.

These forms are reproduced in Attachment No. 10.

Inquiries and application for permits should be directed to:

Dredging Permits

State Lands Commission  
 1807 - 13th Street  
 Sacramento, CA 95814  
 Attention:  
 Dredging Coordinator  
 (916) 322-7802

Other Than Dredging Permits

State Lands Commission  
 Division of Land Management  
 and Conservation  
 1807 - 13th Street  
 Sacramento, CA 95814  
 (916) 445-7738

Department of Fish and Game

Stream or Lake Alteration Agreements. If a project will change the natural state of any river, stream, or lake, the project's sponsor must enter into a Stream or Lake Alteration Agreement with the Department of Fish and Game. These agreements are often referred to as 1601 or 1603 permits. In general, this requirement applies to any work undertaken within the mean high-water mark of a body of water which contains fish or wildlife resources or where the project sponsor will use material from the streambed. The Department of Fish and Game determines the high-water mark by (1) the height of residue deposited by the stream, river, or lake on its bank or beach in the course of a normal year; (2) the yearly fluctuation in flow; (3) personal knowledge of the area involved; and (4) United States Geological Survey charts. The application form for an alteration agreement is reproduced in Attachment No. 11.

All inquiries and applications for Stream or Lake Alteration Agreement should be directed to the Fish and Game office in the area where the project is located as follows:

Department of Fish and Game  
627 Cypress  
Redding, CA 96001  
(916) 246-6511

Del Norte, Humboldt, Lassen, Modoc,  
Shasta, Siskiyou, Tehama and Trinity  
Counties

Department of Fish and Game  
1001 Jedsmith Drive  
Sacramento, CA 95819  
(916) 355-7030

Alpine, Amador, Butte, Calaveras,  
Colusa, eastern Contra Costa,  
El Dorado, Glenn, Lake, Napa, Nevada,  
Placer, Plumas, Sacramento,  
San Joaquin, Sierra, eastern Solano,  
Sutter, Yolo, and Yuba Counties

Department of Fish and Game  
Yountville Veterans Facility  
P. O. Box 47  
Yountville, CA 94599  
(707) 944-2443

Alameda, western Contra Costa, Marin,  
Mendocino, Monterey, San Benito,  
San Luis Obispo, San Mateo, Santa  
Clara, Santa Cruz, western Solano,  
and Sonoma Counties

Department of Fish and Game  
1234 East Shaw Avenue  
Fresno, CA 93710  
(209) 222-3761

Fresno, Kern, Kings, Madera,  
Mariposa, Merced, Stanislaus, Tulare,  
and Tuolumne Counties

Department of Fish and Game  
350 Golden Shore  
Long Beach, CA 90802  
(213) 590-5177

Imperial, Inyo, Los Angeles, Mono,  
Orange, Riverside, San Bernardino,  
San Diego, Santa Barbara, and  
Ventura Counties

Office of State Treasurer

The Districts Securities Division of the State Treasurer's Office has financial supervision over special districts and certain other local agencies for the benefit of their constituents and to help establish and maintain the confidence of the bond-buying public. This protects the credit

rating of districts, agencies, and the state. The Division conducts an impartial examination of the overall feasibility and financial soundness of each major debt proposal, and supervises the expenditure of proceeds from the sale of bonds, warrants, or other forms of indebtedness. It also conducts engineering inspections of the projects under construction to assure investors that the project being financed will be completed as planned. Each district with outstanding certified securities must file an annual report of its financial transactions with the State Treasurer.

In general, the Districts Securities Division has financial supervision over all districts that have landowner or assessed-value voting. Districts that have resident voting are subject to financial supervision only as specified in the act under which the district may be formed. Districts subject to financial supervision file an application with the State Treasurer, and after review of the financial and engineering analyses including an open public meeting, the State Treasurer will issue a report or order setting forth his determination and authorizing the district to proceed in a specific manner.

Project sponsors should direct inquiries and applications to:

Office of State Treasurer  
Districts Securities Division  
120 Montgomery Street, Room 1025  
San Francisco, CA 94104  
(415) 557-1932

#### COUNTY OR SPECIAL DISTRICTS

Most small hydroelectric projects will require local approval by the counties or special districts within whose boundaries the facilities will be located. This approval may be in the form of general plan amendments, rezonings, use permits, variances, grading permits, and/or building permits. Since the requirements are site-specific and vary from one county to another, detailed information cannot be provided in this report. Developers should contact the appropriate County Clerk and Planning Department(s) for further information.



ATTACHMENT NO. 1

FEDERAL ENERGY REGULATORY COMMISSION

LICENSE EXEMPTIONS

- Conduits, 15 MW or less
- Projects of 5 MW or less
- Categorical Exemptions
  - . Greater than 100 kW but not more than 5 MW
  - . Less than 100 kW

License Exemption

The FERC rulemaking under Section 213 of PURPA concerning exemption of small conduit hydroelectric facilities from regulation added Subpart J to Part 4, Subchapter B, Chapter 1 of Title 18, Code of Federal Regulations. Sections 4.90, 4.91, and 4.92 of Subpart J are reproduced in the following paragraphs to allow potential site developer to determine if the proposed hydroelectric facility may be exempt from federal regulation and to provide the procedure for making an application for exemption.

Similarly, the FERC rulemaking under Section 408 of the Energy Security Act of 1980 concerning exemption of hydroelectric projects of 5 MW or less from licensing added Subpart K to Part 4, Subchapter B, Chapter 1, of Title 18, Code of Federal Regulations. Sections 4.101 through 4.107 of Subpart K are also reproduced in the following paragraphs.

FERC has issued a proposed rulemaking (Docket No. RM81-7, December 22, 1980) to provide for exemption for two categories of hydroelectric projects of 5 MW or less. This would amend and revise titles and paragraphs of Subpart K and add Sections 4.109 through 4.113. These are reproduced in the following paragraphs.

Subpart J - EXEMPTION OF SMALL CONDUIT HYDROELECTRIC FACILITIES

§4.90 Applicability and purpose.

This subpart implements Section 30 of the Federal Power Act and provides procedures for obtaining an exemption for constructed or unconstructed small conduit hydroelectric facilities, as defined in §4.91, from all or part of the requirements of Part I of the Federal Power Act, including licensing, and the regulations issued under Part I.

§4.91 Definitions.

For the purpose of this subpart:

(a) "Conduit" means any tunnel, canal, pipeline, aqueduct, flume, ditch, or similar manmade water conveyance that is operated for the distribution of water for agricultural, municipal, or industrial consumption and not primarily for the generation of electricity. The term "not primarily for the generation of electricity" includes but is not limited to a conduit:

(i) which was built for the distribution of water for agricultural, municipal, or industrial consumption, and is operated for such a purpose, and

(ii) to which a hydroelectric facility has been or is proposed to be added.

(b) "Construction of a dam" means any construction, repair, reconstruction, or modification of a dam that creates a new impoundment or increases the normal maximum surface elevation or the normal maximum surface area of an existing impoundment.

(c) "Dam" means any structure that impounds water.

(d) "Fish and wildlife agencies" means the U.S. Fish and Wildlife Service, the National Marine Fisheries Service if anadromous fish may be affected, and any State agency with administrative authority over fish or wildlife resources of the State in which a particular small conduit hydroelectric facility will be located.

(e) "Non-Federal lands" means any lands except land to which the United States holds fee title.

(f) "Small conduit hydroelectric facility" means an existing or proposed hydroelectric facility, including all structures, fixtures, equipment, and lands used and useful in the operation or maintenance of the hydroelectric facility, but not including the conduit on which the hydroelectric facility is located or the transmission lines associated with the hydroelectric facility, which facility is constructed, operated, or maintained for the generation of electric power and:

(1) utilizes for electric power generation the hydroelectric potential of a conduit;

(2) is located entirely on non-Federal lands;

(3) has an installed generating capacity of 15 megawatts or less;

(4) is not an integral part of a dam;

(5) discharges the water it uses for power generation either:

(i) into a conduit;

(ii) directly to a point of agricultural, municipal, or industrial consumption; or

(iii) into a natural water body, if a quantity of water equal to or greater than the quantity discharged from the hydroelectric facility is withdrawn from that water body downstream into a conduit that is part of the same water supply system as the conduit on which the hydroelectric facility is located; and

(6) does not rely upon construction of a dam which construction will create any portion of the hydrostatic head that the facility uses for power generation, unless that construction would occur for agricultural, municipal, or industrial consumptive purposes even if hydroelectric generating facilities were not installed. )

§4.92 Exemption applications.

(a) Who may apply. Any citizen or association of citizens of the United States, municipality, State, or corporation incorporated under the laws of the United States or a State, may apply for exemption of a small conduit hydroelectric facility from all or part of the provisions of Part I of the Federal Power Act.

(b) General requirements. (1) Except as otherwise prescribed in this subpart, an application for exemption of a small conduit hydroelectric facility must conform to the requirements set forth in §§1.5 and 1.14 through 1.17 of this chapter. (2) An original and fourteen copies of the exemption application must be submitted to the Secretary of the Commission. Full-sized prints (but not the originals) of all required maps and drawings must be filed with the original application. The original maps or drawings (microfilm) may be requested pursuant to §4.31(c) of this part.

(c) Contents of Application. (1) An application for exemption under this subpart must include:

(i) an introductory statement, including a declaration that the facility for which application is made meets the requirements of §4.91(f) of this subpart (If the facility qualifies but for the discharge requirement of §4.91(f)(5), the introductory statement must identify that fact and state that the application is accompanied by a petition for waiver of §4.91(f)(5), filed pursuant to §1.7(b) of this chapter.); and

(ii) Exhibits A, B, E, and G.

(2) Introductory Statement. The introductory statement must be set forth in the following format:

BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION

APPLICATION FOR EXEMPTION FOR SMALL  
CONDUIT HYDROELECTRIC FACILITY

[Name of applicant] applies to the Federal Energy Regulatory Commission for an exemption for the [name of facility], a small conduit hydroelectric facility that meets the requirements of [insert the following language, as appropriate: "§4.91(f) of this subpart" or "§4.91(f) of this subpart, except paragraph (f)(5)"], from certain provisions of Part I of the Federal Power Act.

The location of the facility is:

State or Territory:  
County:  
Township or nearby town:

The exact name and business address of each applicant are:

---

---

The exact name and business address of each person authorized to act as agent for the applicant in this application are:

---

---

---

[Name of applicant] is [a citizen of the United States, an association of citizens of the United States, a municipality, State, or a corporation incorporated under the laws of (specify the United States or the State of incorporation, as appropriate), as appropriate].

The provisions of Part I of the Federal Power Act for which exemption is requested are:

[List here all sections or subsections for which exemption is requested.]

[If the facility does not meet the requirement of §4.91(f)(5), add the following sentence: "This application is accompanied by a petition for waiver of §4.91(f)(5), submitted pursuant to 18 C.F.R §1.7(b)."]

(3) Exhibit A. Exhibit A must describe the small conduit hydro-electric facility and proposed mode of operation with appropriate references to Exhibits B and G. To the extent feasible the information in this exhibit may be submitted in tabular form. The following information must be included:

(i) a brief description of any conduits and associated consumptive water supply facilities, intake facilities, powerhouses, and any other structures associated with the facility.

(ii) The proximate natural sources of water that supply the related conduit.

(iii) The purposes for which the conduit is used.

(iv) The number of generating units, including auxiliary units, the capacity of each unit, and provisions, if any, for future units.

(v) The type of each hydraulic turbine.

(vi) A description of how the plant is to be operated, manually or automatically, and whether the plant is to be used for peaking.

(vii) Estimations of:

- (A) the average annual generation in kilowatt hours;
- (B) the average head of the plant;
- (C) the hydraulic capacity of the plant (flow through the plant) in cubic feet per second;
- (D) the average flow of the conduit at the plant or point of diversion; and
- (E) the average amount of the flow described in clause (D) available for power generation.

(viii) The planned date for beginning construction of the facility.

(ix) If the hydroelectric facility discharges directly into a natural body of water and a petition for waiver of §4.91(f)(5) has not been submitted, evidence that a quantity of water equal to or greater than the quantity discharged from the hydroelectric facility is withdrawn from that water body downstream into a conduit that is part of the same water supply system as the conduit on which the hydroelectric facility is located.

(x) If the hydroelectric facility discharges directly to a point of agricultural, municipal, or industrial consumption, a description of the nature and location of that point of consumption.

(xi) A description of the nature and extent of any construction of a dam that would occur in association with construction of the proposed small conduit hydroelectric facility, including a statement of the normal maximum surface area and normal maximum surface elevation of any existing impoundment before and after that construction; and any evidence that the construction would occur for agricultural, municipal, or industrial consumptive purposes even if hydroelectric generating facilities were not installed.

(4) Exhibit B. Exhibit B is a general location map that must show the following information:

(i) the physical structures of the small conduit hydroelectric facility in relation to the conduit and any dam to which any of these structures is attached;

(ii) a proposed boundary for the small conduit hydroelectric facility, by indicating distances from the facility's structures; and

(iii) the ownership of the parcels of the land within the proposed boundary for the small conduit hydroelectric facility.

(5) Exhibit E. This exhibit is an environmental report that must include the following information, commensurate with the scope and environmental impact of the facility's construction and operation:

(i) A description of the environmental setting in the vicinity of the facility, including vegetative cover, fish and wildlife resources, water quality and quantity, land and water uses, recreational use, socio-economic conditions, historical and archeological resources, and visual resources. The report must give special attention to endangered or threatened plant and animal species, critical habitats, and sites eligible for or included on the National Register of Historic Places. The applicant may obtain assistance in the preparation of this information from State natural resources agencies, the State historic preservation officer, and from local offices of Federal natural resources agencies.

(ii) A description of the expected environmental impacts resulting from the continued operation of an existing small conduit hydroelectric facility, or from the construction and operation of a proposed small conduit hydroelectric facility, including a discussion of the specific measures proposed by the applicant and others to protect and enhance environmental resources and to mitigate adverse impacts of the facility on them.

(iii) A description of alternative means of obtaining an amount of power equivalent to that provided by the proposed or existing facility.

(iv) Documentary evidence that the applicant consulted with fish and wildlife agencies before filing, including any terms or conditions of exemption that those agencies have determined are appropriate to prevent loss of, or damage to, fish and wildlife resources or otherwise to carry out the provisions of the Fish and Wildlife Coordination Act. If any fish or wildlife agency fails to provide the applicant with timely documentation of the consultation process, the applicant may submit a summary of the consultation and any determinations of the agency.

(v) Any additional information the applicant considers important.

(6) Exhibit G. Exhibit G is a set of drawings showing the structures and equipment of the small conduit hydroelectric facility. The drawings must include plan, elevation, profile, and section views of the power plant and any other principal facility structure and of any dam to which a facility structure is attached. Each drawing must be an ink drawing or a drawing of similar quality on a sheet no smaller than eight and one-half inches by eleven inches, with a scale no smaller than one inch equals 50 feet for plans and profiles and one inch equals 10 feet for sections. Generating and auxiliary equipment must be clearly and simply depicted and described. For purposes of this subpart, these drawing specifications replace those required in §4.32 of the Commission's regulations.

Subpart K - EXEMPTION OF SMALL HYDROELECTRIC POWER PROJECTS OF  
5 MEGAWATTS OR LESS (Case-by-Case Basis)

§4.101 Purpose

This subpart provides a procedure for obtaining exemption on a case-by-case basis from all or part of Part I of the Federal Power Act (Act), including licensing, for certain small hydroelectric power projects.

§4.102 Definitions.

For purposes of this subpart --

(a) "Dam" means any structure for impounding water, including any diversion structure that is designed to obstruct all or substantially all of the flow of a natural body of water.

(b) "Existing dam" means any dam, the construction of which was completed on or before April 20, 1977, and which does not require any construction or enlargement of impoundment structures (other than repairs or reconstruction) in connection with the installation of any small hydroelectric power projects.

(c) "Fish and wildlife agencies" means the U.S. Fish and Wildlife Service, the National Marine Fisheries Service if anadromous or estuarine fish may be affected, and any state agency with administrative authority over fish or wildlife resources of the state or states in which the small hydroelectric power project is or will be located.

(d) "Federal lands" means any lands to which the United States holds fee title.

(e) "Non-Federal lands" means any lands other than Federal lands.

(f) "Real property interests" includes ownership in fee, right-of-way, easement, or leasehold.

(g) "Licensed water power project" means a project, as defined in section 3 (11) of the Act, that is licensed under Part I of the Act.

(h) "Project" means:

(1) the impoundment and any associated dam, intake, water conveyance facility, power plant, primary transmission line, and other appurtenant facility, if a lake or similar natural impoundment or a man-made impoundment is used for power generation; or

(2) any diversion structure other than a dam and any associated water conveyance facility, power plant, primary transmission line, and

other appurtenant facility, if a natural water feature other than a lake or similar natural impoundment is used for power generation.

(i) "Person" means any individual and, as defined in section 3 of the Act, any corporation, municipality, or state.

(j) "Qualified exemption applicant" means any person who meets the requirements specified in § 4.103(b)(2) with respect to a small hydroelectric power project for which exemption from licensing is sought.

(k) "Qualified license applicant" means any person to whom the Commission may issue a license, as specified in section 4(e) of the Act.

(1) "Small hydroelectric power project" means any project in which capacity will be installed or increased after the date of application under this subpart and which will have a total installed capacity of not more than 5 megawatts and which:

(1) would utilize for electric power generation the water power potential of an existing dam that is not owned or operated by the United States or by any instrumentality of the Federal Government, including the Tennessee Valley Authority; or

(2) would utilize a natural water feature for the generation of electricity, without the need for any dam or man-made impoundment.

(m) "Install or increase" means to add new generating capacity at a site that has no existing generating units, to replace or rehabilitate an abandoned or unused existing generating unit, or to increase the generating capacity of any existing power plant by installing an additional generating unit or by rehabilitating an operable generating unit in a way that increases its rated electric power output.

#### §4.103 General provisions.

(a) Exemptible projects. Except as provided in paragraph (c), the Commission may exempt under this subpart any small hydroelectric power project from all or part of Part I of the Act, including licensing.

(b) Who may apply.

(1) Exemption from provisions other than licensing. Any qualified license applicant or licensee seeking amendment of license may apply for exemption of the related project from provisions of Part I of the Act other than licensing.

(2) Exemption from licensing.

(i) Only Federal lands involved. If only rights to use or occupy Federal lands would be necessary to develop and operate the

proposed small hydroelectric power project, any person may apply for exemption of that project from licensing.

(ii) Some non-Federal lands involved. If real property interests in any non-Federal lands would be necessary to develop and operate the proposed small hydroelectric power project, any person who has all of the real property interests in non-Federal lands necessary to develop and operate that project, or an option to obtain those interests, may apply for exemption of that project from licensing.

(c) Limitation for licensed water power project. The Commission will not accept for filing an application for exemption from licensing for any project that is only part of a licensed water power project.

(d) Waiver. A qualified exemption applicant may petition under §1.7 of this chapter for waiver of any specific provision of this subpart. The Commission may grant a waiver if consistent with section 408 of the Energy Security Act of 1980.

#### §4.104 Relationships among applications, exemptions, permits, and licenses.

For purposes of this subpart, the Commission will treat preliminary permit and license applications, preliminary permits, licenses, exemptions from licensing, and applications for exemption from licensing that are related to a small hydroelectric power project as follows:

##### (a) Limitations on submission and acceptance of exemption applications.

(1) Unexpired permit or license. If there is an unexpired preliminary permit or license in effect for a project, the Commission will accept an application for exemption of that project from licensing only if the exemption applicant is the permittee or licensee.

##### (2) Pending permit or license application.

(i) Pending permit application. If a preliminary permit application for a project has been accepted for filing, an application for exemption of that project from licensing, or a notice of intent to submit such an application, may be submitted not later than the last date for filing protests or petitions to intervene prescribed in the public notice issued for the permit application under §4.31(c)(2) of this chapter.

##### (ii) Pending license application.

(A) Submitted by permittee. If an accepted license application for a project was submitted by a permittee before the preliminary permit expired, the Commission will not accept an application for exemption of that project from licensing submitted by a person other than the permittee.

(B) Submitted by non-permittee other than qualified exemption applicant. Except as provided in clause (A), if the first accepted license application for a project was filed by a person other than a qualified exemption applicant, an application for exemption from licensing, or a notice of intent to submit such an application, may be submitted not later than the last date for filing protests or petitions to intervene prescribed in the public notice issued for that license application under §4.31(c)(2) of this chapter.

(C) Submitted by qualified exemption applicant. If the first accepted license application for a project was filed by a qualified exemption applicant, the applicant may request that its license application be treated initially as an application for exemption from licensing by so notifying the Commission in writing and, unless only rights to use or occupy Federal lands would be necessary to develop and operate the project, submitting documentary evidence showing that the applicant holds the real property interests under §4.103(b)(2) (ii). Such notice and documentation must be submitted not later than the last date for filing protests or petitions to intervene prescribed in the public notice issued for the license application under §4.31(c)(2) of this chapter.

(b) Priority of exemption applicant's earlier permit or application. Any accepted preliminary permit or license application submitted by a person who later applies for exemption of the project from licensing under paragraph (a)(2)(i) or (ii)(C) will retain its validity and priority under Subpart D of this part until the preliminary permit or license application is withdrawn or the project is exempted from licensing under this subpart.

(c) Limitations on submission and acceptance of permit or license applications.

(1) General rule. Except as permitted under subparagraph (2) or under §4.106(c) or (e), the Commission will not accept a preliminary permit or license application for any small hydroelectric project if:

(i) that project is exempt from licensing, under this subpart;  
or

(ii) the Commission has accepted an application for exemption of that project from licensing and the application has not yet been granted or denied.

(2) Exceptions.

(i) If the Commission has accepted an application for exemption of a project from licensing, any qualified license applicant may submit a competing license application that proposes to develop at least 7.5 megawatts in that project, or a notice of intent to file such a license application, not later than the last date for filing protests or petitions to intervene prescribed in the public notice of the application for exemption from licensing issued under §4.31(c)(2) of this chapter.

(ii) If a project is exempted from licensing and real property interests in any non-Federal lands would be necessary to develop and operate the project, any person who is a qualified license applicant and has any of those real property interests in non-Federal lands may submit a license application for that project.

(iii) If the Commission has accepted an application for exemption of a project from licensing and the application has not yet been granted or denied, the applicant for exemption may submit a license application for that project if it is a qualified license applicant. The pending application for exemption from licensing will be considered withdrawn as of the date that the Commission accepts the license application for filing.

(iv) If a license application submitted under clause (ii) or (iii) has been accepted for filing, any qualified license applicant may submit a competing license application in accordance with §4.33 of this part.

(d) Requirements for notices of intent and competing applications.

(1) Competing exemption applications and notices of intent.

(i) Any notice of intent to file an application for exemption from licensing submitted under paragraph (a)(2)(i) or (ii)(B) must conform to the requirements of §4.33(b) of this chapter.

(ii) If a notice of intent is submitted under paragraph (a)(2)(i) or (ii)(B), the application for exemption from licensing must be submitted not later than 120 days after the last date for filing protests and petitions to intervene prescribed in the public notice issued for the permit or license application under §4.31(c)(2) of this chapter.

(iii) Any notice of intent or application for exemption from licensing submitted under paragraph (a)(2)(i) or (ii)(B) must be accompanied by proof of service of a copy of the notice of intent or exemption application on the permit or license applicant.

(2) Competing license applications and notices of intent.

(i) Any notice of intent to file a license application submitted under paragraph (c)(2)(i) must conform to the requirements of §4.33(b) of this chapter and specify the capacity that the applicant proposes to install in the project.

(ii) If a notice of intent is submitted under paragraph (c)(2)(i), the license application must be submitted not later than 120 days after the last date for filing protests and petitions to intervene prescribed in the public notice issued for the exemption application under §4.31(c)(2) of this chapter.

(iii) Any notice of intent or application for license submitted under paragraph (c)(2)(i) must be accompanied by proof of service of a copy of the notice or application on the exemption applicant.

(e) Disposition of competing applications.

(1) Exemption v. permit. If an accepted application for a preliminary permit and an accepted application for exemption from licensing propose to develop mutually exclusive small hydroelectric power projects, the Commission will favor the application for exemption.

(2) Exemption v. license. If an application for a license and an application for exemption from licensing are each accepted for filing and each propose to develop a mutually exclusive project, the Commission will favor the application first filed, unless the Commission determines the plans of the subsequent applicant would better develop the water power potential of the affected water resources.

§4.105 Action on exemption applications.

(a) Exemption from provisions other than licensing. An application for exemption of a small hydroelectric power project from provisions of Part I of the Act other than the licensing requirement will be processed and considered as part of the related application for license or amendment of license.

(b) Exemption from licensing.

(1) General Procedure. An application for exemption of a small hydroelectric power project from licensing will be processed in accordance with paragraphs (c) through (g) of §4.31 of this part, except that notice will be published only once in a daily or weekly newspaper of general circulation in each county in which the project is or will be located. The additional time that may be allowed under §4.31(d) of this part for correcting deficiencies in an application for exemption may not exceed 45 days.

(2) Hearing. The Commission may order a hearing on an application for exemption from licensing either on its own motion or on the motion of any party in interest. Any hearing shall be limited to the issues prescribed by order of the Commission.

(3) Consultation. The Commission will circulate a notice of application for exemption from licensing to interested agencies at the time the applicant is notified that the application is accepted for filing. If a particular agency does not comment within 60 days from the date of issuance of the notice, that agency will be presumed to have no comment on or objection to the exemption requested. Any comments submitted by a fish or wildlife agency must include any specific terms or conditions that the agency has determined are necessary to prevent loss of, or damage to, fish or wildlife resources or otherwise to carry out the provisions of the fish and Wildlife

Coordination Act, except those terms or conditions that may be included in Exhibit E of the application for exemption submitted under §4.107(e). Any fish or wildlife agency that does not comment within the 60-day period will be presumed to have determined that no terms or conditions of exemption are necessary for the above purposes, except the terms and conditions included in Exhibit E of the exemption application.

(4) Automatic exemption. If the Commission has not taken one of the actions set forth in subparagraph (5) within 120 days after notifying the applicant that its application for exemption from licensing is accepted for filing, exemption of the project, as proposed, will be deemed to be found consistent with the public interest and granted, on the standard terms and conditions set forth in §4.106.

(5) Affirmative action on exemption. Within 120 days after notifying an applicant that its application for exemption from licensing is accepted for filing, the Commission may take any of these affirmative actions:

- (i) grant the exemption as requested;
- (ii) grant an exemption from provisions of Part I of the Federal Power Act (and the regulations issued under those provisions) other than those for which exemption was requested, upon finding that modification of the exemption requested is in the public interest;
- (iii) deny exemption if granting the exemption would be inconsistent with the public interest; or
- (iv) suspend the 120-day period for action under this paragraph, upon finding that additional time is necessary for gathering additional information, conducting additional proceedings; or delivering on the issues raised by the application.

(6) Non-standard terms and conditions. In granting an exemption from licensing, the Commission may prescribe terms or conditions in addition to those set forth in §4.106 in order to:

- (i) protect the quality or quantity of the related water supply;
- (ii) otherwise protect life, health, or property;
- (iii) avoid or mitigate adverse environmental impact; or
- (iv) better conserve, develop, or utilize in the public interest the water resources of the region.

§4.106 Standard terms and conditions of exemption from licensing.

Any exemption from licensing granted under this subpart for a small hydroelectric power project is subject to the following standard terms and conditions:

(a) Article 1. The Commission reserves the right to conduct investigations under sections 4(g), 306, 307, and 311 of the Federal Power Act with respect to any acts, complaints, facts, conditions, practices, or other matters related to the construction, operation, or maintenance of the exempt project. If any terms or condition of the exemption is violated, the Commission may revoke the exemption, issue a suitable order under section 4(g) of the Federal Power Act, or take appropriate action for enforcement, forfeiture, or penalties under Part III of the Federal Power Act.

(b) Article 2. The construction, operation, and maintenance of the exempt project must comply with any terms and conditions that any Federal or state fish and wildlife agencies have determined are appropriate to prevent loss of, or damage to, fish or wildlife resources or otherwise to carry out the purposes of the Fish and Wildlife Coordination Act, as specified in Exhibit E of the application for exemption from licensing or in the comments submitted in response to the notice of the exemption application.

(c) Article 3. The Commission may accept a license application by any qualified license applicant and revoke this exemption if actual construction or development of any proposed generating facilities has not begun within 18 months, or been completed within four years, from the date on which this exemption was granted. If an exemption is revoked, the Commission will not accept a subsequent application for exemption within two years of the revocation.

(d) Article 4. This exemption is subject to the navigation servitude of the United States if the project is located on navigable waters of the United States.

(e) Article 5. This exemption does not confer any right to use or occupy any Federal lands that may be necessary for the development or operation of the project. Any right to use or occupy any Federal lands for those purposes must be obtained from the administering Federal land agencies. The commission may accept a license application by any qualified license applicant and revoke this exemption, if any necessary right to use or occupy Federal lands for those purposes has not been obtained within one year from the date on which this exemption was granted.

§4.107 Contents of application for exemption from licensing.

(a) General requirements.

(1) An application for exemption from licensing submitted under this subpart must contain the introductory statement and exhibits

described in this section and, if the project structures would use or occupy any lands other than Federal lands, an appendix containing documentary evidence showing that the applicant has the real property interests required under §4.103(b)(2)(ii) of this subpart. An application for exemption from licensing must conform to the requirements set forth in §§1.5 and 1.14 through 1.17 of this chapter.

(2) An original and fourteen copies of the exemption application must be submitted to the Secretary of the Commission, and a copy must be served at the same time on the Commission's regional engineer for the region in which the project is located and on each of the consulted fish and wildlife agencies. Full-sized prints of all required maps and drawings must be filed with the application. Maps and drawings need not conform to the requirements of §4.32 of this part, but must be of sufficient size, scale, and quality to permit easy reading and understanding. The Commission will request original drawings (microfilm) when it notifies the applicant that the application is accepted.

(b) Introductory statement. The application must include an introductory statement that conforms to the following format:

BEFORE THE FEDERAL ENERGY REGULATORY COMMISSION

APPLICATION FOR EXEMPTION OF  
SMALL HYDROELECTRIC POWER PROJECT  
FROM LICENSING

(1) [Name of applicant] applies to the Federal Energy Regulatory Commission for an exemption for [name of project], a small hydroelectric power project that is proposed to have an installed capacity of 5 megawatts or less, from licensing under the Federal Power Act. [If applicable: The project is currently licensed as FERC Project No. \_\_\_\_\_.]

(2) The location of the project is:

[State or territory]

[County]

[Township or nearby town]

[Stream or body of water]

(3) The exact name and business address of each applicant are:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(4) The exact name and business address of each person authorized to act as agent for the applicant in this application are:

---

---

---

(5) [Name of applicant] is [specify, as appropriate: a citizen of the United States or other identified nation; an association of citizens of the United States or other identified nation; a municipality; a state; or a corporation incorporated under the laws of (specify the United States or the state or nation of incorporation, as appropriate)].

(c) Exhibit A. Exhibit A must describe the small hydroelectric power project and its proposed mode of operation. To the extent feasible, the information in this exhibit may be submitted in tabular form. The applicant must submit the following information:

(1) A brief description of any existing dam and impoundment proposed to be utilized by the small hydroelectric power project and any other existing or proposed project works and appurtenant facilities, including intake facilities, diversion structures, powerhouses, primary transmission lines, penstocks, pipelines, spillways, and other structures, and the sizes, capacities, and construction materials of those structures.

(2) The number of existing and proposed generating units at the project, including auxiliary units, the capacity of each unit, any provisions for future units, and a brief description of any plans for retirement or rehabilitation of existing generating units.

(3) The type of each hydraulic turbine of the small hydroelectric power project.

(4) A description of how the power plant is to be operated, that is, run-of-river or peaking.

(5) A graph showing a flow duration curve for the project or, if flow data are not available from United States Geological Survey records, the estimated average annual stream flow in cubic feet per second.

(6) Estimations of:

(i) the average annual generation in kilowatt-hours;

(ii) the average and design head of the power plant;

(iii) the hydraulic capacity of each turbine of the power plant (flow through the plant) in cubic feet per second;

(iv) the number of surface acres of the man-made or natural impoundment used, if any, at its normal maximum surface elevation and its net and gross storage capacities in acre-feet.

(7) The planned data for beginning and completing the proposed construction or development of generating facilities.

(8) A description of the nature and extent of any repair, reconstruction, or other modification of a dam that would occur in association with construction or development of the proposed small hydroelectric power project, including a statement of the normal maximum surface area and normal maximum surface elevation of any existing impoundment before and after construction.

(d) Exhibit B. Exhibit B is a general location map, which may be prepared on United States Geological Survey topographic quadrangle sheets or similar topographic maps of a state agency, enlarged, if necessary, to show clearly and legibly all of the information required by this paragraph. The map must show the following information:

(1) The location of the existing and proposed physical structures of the small hydroelectric power project, including any dam or diversion structure, reservoir or impoundment, penstocks, pipelines, power plants, access roads, transmission lines, and other important features.

(2) The relationship of the project structures to the stream or other body of water on which the project is located and to the nearest town or other permanent objects that can be readily recognized in the field.

(3) A description of who owns or otherwise has real property interests in any tract of land occupied by the small hydroelectric power project or the structures to which it is directly connected.

(e) Exhibit E. This exhibit is an environmental report that must include the following information, commensurate with the scope and environmental impact of the construction and operation of the small hydroelectric power project:

(1) A description of the environmental setting of the project, including vegetative cover, fish and wildlife resources, water quality and quantity, land and water uses, recreational uses, historical and archeological resources, and scenic and aesthetic resources. The report must list any endangered or threatened plant and animal species, any critical habitats, and any sites eligible for or included on the National Register of Historic Places. The applicant may obtain assistance in the preparation of this information from state natural resources agencies, the state historic preservation officer, and from local offices of Federal natural resources agencies.

(2) A description of the expected environmental impacts from the proposed construction or development and the proposed operation of the small hydroelectric power project, including any impacts from any

proposed changes in the capacity and mode of operation of the project if it is already generating electric power, and an explanation of the specific measures proposed by the applicant, the agencies consulted, and others to protect and enhance environmental resources and values and to mitigate adverse impacts of the project on such resources.

(3) Letters or other documentation showing that the applicant consulted or attempted to consult with each of the relevant fish and wildlife agencies (specify each agency) before filing the application, including any terms or conditions of exemption that those agencies have determined are appropriate to prevent loss of, or damage to, fish or wildlife resources or otherwise to carry out the provisions of the Fish and Wildlife Coordination Act. If any fish or wildlife agency fails to provide the applicant with documentation of the consultation process within a reasonable time, in no case less than 30 days after documentation is requested, the applicant may submit a summary of the consultation and any determinations of the agency. Any exemption application that does not contain the information in this subparagraph will be considered patently deficient and be rejected pursuant to §4.31(d) of this part. The applicant may obtain a list of fish and wildlife agencies from the Director of the Division of Hydropower Licensing or any Regional Engineer.

(4) Any additional information the applicant considers important.

(f) Exhibit G. Exhibit G is a set of drawings showing the structures and equipment, that is, the proposed and existing project works, of the small hydroelectric power project. The drawings must include plan, elevation, and section views of the power plant, any existing dam or diversion structure, and any other principal structure of the project.

#### §4.108 Contents of Application for exemption from provisions other than licensing.

An application for exemption of a small hydroelectric power project from provisions of Part I of the Act other than the licensing requirement need not be prepared according to any specific format, but must be included as an identified appendix to the related application for license or amendment of license. The application for exemption must list all sections or subsections of Part I of the Act for which exemption is requested.

Subpart K of Part 4 is amended by revising § 4.101 and by revising the title and paragraphs (a) and (d) of § 4.103, and by adding §§ 4.109 through 4.113, to read as follows for certain projects with installed capacity of more than 100 kilowatts.

SUBPART K - EXEMPTION OF SMALL HYDROELECTRIC POWER PROJECTS OF  
5 MEGAWATTS OR LESS<sup>1</sup>

§4.101 Applicability. (a) General. This subpart provides procedures for exemption on a case-specific or categorical basis from all or part of Part I of the Federal Power Act (Act), including licensing, for small hydroelectric power projects as defined in §4.102.

(b) Case-specific exemption. The provisions of §§ 4.103 through 4.108 apply to:

(1) exemption of any small hydroelectric power project from provisions of Part I of the Act other than licensing; and

(2) exemption of any small hydroelectric power project from licensing, except any project that has been exempted as part of a category of exemptible projects under §§4.109 through 4.112.

(c) Categorical exemption of certain projects of more than 100 kilowatts. The provisions of §§4.109 through 4.112 apply to exemption from licensing for any small hydroelectric power project which meets the criteria set forth in § 4.109(a) of this subpart. Such projects may be exempted by filing a notice of exemption from licensing.

(d) Categorical exemption of certain projects of 100 kilowatts or less. The provisions of §4.113 apply to certain small hydroelectric power projects which have a proposed installed capacity of 100 kilowatts or less and which are categorically exempt from licensing by operation of this subpart.

\* \* \* \* \*

§4.103 General provisions for case-specific exemption.

(a) Exemptible projects. Subject to the provisions of paragraphs (b) and (c) of this section and §§4.104 through 4.106, the Commission may exempt on a case-specific basis any small hydroelectric power project from all or part of Part I of the Act, including licensing. Applications for exemption for specific projects shall conform to the requirements of §§4.107 or 4.108, as applicable.

\* \* \* \* \*

(d) Waiver. In applying for case-specific exemption from licensing, a qualified exemption applicant may petition under §1.7 of this chapter for waiver of any specific provision of §§4.102 through 4.107. The Commission will grant a waiver only if consistent with section 408 of the Energy Security Act of 1980.

\* \* \* \* \*

---

<sup>1</sup>/ FERC Proposed Rulemaking issued December 22, 1980, Docket No. RM81-7

§4.109 General provisions for categorical exemption from licensing for certain projects with installed capacity of more than 100 kilowatts.

(a) Exempted projects. Subject to the provisions of §§4.110 and 4.111 and effective according to paragraph (b) of this section, the Commission exempts from the licensing requirements of Part I of the Act any small hydroelectric power project which has a proposed installed capacity of more than 100 kilowatts and which:

(1) utilizes for electric power generation only the water power potential of an existing dam;

(2) does not entail any increase in the normal maximum surface elevation of the impoundment pursuant to repair or reconstruction of a dam;

(3) does not entail, for the purpose of generating electric power, any change from the prevailing regime of storage and release of water from the impoundment;

(4) does not entail diversion of water from the waterway for more than 300 feet from the toe of the dam to the point of discharge into the waterway;

(5) does not entail construction of any primary transmission line which:

(i) has a design capacity of more than 69 kilovolts (KV);

or

(ii) is more than one mile long and located on a new right-of-way;

(6) utilizes only a dam at which there is no significant existing upstream or downstream passage of fish;

(7) will not cause violation of applicable water quality standards established by the U.S. Environmental Protection Agency or any state in which the project is located;

(8) does not entail any construction on or alteration of any site included in or eligible for inclusion in the National Register of Historic Places;

(9) does not entail construction in the vicinity of any threatened or endangered species or critical habitat, listed or designated in the regulations of the U.S. Department of the Interior; and

(10) is not only part of a licensed water power project.

(b) Effective date of exemption. Any small hydroelectric power project in the category of projects specified in paragraph (a) is exempted from licensing as of the date that a notice of exemption from licensing for that project, complying with the provisions of §4.112, is deemed accepted for filing.

(c) Who may file a notice of exemption from licensing for Category A projects.

(1) Only Federal lands involved. If only the rights to use or occupy Federal lands would be necessary to develop and operate a proposed small hydroelectric power project that meets the criteria of paragraph (a), any person may file a notice of exemption from licensing for that project under §4.112.

(2) Some non-Federal lands involved. If real property interests in any non-Federal lands would be necessary to develop and operate a proposed small hydroelectric power project that meets the criteria of paragraph (a), any person who has all of the real property interests in non-Federal lands necessary to develop and operate that project, or an option to obtain those interests, may file a notice of exemption from licensing for that project under §4.112.

§4.110 Categorical exemption from licensing for projects of more than 100 kilowatts: relationships among applications, exemptions, permits, licenses, and notices of exemption. For purposes of categorical exemption from licensing under §§4.109 through 4.112, the Commission will treat preliminary permit and license applications, preliminary permits, license, exemptions from licensing, and applications for exemption from licensing that are related to any small hydroelectric power project described in §4.109(a), as follows:

(a) Limitations on submission and acceptance of notices of exemption.

(1) Unexpired permit or license. If there is an unexpired preliminary permit or license in effect for a project, the Commission will accept a notice of exemption from licensing for any project meeting the criteria of §4.109(a) only if the person filing the notice is the permittee or licensee. If the notice of exemption is submitted by a permittee, the permit will be deemed cancelled. If the notice of exemption is filed by a licensee, the license will be deemed terminated.

(2) Pending permit, license, or exemption application.

(i) General Rule. Except as permitted under clause (ii), the Commission will not accept a notice of exemption from licensing for any project meeting the criteria of §4.109(a) if a preliminary permit or license application for that project, or an application for exemption of that project from licensing, has been accepted for filing.

(ii) Exceptions. If an application for preliminary permit, license, or exemption from licensing has been accepted for filing for a project meeting the criteria of §4.109(a), the Commission will accept a notice of exemption from licensing for that project, if:

(A) no competing application, whether for preliminary permit, license, or exemption from licensing, has been accepted for filing for that project;

(B) the last date for filing protests or petitions to intervene, prescribed in the public notice issued for the permit or license application under §4.31(c)(2) of this chapter, has passed;

(C) no notice of intent to file a competing preliminary permit or license application for that project has been filed in accordance with §4.33(b) of this chapter; and

(D) the person filing the notice of exemption is the applicant for preliminary permit, license, or exemption from licensing.

(iii) Withdrawal of pending applications. If a notice of exemption from licensing complying with §4.112 is filed under clause (ii), any pending application for preliminary permit, license, or exemption from licensing will be deemed withdrawn.

(b) Limitations on submissions and acceptance of permit or license applications. (1) General rule. Except as permitted under subparagraph (2) or under §4.111(c) or (e), the Commission will not accept a preliminary permit or license application for any small hydroelectric power project that is exempt from licensing pursuant to §4.109.

(2) Exceptions. (i) If a project is exempted from licensing pursuant to §4.109, any qualified license applicant may submit a license application that proposes to develop at least 7.5 megawatts in any exempted project.

(ii) If a project is exempted from licensing pursuant to §4.109 and real property interests in any non-Federal lands would be necessary to develop and operate the project, any person who is both a qualified license applicant and has any of the real property interests in such non-Federal lands may submit a license application for that project. If a license application is submitted under this clause, any other qualified license applicant may submit a competing license application in accordance with §4.33 of this part.

§4.111 Standard terms and conditions of categorical exemption from licensing for projects installed capacity of more than 100 kilowatts. Any small hydroelectric power project exempted from licensing under §4.109 (a) is subject to the following standard terms and conditions:

(a) Article 1. The Commission reserves the right to conduct investigations under sections 4(g), 306, 307, and 311 of the Federal Power Act with respect to any acts, complaints, facts, conditions, practices, or other matters related to the construction, operation, or maintenance of the exempt project. If any term or condition of the exemption is violated, the Commission may revoke the exemption, issue a suitable order under section 4(g) of the Federal Power Act, or take appropriate action for enforcement, forfeiture, or penalties under Part III of the Federal Power Act.

(b) Article 2. The construction, operation, and maintenance of the exempt project must comply with any measures that any fish and wildlife agency may in the future prescribe as part of any migratory fish restoration program.

(c) Article 3. The Commission may accept a license application submitted by any qualified license applicant and revoke this exemption if actual construction or development of any proposed generating facilities has not begun within 18 months, or been completed within four years, from the effective date of this exemption. If an exemption is revoked, the Commission will not accept a subsequent notice of exemption from licensing or application for exemption for the project within two years of the revocation.

(d) Article 4. This exemption is subject to the navigation servitude of the United States if the project is located on navigable waters of the United States.

(e) Article 5. This exemption does not confer any right to use or occupy any Federal lands that may be necessary for the development or operation of the project. Any right to use or occupy any Federal lands for those purposes must be obtained from the administering Federal land agencies. The Commission may accept a license application submitted by any qualified license applicant and revoke this exemption if any necessary right to use or occupy Federal lands for those purposes has not been obtained within one year from the effective date of this exemption.

(f) Article 6. Any exempted small hydroelectric power project that utilizes a dam that is more than 33 feet in height above streambed, as defined in 18 C.F.R. §12.30(b)(3) of this chapter, impounds more than 2,000 acre-feet of water, or has high hazard potential, as defined in 18 C.F.R. §12.30(b)(2), is subject to the following provisions of 18 C.F.R. Part 12:

- (1) §12.4(b)(2)(i), (ii), (iii)(B), (iv), and (v);
- (2) §12.4(c); and
- (3) Subpart D.

For the purposes of applying these provisions of 18 C.F.R. Part 12, the exempted project is deemed to be a licensed project development and the owner of the exempted project is deemed to be a licensee, under the definitions in 18 C.F.R. §13.3.

§4.112 Notice of exemption from licensing for projects with installed capacity of more than 100 kilowatts. (a) General requirement. Any person meeting the requirements specified in §4.109(c) and filing a notice of exemption from licensing for any small hydroelectric power project under §4.109(a) must submit:

(1) the original and 14 copies of the notice of exemption described in paragraph (c) of this section; and

(2) proof of service of a copy of the notice of exemption on:

(i) the U.S. Fish and Wildlife Service and other fish and wildlife agencies;

(ii) the state Historic Preservation Officer for each state in which the project is located; and

(iii) the state water resource agency for each state in which the project is located or, if there are no applicable state water quality standards, the U.S. Environmental Protection Agency.

(b) Certifications or surveys. As a basis for certifying to the nature and effects of a small hydroelectric power project under paragraph (c)(4) of this section, a person filing a notice of exemption must:

(1) obtain certification from the state water resource agency for each state in which the project is located or, if there are no applicable state water quality standards, from the U.S. Environmental Protection Agency, that the project will not cause a violation of any applicable water quality standards.

(2) obtain certification from the U.S. Fish and Wildlife Service or the fish and wildlife agency for each state in which the project is located that there is no significant existing upstream or downstream passage of fish at any project dam;

(3) either obtain certification from the state Historic Preservation Officer of each state in which the project is located or obtain an independent field survey and survey of the applicable literature, conducted by an archeologist approved by each applicable state Historic Preservation Officer, with respect to whether the project will entail construction on or alteration of sites included in or eligible for inclusion in the National History Register of Historic Places;

(4) either obtain certification from the U.S. Fish and Wildlife Service or the state fish and wildlife agency for each state in which the project is located or obtain an independent field survey and survey of the applicable literature, conducted by a biologist approved by each applicable state fish and wildlife agency, with respect to whether the project entails any construction in the vicinity of any endangered or threatened species or critical habitat listed or designated in the regulations of the U.S. Department of the Interior.

(c) Contents. The notice of exemption from licensing required by this section must conform to the following format:

BEFORE THE FEDERAL ENERGY REGULATORY COMMISSION

Notice of Exemption of  
Small Hydroelectric Power Project  
From Licensing

(1) [Name of filing party or parties] notifies [notify] the Federal Energy Regulatory Commission that the [name of the project], a small hydroelectric power project as defined in 18 C.F.R. §4.102, is exempt from licensing under the terms of 18 C.F.R. §4.109 through §4.111. [If applicable: The project is currently licensed as FERC Project No. \_\_\_\_.]

(2) The location of the project is:

[State or territory]

[County]

[Township or nearby town]

[River or stream]

[River basin]

(3) The exact name, business address, and telephone number of the filing party or parties are:

(4) The project includes the following features:

(a) Dams: [For each existing dam, identify the dam; state the date on which construction was completed and state both the dam's height above streambed and the gross storage capacity of the related impoundment as defined in 18 C.F.R. §12.30].

(b) Powerplants: [For each powerplant: identify the powerplant; state whether it is existing or proposed; state the hydraulic head; state the installed capacity in kilowatts and average annual generation in kilowatt-hours for any existing electric generating capacity; and state the proposed total installed capacity in kilowatts and the estimated average annual generation in kilowatt-hours for the proposed total installed capacity].

(c) Average stream flow: The average annual streamflow is [ ] cubic feet per second.

(5) It is certified that [name of filing party or parties] has [have] complied with §4.112(c) of the Commission's regulations and that the small hydroelectric power project conforms to the specifications set forth in §4.109(a) of the Commission's regulations, including the following:

(i) The [each applicable state water resource agencies or U.S. Environmental Protection Agency] has [have] certified that the construction, operation, and maintenance of the project will not cause a violation of any applicable water quality standards.

(ii) The [U.S. Fish and Wildlife Service or each applicable state fish and wildlife agency] has [have] certified that there is no significant existing upstream or downstream migration of fish at any project dam.

(iii) The proposed small hydroelectric power project does not entail any construction on or alteration of any site that is included in or is eligible for inclusion in the National Register of Historic Places.

(iv) The proposed small hydroelectric power project does not entail construction in the vicinity of any threatened or endangered species or critical habitat listed or designated in the regulations of the U.S. Department of the Interior.

(6) [Signature of filing party or parties under §1.15 of this chapter; subscription and verification under §1.16 of this chapter]

§4.113 General provisions for categorical exemption from licensing for certain projects with installed capacity of 100 kilowatts or less.

(a) Exemption. (1) The Commission categorically exempts from the licensing requirements of Part I of the Act, effective according to paragraph (b) any small hydroelectric power project that:

(i) utilizes for electric power generation only the water power potential of an existing dam;

(ii) has total proposed installed capacity of not more than 100 kilowatts; and

(iii) is not only part of a licensed water project.

(b) Effective dates. (1) Exemption. Any small hydroelectric power project meeting the criteria in paragraph (a) is exempted from licensing as of the effective date of this section.

(2) Proposed capacity. For purposes of installing or increasing capacity in any project meeting the criteria in paragraph (a), under the definition of small hydroelectric power project in §4.102(1), the effective date of this section is deemed to be the date of notice of exemption or application under this subpart.

(c) Limitation on submissions and acceptance of permit or license applications. For purposes of categorical exemption under this section, the Commission will treat preliminary permit and license applications, preliminary permits, licenses, and applications for exemptions from licensing that are related to a small hydroelectric power project described in §4.113(a), as follows:

(1) General rule. Except as permitted under subparagraph (2), the Commission will not accept a preliminary permit or license application for any small hydroelectric power project that is exempted from licensing pursuant to §4.113.

(2) Exceptions. (i) If a project is exempted from licensing pursuant to §4.113, any qualified license applicant may submit a license application that proposes to develop at least 7.5 megawatts in any exempted project.

(ii) If a project is exempted from licensing pursuant to §4.113 and real property interests in any non-Federal lands would be necessary to develop and operate the project, any person who is both a qualified license applicant and has any of those real property interests in non-Federal lands

may submit a license application for that project. If a license application is submitted under this clause, any other qualified license applicant may submit a competing license application in accordance with §4.33 of this part.

4. Section 4.102(1) is amended by inserting after the words "after the date of" the words "notice of exemption or."

5. Section 4.104 is amended by revising the title to read "Case-specific exemption from licensing: relationships among applications, exemptions, permits and licenses." and by deleting from the first sentence the words "this subpart" and substituting in lieu thereof the words "case-specific exemption under §§4.103 through 4.107".

6. Section 4.105 is amended in the first sentence of paragraph (b)(6) be deleting the words "In granting an exemption from licensing," and substituting in lieu thereof the words "In approving any application for exemption from licensing,".

7. Section 4.106 is amended by revising the title of the section, by revising the first sentence, and by revising the second sentence of paragraph (c) to read:

§4.106 Standard terms and conditions of case-specific exemption from licensing. Any case-specific exemption from licensing granted for small hydroelectric power project is subject to the following standard terms and conditions:

\* \* \* \* \*

(c) Article 3.

\* \* \* \* \*

If an exemption is revoked, the Commission will not accept a subsequent application for exemption or a notice of exemption from licensing within two years of the revocation.

\* \* \* \* \*

7. Section 375.308 is amended in paragraph (n) and (o) to read as follows:

§375.308 Delegations to the Director of the Office of Electric Power Regulation.

\* \* \* \* \*

(n) Issue deficiency letters regarding electric rate schedule filings, refund reports, corporate applications for the sale of facilities with respect to interlocking directorates, exemption applications a notices of exemption filed under Subparts J or K of Part 4 of this chapter, and applications filed under Part I of the Federal Power Act.

(o) Reject a rate filing, an application filed under Part I of the Federal Power Act, an application or other filing under section 405 of the Public Utility Regulatory Policy Act of 1978, or a non-complying notice of exemption from licensing filed under §§4.109 through 4.112 of this chapter, unless accompanied by a request for waiver in conformity with §1.14(a)(2) of this chapter, if it fails patently to comply with applicable statutory requirements or Commission rules, regulations and orders.

\* \* \* \* \*



ATTACHMENT NO. 2

FEDERAL ENERGY REGULATORY COMMISSION

PRELIMINARY PERMIT

Preliminary Permit

The application for preliminary permit is set forth in Subpart I of Part 4, Subchapter B, Chapter 1 of Title 18, Code of Federal Regulations. Section 4.81 is reproduced in the following paragraphs to assist a potential site developer in making an application to FERC for a Preliminary Permit to determine the feasibility of a project and to support an application for license.

4.81 Contents of application.

Each application for a preliminary permit must include the following initial statement and numbered exhibits containing the information and documents specified:

(a) Initial statement:

BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION  
APPLICATION FOR PRELIMINARY PERMIT

(1) [Name of applicant] applies to the Federal Energy Regulatory Commission for a preliminary permit for the proposed [name of project] water power project, as described in the attached exhibits. This application is made in order that the applicant may secure and maintain priority of application for a license for the project under Part I of the Federal Power Act while obtaining the data and performing the acts required to determine the feasibility of the project and to support an application for a license.

(2) The location of the proposed project is:

State or territory : \_\_\_\_\_  
County : \_\_\_\_\_  
Township or nearby town : \_\_\_\_\_  
Stream or other body of water: \_\_\_\_\_

(3) The exact name and business address of each applicant are:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

The exact name and business address of each person authorized to act as agent for the applicant in this application are:

-----  
-----  
-----

(4) [Name of applicant] is a [citizen, association of citizens, domestic corporation, municipality, or state, as appropriate].

(5) The proposed term of the requested permit is [period not to exceed 36 months].

(b) Exhibit 1 must contain a description of the proposed project, specifying and including, to the extent possible:

(1) the number, physical composition, dimensions, general configuration and, where applicable, age and condition, of any dams, spillways, penstocks, powerhouses, tailraces, or other structures, whether existing or proposed, that would be part of the project;

(2) the estimated number, surface area, storage capacity, and normal maximum surface elevation (mean sea level) of any reservoirs, whether existing or proposed that would be part of the project;

(3) the estimated number, length, voltage, interconnections, and, where applicable, age and condition, of any primary transmission lines, whether existing or proposed, that would be part of the project [see 16 U.S.C. §796(11)];

(4) the total estimated average annual energy production and the estimated number, rated capacity, and, where applicable, age and condition, of any turbines or generators, whether existing or proposed, that would be part of the project;

(5) all lands of the United States that are enclosed within the proposed project boundary described under paragraph (e)(3) of this section, identified and tabulated on a separate sheet by legal subdivisions of a public land survey of the affected area, if available; and

(6) any other information demonstrating in what manner the proposed project would develop, conserve, and utilize in the public interest the water resources of the region.

(c) Exhibit 2 is a description of studies conducted or to be conducted with respect to the proposed project, including field studies. Exhibit 2 must supply the following information:

(1) General requirement. For any proposed project, a study plan containing a description of:

(i) any studies, investigations, tests, or surveys that are proposed to be carried out, and any that have already taken place, for the purpose of determining the technical, economic, and financial feasibility of the proposed project, taking into consideration its environmental impacts, and of preparing an application for a license for the project; and

(ii) the approximate locations and nature of any new roads that would be built for the purpose of conducting the studies; and

(2) Work plan for new dam construction. For any development within the project that would entail new dam construction, a work plan and schedule containing:

(i) a description, including the approximate location, of any field study, test, or other activity that may alter or disturb lands or waters in the vicinity of the proposed project, including floodplains and wetlands; measures that would be taken to minimize any such disturbance; and measures that would be taken to restore the altered or disturbed areas; and

(ii) a proposed schedule (a chart or graph may be used), the total duration of which does not exceed the proposed term of the permit, showing the intervals at which the studies, investigations, tests, and surveys, identified under this paragraph are proposed to be completed.

(iii) For purposes of this paragraph, "new dam construction" means any dam construction the studies for which would require test pits, borings, or other foundation exploration in the field.

(3) Waiver. The Commission may waive the requirements of paragraph (c)(2) pursuant to §1.14(a)(2) of this chapter, upon a showing by the applicant that the field studies, tests, and other activities to be conducted under the permit would not adversely affect cultural resources or endangered species and would cause only minor alterations or disturbances of lands and waters, and that any land altered or disturbed would be adequately restored.

(d) Exhibit 3 must contain a statement of costs and financing, specifying and including, to the extent possible:

(1) the estimated costs of carrying out or preparing the studies, investigations, tests, surveys, maps, plans or specifications identified under paragraph (c) of this section;

(2) the expected sources and extent of financing available to the applicant to carry out or prepare the studies, investigations, tests, surveys, maps, plans, or specifications identified under paragraph (c) of this section; and

(3) a description of the proposed market for the power generated at the project, including the identity of the proposed purchaser or

purchasers of the power, and any information that is available concerning the revenues to be derived from sale of the power.

(e) Exhibit 4 must include a map or series of maps, to be prepared on United States Geological Survey topographic quadrangle sheets or similar topographic maps of a state agency, if available. The maps need not conform to the precise specifications of §4.32(a) and (b). If the scale of any base map is not sufficient to show clearly and legibly all of the information required by this paragraph, the maps submitted must be enlarged to a scale that is adequate for that purpose. (If Exhibit 4 comprises a series of maps, it must also include an index sheet showing, by outline, the parts of the entire project covered by each map of the series.) The maps must show:

(1) the location of the project as a whole with reference to the affected stream or other body of water and, if possible, to a nearby town or any permanent monuments or objects that can be noted on the maps and recognized in the field;

(2) the relative locations and physical interrelationships of the principal project features identified under paragraph (b) of this section;

(3) a proposed boundary for the project, enclosing:

(i) all of the principal project features identified under paragraph (b) of this section;

(ii) any non-Federal lands and any public lands or reservations of the United States [see 16 U.S.C. §796(1) and (2)] necessary for the purposes of the project. To the extent that those public lands or reservations are covered by a public land survey, the project boundary must enclose each of and only the smallest legal subdivisions (quarter-quarter section, lots, or other subdivisions, identified on the map by subdivision) that may be occupied in whole or in part by the project.

(4) areas within the vicinity of the proposed project boundary which are included in or have been designated for study for inclusion in the National Wild and Scenic River System; and

(5) areas within the project boundary that, under the provisions of the Wilderness Act, have been:

(i) designated as wilderness area;

(ii) recommended for designation as wilderness area; or

(iii) designated as wilderness study area.

ATTACHMENT NO. 3

FEDERAL ENERGY REGULATORY COMMISSION

MINOR LICENSE

## Minor License

The application for a short-form license is provided for in Section 4.60 and set forth in Section 131.6 of Chapter 1 of Title 18, Code of Federal Regulations. The application form and instructions for completing it, prepared by FERC, are reproduced in the following paragraphs to assist a potential site developer in making an application to the FERC for a minor license for a small hydroelectric project of not more than 1500 kW capacity.

BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION

## APPLICATION FOR SHORT-FORM LICENSE (MINOR)

1. Applicant's full name and address: \_\_\_\_\_

\_\_\_\_\_  
(Zip Code)

2. Location of Project:

State: \_\_\_\_\_ County: \_\_\_\_\_

Nearest town: \_\_\_\_\_ Water body: \_\_\_\_\_

3. Project description and proposed mode of operation (reference to Exhibits K and L, as appropriate):

(continue on separate sheet, if necessary)

4. Land of the United States affected (shown on Exhibit K)

(Name) (Acres)

a. National Forest \_\_\_\_\_

b. Indian Reservation \_\_\_\_\_

(Name) (Acres)

c. Public Lands Under Jurisdiction of \_\_\_\_\_

d. Other \_\_\_\_\_

e. Total U.S. Lands \_\_\_\_\_

- f. Check appropriate box:

Surveyed  Unsurveyed land in public-land state:

- (1) If surveyed land in public-land state provide the following:

Sections and subdivisions: \_\_\_\_\_

Range \_\_\_\_\_ Township: \_\_\_\_\_

Principal base and meridian: \_\_\_\_\_

- (2) If unsurveyed or not in public-land state, see Item 8 of instructions: \_\_\_\_\_

5. Purposes of project (use of power output, etc.)  
\_\_\_\_\_
6. Construction of the project is planned to start \_\_\_\_\_  
it will be completed within \_\_\_\_\_ months from date of the  
issuance of license.
7. List here and attach copies of State water permits or other  
permits obtained authorizing the use or diversion of water, or  
authorizing (check appropriate box):
- the construction, operation, and maintenance
- the operation and maintenance of the proposed  
project.
8. Attach an environmental report prepared in accordance with the  
requirements set forth in the Instructions for Completing  
Application for Short-Form License (Minor), below.
9. Attach Exhibits K and L drawings.
10. State of \_\_\_\_\_  
County of \_\_\_\_\_ ss:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

being duly sworn, depose(s) and say(s) that the contents of this  
application are true to the best of \_\_\_\_\_ knowledge or belief and that  
(check appropriate box)

\_\_\_\_\_ is (are) a citizen(s) of the United States

all members of the association are citizens of the United  
States

\_\_\_\_\_ is (are) the duly appointed agent(s) of the state  
(municipality) (corporation) (association) and has (have) signed this  
application this \_\_ day of \_\_\_\_\_, 19\_\_.

\_\_\_\_\_  
(Applicant(s))

By \_\_\_\_\_  
Subscribed and sworn to before me, a Notary Public of the State of \_\_\_\_\_,  
this \_\_ day of \_\_\_\_\_,

/SEAL/

\_\_\_\_\_  
(Notary Public)

INSTRUCTIONS FOR COMPLETING APPLICATION  
FOR SHORT-FORM LICENSE (MINOR)

GENERAL

1. This application may be used if the proposed or existing project will have or has a total generating capacity of not more than 1,500 kW (2,000 horsepower). Advice regarding the proper procedure for filing should be requested from the Federal Energy Regulatory Commission in Washington, D.C.; or from one of the Commission's Regional Offices in Atlanta, Chicago, Forth Worth, New York, or San Francisco.
  
2. This application is to be completed and filed in an original and nine copies with the Federal Energy Regulatory Commission, 825 N. Capitol Street, N.E., Washington, D.C., 20426. Each of the original and the nine copies of the application is to be accompanied by:
  - a. One copy each of Exhibits K and L described below.
  - b. One copy each of a state water quality certificate pursuant to Section 401 of the Federal Water Pollution Control Act (or evidence that this certificate is not needed), and any water rights certificate or similar evidence required by state law relating to use or diversion of water. In lieu of submitting a copy of a Section 401 certificate (or other certificate), evidence that applications for these certificates have been filed with appropriate agencies, or that such certificates are not necessary, will be adequate to begin FERC processing of the application.
  - c. One copy each of any other state approvals necessary. (Applicant should contact the state natural resources department or equivalent to ascertain whether any such approvals are necessary.)
  - d. One copy of Applicant's environmental report, described below.
  
3. Applicant is required to consult with appropriate Federal, State, and local resources agencies during the preparation of the application and provide interested agencies with the opportunity to comment on the proposal prior to its filing with the Commission. The comments of such agencies must be attached to the application when filed. A list of agencies to be consulted can be obtained from the Commission's main office or the appropriate regional office.
  
4. No work may be started on the project until receipt of a signed license from the Commission. The application itself does not authorize entry upon Federal land for any purpose. If the project is located in part or in whole upon Federal land, the Applicant should contact the appropriate land management agency regarding the need to obtain a right-of-way permit. As noted above, other state or Federal permits may be required.
  
5. An applicant must be: a citizen or association of citizens of the United States; a corporation organized under the laws of the United States or a State; a State; or a municipality.

- (a) If the applicant is a natural person, include an affidavit of United States citizenship.
- (b) If the applicant is an association, include one verified copy of its articles of association. If there are no articles of association, that fact shall be stated over the signature of each member of the association. Also include a complete list include a complete list of members and a statement of the citizenship of each in an affidavit by one of them.
- (c) If the applicant is a corporation, include one copy of the charter or certificate and articles of incorporation, with all the amendments, duly certified by the secretary of state of the State where organized, and one copy of the by-laws. If the project is located in a state other than that in which the corporation is organized, include a certificate from the secretary of state of the State in which the project is located showing compliance with the laws relating to foreign corporations.
- (d) If the applicant is a state, include a copy of the laws under the authority of which the application is made.
- (e) If the applicant is a municipality as defined in the Federal Power Act, include one copy of its charter or other organization papers, duly certified by the secretary of state of the State in which it is located, or other proper authority. Also include a copy of the State laws authorizing the operations contemplated by the application.

Include a copy of all minutes, resolutions of stockholders or directors, or other representatives of the applicant, properly attested, authorizing the filing of the application. This information can be provided by a letter attached to the application.

6. If the stream or water body is unnamed, give the name of the nearest named stream or water body to which it is tributary.

7. The project description (application item 3) shall include, as appropriate: the number of generating units, including auxiliary units, the capacity of each unit, and provisions, if any, for future units; type of hydraulic turbine(s); a description of how the plant is to be operated, manual or automatic, and whether the plant is to be used for peaking; estimated average annual generation in kilowatthours or mechanical energy equivalent; estimated average head on the plant; reservoir surface area in acres and, if known, the net and gross storage capacity; estimated hydraulic capacity of the plant (flow through the plant) in cubic feet per second; estimated average flow of the stream or water body at the plant or point of diversion; sizes, capacities, and construction materials, as appropriate, of pipelines, ditches, flumes, canals, intake facilities, powerhouses, dams, transmission lines, etc.; and estimated cost of the project.

8. In the case of unsurveyed public land, or land not in a public-lands state, give the best legal description available. Include the

distance and general direction from the nearest city or town, fixed monument, physical features, etc.

9. Exhibits K and L shall be submitted on separate drawings. Drawings for Exhibits K and L shall have identifying title blocks and bear the following certification:

"This drawing is a part of the application for license made by the undersigned this \_\_\_ day of \_\_\_\_\_, 19\_\_.

\_\_\_\_\_  
" (Name of Applicant)

10. The Commission reserves the right to require additional information, or another filing procedure, if data provided indicate such action to be appropriate.

#### EXHIBIT K- PROJECT LANDS AND BOUNDARIES

1. The Exhibit K is a planimetric map showing the portion of the stream developed, the location of all project works, and other important features, such as: the dam or diversion structure, reservoir, pipeline, powerplant, access roads, transmission lines, project boundary, private land ownerships (clearly differentiate between fee ownership and land over which applicant only owns an easement), and Federal land boundaries and identifications.

2. The map shall be an ink drawing or drawing of similar quality on a sheet not smaller than 8 inches by 10-1/2 inches, drawn to a scale no smaller than one inch equals 1,000 feet. Ten legible prints shall be submitted with the application. Upon request after review of the application, the tracing must be submitted.

3. The project boundary shall be drawn on the map so that the relationship of each project facility and reservoir to other property lines can be determined. The boundary shall enclose all project works, such as the dam, reservoir, pipelines, roads, powerhouse, and transmission lines. The boundary shall be set at the minimum feasible distance from project works necessary to allow operation and maintenance of the project and control of the shoreline and reservoir. The distance in feet from each principle facility to the boundary shall be shown. The project boundary should be a surveyed line with stated courses and distances. A tape-compass survey is acceptable. True north shall be indicated on the map. The area of Federal land in acres within the project boundary shall be shown. The appropriate Federal agency should be contacted for assistance in determining the Federal land acreage. For clarity, use inset sketches to a larger scale than used for the overall map to show relationships of project works, natural features, and property lines.

4. Show one or more ties by distance and bearing from a definite, identifiable point or points on project works or the project boundary to established corners of the public land survey or other survey monuments, if available.

5. If the project affects unsurveyed Federal lands, the protraction of township and section lines shall be shown. Such protractions, whenever available, shall be those recognized by the agency of the United States having jurisdiction over the lands. On unsurveyed lands, show ties by distance and bearing to fixed recognizable objects.

6. If the project uses both Federal and private lands, the detailed survey descriptions discussed above for the project boundary apply only to Federal lands. General location data and an approximate project boundary will normally suffice for project works on private lands.

#### EXHIBIT L-PROJECT STRUCTURES AND EQUIPMENT

1. The exhibit shall be a simple ink drawing or drawing of similar quality on a sheet no smaller than 8 inches by 10-1/2 inches, drawn to a scale no smaller than one inch equals 50 feet for plans and profiles, and one inch equals 10 feet for sections. Ten legible prints shall be submitted with the application. Upon request after initial review of the application, tracings must be submitted.

2. The drawing shall show a plan, elevation, and section of the diversion structure and powerplant. Generating and auxiliary equipment proposed should be clearly and simply depicted and described. Include a north arrow on the plan view.

#### ENVIRONMENTAL REPORT

The environmental report should be consistent with the scope of the project and the environmental impacts of the proposed action; e.g., authorization to operate and maintain an existing project, or a project using an existing dam or other facility, would require less detailed information than authorization to construct a new project. The environmental report shall set forth in a clear and concise manner:

- (1) A brief description of the project and the mode of operation, i.e., run-of-river, peaking or other specific mode.
- (2) A description of the environmental setting in and near the project area, to include vegetative cover, fish and wildlife resources, water quality and quantity, land and water uses, recreational use, socio-economic aspects, historical and archeological resources, and visual resources. Special attention shall be provided endangered and threatened plant and animal species, critical habitats, and sites eligible for or included on the National Register of Historic Places. Assistance in the preparation of this information may be obtained from state natural resources departments and from local offices of Federal natural resources agencies.
- (3) A description of the expected environmental impacts resulting from the continued operation of an existing project, or from the construction and operation of a new project or a project using an existing dam or other existing facility. Include a discussion of specific measures proposed by the Applicant and others to protect

and enhance environmental resources and to mitigate adverse impacts of the project on the environmental resources and values, the cost of those measures, and the party undertaking to implement those measures if other than the Applicant.

- (4) A description of alternative means of obtaining an amount of power equivalent to that provided by the project in the event that construction or continued operation of the project is not authorized.
- (5) A description of the steps taken by the Applicant in consulting with Federal, state, and local agencies during the preparation of the environmental report. Indicate which agencies have received the final report and provide copies of letters containing the comments of those agencies.

ATTACHMENT NO. 4

FEDERAL ENERGY REGULATORY COMMISSION

MAJOR PROJECT - EXISTING DAM

Major Project - Existing Dam

The regulations governing applications for a license for Major Projects - Existing Dams are contained in Sections 4.50 and 4.51 of Subpart F of Part 4, Chapter 1 of Title 18, Code of Federal Regulations. These regulations are reproduced in the following paragraphs to assist a potential site developer in making an application for a major project at an existing dam.

SUBPART F - APPLICATION FOR LICENSE  
FOR MAJOR PROJECT - EXISTING DAM

§4.50 Applicability and definitions.

(a) Applicability. The provisions of §§4.50 and 4.51 apply to any application for either an initial license or a new license for a major project - existing dam.

(b) Definitions. For the purposes of this subpart:

(1) "Dam" means any structure for impounding or diverting water;

(2) "Existing dam" means any dam that has been completely constructed;

(3) "Existing impoundment" means any body of water that an existing dam impounds;

(4) "Initial license" means the first license issued for a water power project under either the Federal Water Power Act of 1920 or the Federal Power Act;

(5) "Major project - existing dam" means a licensed or unlicensed, existing or proposed water power project that, as proposed to be licensed:

(i) would have a total installed generating capacity of more than 2,000 hp (1.5 MW);

(ii) would not use the water power potential provided by any dam except an existing dam;

(iii) does not include any proposed repair or reconstruction of an existing dam that would result in a significant change in the normal maximum surface area or the normal maximum surface elevation of an existing impoundment; and

(iv) does not include any proposed new development or change in project operation that would result in a significant environmental impact;

(6) "New development" means any construction, installation, repair, reconstruction, or other change in the existing state of project works or appurtenant facilities, including any dredging and filling in project waters; and

(7) "New license" means any license for a water power project that is issued under the Federal Power Act after the initial license for that project, except an annual license issued under Section 15 of the Federal Power Act.

(c) Guidance from Commission staff. A prospective applicant for a major license - existing dam may seek advice from the Commission staff regarding the applicability of these sections to its project [see 4.31(g)], including the determinations whether any proposed repair or reconstruction of an existing dam would result in a significant change in the normal maximum surface area or the normal maximum surface elevation of an existing impoundment, or whether any proposed new development or change in project operation would result in a significant environmental impact.

#### §4.51 Contents of application.

Each application for a license for a major project - existing dam must be prepared after consultation with the appropriate state public service commission or board and the other Federal, state, and local agencies specified in this section. The applicant may obtain a list of agencies to be consulted from the Director of the Commission's Division of Licensed Projects. Each application must include an initial statement and lettered exhibits containing the following information and documents:

#### (c) Initial statement.

BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION  
  
APPLICATION FOR LICENSE FOR MAJOR  
PROJECT -- EXISTING DAM

(1) [Name of applicant] applies to the Federal Energy Regulatory Commission for a [license or new license, as appropriate] for the [name of project] water power project, as described in the attached exhibits. [Specify any previous FERC project number designation.]

(2) The location of the project is:

State or territory : \_\_\_\_\_

County : \_\_\_\_\_

Township or nearby town: \_\_\_\_\_

Stream or other body of Water: \_\_\_\_\_

(3) The exact name and business address of the applicant are:

---

---

---

The exact name and business address of each person authorized to act as agent for the applicant in this application are:

---

---

---

(4) The applicant is a [citizen of the United States, association of citizens of the United States, domestic corporation, municipality or state, as appropriate, see 16 U.S.C. §796].

(5)(i) The statutory or regulatory requirements of the state(s) in which the project would be located and that affect the project as proposed with respect to bed and banks and to the appropriation, diversion, and use of water for power purposes, and with respect to the right to engage in the business of developing, transmitting, and distributing power and in any other business necessary to accomplish the purposes of the license under the Federal Power Act are: [provide citation and brief identification of the nature of each requirement.]

(ii) The steps which the applicant has taken or plans to take to comply with each of the laws cited above are: [provide brief description for each law.]

(b) Exhibit A is a description of the project. This exhibit need not include information on project works maintained and operated by the U.S. Army Corps of Engineers, the Bureau of Reclamation, or any other department or agency of the United States, except for any project works that are proposed to be altered or modified. If the project includes more than one dam with associated facilities, each dam and the associated component parts must be described together as a discrete development. The description for each development must contain:

(1) the physical composition, dimensions, and general configuration of any dams, spillways, penstocks, powerhouses, tailraces, or other structures, whether existing or proposed, to be included as part of the project;

(2) the normal maximum surface area and normal maximum surface elevation (mean sea level), gross storage capacity, and usable storage capacity of any impoundments to be included as part of the project;

(3) the number, type, and rated capacity of any turbines or generators, whether existing or proposed, to be included as part of the project;

(4) the number, length, voltage, and interconnections of any primary transmission lines, whether existing or proposed, to be included as part of the project [see 16 U.S.C. §796(11)];

(5) the specifications of any additional mechanical, electrical, and transmission equipment appurtenant to the project; and

(6) all lands of the United States that are enclosed within the project boundary described under paragraph (h) of this section (Exhibit G), identified and tabulated by legal subdivisions of a public land survey of the affected area or, in the absence of a public land survey, by the best available legal description. The tabulation must show the total acreage of the lands of the United States within the project boundary.

(c) Exhibit B is a statement of project operation and resource utilization. If the project includes more than one dam with associated facilities, the information must be provided separately for each such discrete development. The exhibit must contain:

(1) a statement whether operation of the power plant will be manual or automatic, an estimate of the annual plant factor, and a statement of how the project will be operated during adverse, mean, and high water years;

(2) an estimate of the dependable capacity and average annual energy production in kilowatthours (or a mechanical equivalent), supported by the following data:

(i) the minimum, mean, and maximum recorded flows in cubic feet per second of the stream or other body of water at the powerplant intake or point of diversion, with a specification of any adjustments made for evaporation, leakage, minimum flow releases (including duration of releases), or other reductions in available flow; a flow duration curve indicating the period of record and the gauging stations used in deriving the curve; and a specification of the period of critical streamflow used to determine the dependable capacity;

(ii) an area-capacity curve showing the gross storage capacity and usable storage capacity of the impoundment, with a rule curve showing the proposed operation of the impoundment and how the usable storage capacity is to be utilized;

(iii) the estimated hydraulic capacity of the powerplant (maximum flow through the powerplant) in cubic feet per second;

(iv) a tailwater rating curve; and

(v) a curve showing powerplant capability versus head and specifying maximum, normal, and minimum heads;

(3) a statement, with load curves and tabular data, if necessary, of the manner in which the power generated at the project is to be utilized, including the amount of power to be used on-site, if any, the amount of power to be sold, and the identity of any proposed purchasers; and

(4) a statement of the applicant's plans, if any, for future development of the project or of any other existing or proposed water power project on the stream or other body of water, indicating the approximate location and estimated installed capacity of the proposed developments.

(d) Exhibit C is a construction history and proposed construction schedule for the project. The construction history and schedule must contain:

(1) if the application is for an initial license, a tabulated chronology of construction for the existing project structures and facilities described under paragraph (b) of this section (Exhibit A), specifying for each structure or facility, to the extent possible, the actual or approximate dates (approximate dates must be identified as such) of:

(i) commencement and completion of construction or installation

(ii) commencement of commercial operation; and

(iii) any additions or modifications other than routine maintenance; and

(2) if any new development is proposed, a proposed schedule describing the necessary work and specifying the intervals following issuance of a license when the work would be commenced and completed.

(e) Exhibit D is a statement of costs and financing. The statement must contain:

(1) If the application is for an initial license, a tabulated statement providing the actual or approximate original cost (approximate cost must be identified as such) of:

(i) any land or water right necessary to the existing project; and

(ii) each existing structure and facility described under paragraph (b) of this section (Exhibit A).

(2) If the applicant is a licensee applying for a new license, and is not a municipality or a state, an estimate of the amount which would be payable if the project were to be taken over pursuant to section 14 of the Federal Power Act upon expiration of the license in effect [see 16 U.S.C. §807], including:

(i) fair value;

- (ii) net investment; and
  - (iii) severance damages.
- (3) If the application includes proposals for any new development, a statement of estimated costs, including:
- (i) the cost of any land or water rights necessary to the new development; and
  - (ii) the cost of the new development work, with a specification of:
    - (A) total cost of each major item;
    - (B) indirect construction costs such as costs of construction equipment, camps, and commissaries;
    - (C) interest during construction; and
    - (D) overhead, construction, legal expenses, taxes, administrative and general expenses, and contingencies.
- (4) A statement of the estimated average annual cost of the total project as proposed, specifying any projected changes in the costs over the estimated financing or licensing period if the applicant takes such changes into account, including:
- (i) cost of capital (equity and debt);
  - (ii) local, state, and Federal taxes;
  - (iii) depreciation or amortization, and
  - (iv) operation and maintenance expenses, including interim replacements, insurance, administrative and general expenses, and contingencies.
- (5) A statement of the estimated annual value of project power, based on a showing of the contract price for sale of power or the estimated average annual cost of obtaining an equivalent amount of power (capacity and energy) from the lowest cost alternative source, specifying any projected changes in the cost of power from that source over the estimated financing or licensing period if the applicant takes such changes into account.
- (6) A statement specifying the sources and extent of financing and annual revenues available to the applicant to meet the costs identified in paragraphs (e)(3) and (4) of this section.
- (f) Exhibit E is an environmental report. The report must be prepared in consultation with local, state, and Federal agencies with expertise in environmental matters. The names and addresses of these agencies may be obtained from the Director, Division of Licensed

Projects. If any agency that an applicant is required to consult fails to provide to the applicant timely documentation of the consultation process as set forth in this paragraph, the applicant may submit a summary of the consultation and the recommendations of the agency. Information provided in the report must be organized and referenced according to the provisions of this paragraph. If a request for information is not applicable, the application must explain briefly why it does not apply. The environmental report must contain the following elements:

(1) General description of the locale. The applicant must provide a general description of the environment of the project and its immediate vicinity. The description must include general information concerning climate, topography, wetlands, vegetative cover, land development, population size and density, the presence of any floodplain and the occurrence of flood events in the vicinity of the project, and any other factors important to an understanding of the setting.

(2) Report on water use and quality. The report must discuss the consumptive use of project waters and the impact of the project on water quality. The report must be prepared in consultation with the state and federal agencies with responsibility for management of water quality in the affected stream or other body of water. Consultation must be documented by appending to the report a letter from each agency consulted that indicates the nature, extent, and results of the consultation. The report must include:

(i) a description (including specified volume over time) of existing and proposed uses of project waters for irrigation, domestic water supply, steam-electric plant, industrial, and other consumptive purposes;

(ii) a description of existing water quality in the project impoundment and downstream water affected by the project and the applicable water quality standards and stream segment classification;

(iii) a description of any minimum flow releases specifying the rate of flow in cubic feet per second (cfs) and duration, changes in the design of project works or in project operation, or other measures recommended by the agencies consulted for the purposes of protecting or improving water quality, including measures to minimize the short-term impacts on water quality of any proposed new development of project works [for any dredging or filling, refer to 40 C.F.R. Part 230 and 33 C.F.R. §§320.3(f) and 323.3(e)];

(iv) a statement of the existing measures to be continued and new measures proposed by the applicant for the purpose of protecting or improving water quality, including an explanation of why the applicant has rejected any measures recommended by an agency and described under paragraph (f)(2)(iii) of this section.

(v) a description of the continuing impact on water quality of continued operation of the project and the incremental impact of

proposed new development of project works or changes in project operation; and

(vi) as an appendix, either:

(A) a copy of a water quality certificate (or agency statement that such certification is waived) as described in section 401 of the Federal Water Pollution Control Act (also known as the Clean Water Act) [see 33 U.S.C. §1341]; or

(B) a copy of a dated letter from the applicant to the appropriate agency requesting that certification.

(3) Report on fish, wildlife, and botanical resources. The report must discuss fish, wildlife, and botanical resources in the vicinity of the project and the impact of the project on those resources. The report must be prepared in consultation with any state agency with responsibility for fish, wildlife, and botanical resources, the U.S. Fish and Wildlife Service, the National Marine Fisheries Service (if the project may affect anadromous fish resources subject to that agency's jurisdiction), and any other state or Federal agency with managerial authority over any part of the project lands. Consultation must be documented by appending to the report a letter from each agency consulted that indicates the nature, extent, and results of the consultation. The report must include:

(i) a description of the fish, wildlife, and botanical resources of the project and its vicinity, and of downstream areas affected by the project, including identification of any species listed as threatened or endangered by the U.S. Fish and Wildlife Service [see 50 C.F.R. §§17.11 and 17.12];

(ii) a description of any measures or facilities recommended by the agencies consulted for the mitigation of impacts on fish, wildlife, and botanical resources, or for the protection or improvement of those resources;

(iii) a statement of any existing measures or facilities to be continued or maintained and any measures or facilities proposed by the applicant for mitigation of impacts on fish, wildlife, and botanical resources, or for the protection or improvement of such resources, including an explanation of why the applicant has rejected any measures or facilities recommended by an agency and described under paragraph (f)(3)(ii) of this section.

(iv) a description of any anticipated continuing impact on fish, wildlife, and botanical resources of continued operation of the project, and the incremental impact of proposed new development of project works or changes in project operation; and

(v) the following materials and information regarding the measures and facilities identified under paragraph (f)(3)(iii) of this section:

(A) functional design drawings of any fish passage and collection facilities, indicating whether the facilities depicted are existing or proposed (these drawings must conform to the specifications of §4.32 regarding dimensions of full-sized prints, scale, and legibility);

(B) description of operation and maintenance procedures for any existing or proposed measures or facilities;

(C) an implementation or construction schedule for any proposed measures or facilities, showing the intervals following issuance of a license when implementation of the measures or construction of the facilities would be commenced and completed;

(D) an estimate of the costs of construction, operation, and maintenance of any proposed facilities, and of implementation of any proposed measures, including a statement of the sources and extent of financing; and

(E) a map or drawing that conforms to the size, scale, and legibility requirements of §4.32 showing by the use of shading, cross-hatching, or other symbols the identity and location of any measures or facilities, and indicating whether each measure or facility is existing or proposed (the map or drawings in this exhibit may be consolidated).

(4) Report on historical and archeological resources. The report must discuss the historical and archeological resources in the project area and the impact of the project on those resources. The report must be prepared in consultation with the State Historic Preservation Officer and the U.S. Heritage Conservation and Recreation Service. Consultation must be documented by appending to the report a letter from each agency consulted that indicates the nature, extent, and results of the consultation. The report must contain:

(i) identification of any sites either listed or determined to be eligible for inclusion in the National Register of Historic Places that are located in the project area, or that would be affected by operation of the project or by new development of project facilities (including facilities proposed in this exhibit);

(ii) a description of any measures recommended by the agencies consulted for the purpose of locating, identifying, and salvaging historical or archaeological resources that would be affected by operation of the project, or by new development of project facilities (including facilities proposed in this exhibit), together with a statement of what measures the applicant proposes to implement and an explanation of why the applicant rejects any measures recommended by an agency.

(iii) the following materials and information regarding the survey and salvage activities described under paragraph (f)(4)(ii) of this section:

(A) a schedule for the activities, showing the intervals following issuance of a license when the activities would be commenced and completed; and

(B) an estimate of the costs of the activities, including a statement of the sources and extent of financing.

(5) Report on recreational resources. The report must discuss existing and proposed recreational facilities and opportunities at the project. The report must be prepared in consultation with local, state, and regional recreation agencies and planning commissions, the U.S. Heritage Conservation and Recreation Service, and any other state or Federal agency with managerial authority over any part of the project lands. Consultation must be documented by appending to the report a letter from each agency consulted indicating the nature, extent, and results of the consultation. The report must contain:

(i) a description of any existing recreational facilities at the project, indicating whether the facilities are available for public use;

(ii) an estimate of existing and potential recreational use of the project area, in daytime and overnight visits;

(iii) a description of any measures or facilities recommended by the agencies consulted for the purpose of creating, preserving, or enhancing recreational opportunities at the project and in its vicinity (including opportunities for the handicapped), and for the purpose of ensuring the safety of the public in its use of project lands and waters;

(iv) a statement of the existing measures or facilities to be continued or maintained and the new measures or facilities proposed by the applicant for the purpose of creating, preserving, or enhancing recreational opportunities at the project and in its vicinity, and for the purpose of ensuring the safety of the public in its use of project lands and waters, including an explanation of why the applicant has rejected any measures or facilities recommended by an agency and described by an agency and described under paragraph (f)(5)(iii) of this section; and

(v) the following materials and information regarding the measures and facilities identified under paragraphs (f)(5)(i) and (iv) of this section:

(A) identification of the entities responsible for implementing, constructing, operating, or maintaining any existing or proposed measures or facilities;

(B) a schedule showing the intervals following issuance of a license at which implementation of the measures or construction of the facilities would be commenced and completed;

(C) an estimate of the costs of construction, operation, and maintenance of any proposed facilities, including a statement of the sources and extent of financing;

(D) a map or drawing that conforms to the size, scale, and legibility requirements of §4.32 showing by the use of shading, cross-hatching, or other symbols the identity and location of any facilities, and indicating whether each facility is existing or proposed (the maps or drawings in this exhibit may be consolidated); and

(vi) a description of any areas within or in the vicinity of the proposed project boundary that are included in, or have been designated for study for inclusion in, the National Wild and Scenic Rivers System, or that have been designated as wilderness area, recommended for such designation, or designated as a wilderness study area under the Wilderness Act.

(6) Report on land management and aesthetics. The report must discuss the management of land within the proposed project boundary, including wetlands and floodplains, and the protection of the recreation and scenic values of the project. The report must be prepared following consultation with local and state zoning and land management authorities and any Federal or state agency with managerial authority over any part of the project lands. Consultation must be documented by appending to the report a letter from each agency consulted indicating the nature, extent, and results of the consultation. The report must contain:

(i) a description of existing development and use of project lands and all other lands abutting the project impoundment;

(ii) a description of the measures proposed by the applicant to ensure that any proposed project works, rights-of-way, access roads, and other topographic alterations blend, to the extent possible, with the surrounding environment; (see, e.g., 44 C.F.R. 1496, et seq.);

(iii) a description of wetlands or floodplains within, or adjacent to, the project boundary, any short-term or long-term impacts of the project on those wetlands or floodplains, and any mitigative measures in the construction or operation of the project that minimize any adverse impacts on the wetlands or floodplains;

(iv) a statement, including an analysis of costs and other constraints, of the applicant's ability to provide a buffer zone around all or any part of the impoundment, for the purpose of ensuring public access to project lands and waters and protecting the recreational and aesthetic values of the impoundment and its shoreline;

(v) a description of the applicant's policy, if any, with regard to permitting development of piers, docks, boat landings, bulkheads, and other shoreline facilities on project lands and waters; and

(vi) maps or drawings that conform to the size, scale and legibility requirements of §4.32, or photographs, sufficient to show the

location and nature of the measures proposed under paragraph (f)(6)(ii) of this section (maps or drawings in this exhibit may be consolidated).

(7) List of literature. The report must include a list of all publications, reports, and other literature which were cited or otherwise utilized in the preparation of any part of the environmental report.

(g) Exhibit F consists of general design drawings of the principal project works described under paragraph (b) of this section (Exhibit A).

(1) The drawings must conform to the specifications of §4.32 and must indicate whether each structure depicted is existing or proposed.

(2) Detailed working drawings that show the precise plans and specifications for proposed structures should not be filed with the application, but must be prepared for the purposes of construction and, if a license is issued and construction ensues, retained as permanent project records.

(3) The general design drawings required under this paragraph must show plans (overhead view), elevations (front view), profiles (side view), and sections for each principal project work. The drawings must be accompanied by a description of the physical condition or state of maintenance and repair of any structures or equipment and by sufficient information relating to composition and competency of foundations and other structures, gradation of filter and riprap material, design strength and ultimate strength of concrete and steel, stress and stability analyses, the project design flood (and Standard Project Flood or Probable Maximum Flood, if different from the design flood) used for stability analysis, spillway rating curves, water levels, and other controlling factors to demonstrate that the structures are safe and adequate to fulfill their stated functions.

(h) Exhibit G is a map of the project. The map must conform to the specifications of §4.32. If more than one sheet is used, the sheets must be numbered consecutively and each sheet must bear a small inset sketch showing the entire project (or development) and indicating the portion depicted on the sheet. The map must show:

(1) Location of the project and principal features. The map must show the location of the project as a whole with reference to the affected stream or other body of water and, if possible, to a nearby town or any permanent monuments or objects, such as roads, transmission lines or other structures, that can be noted on the map and recognized in the field. The map must also show the relative locations and physical interrelationships of the principal project works and other features described under paragraph (b) of this section (Exhibit A).

(2) Project boundary. The map must show a project boundary enclosing all of the principal project works and other features described under paragraph (b) of this section (Exhibit A). The boundary must enclose only those lands necessary for operation and maintenance of the project and for other project purposes, such as recreation, shoreline control, or protection of environmental resources (see paragraph (f) of this section (Exhibit E)). Existing residential, commercial, or other structures may be included within the boundary only to the extent that underlying lands are needed for project purposes (e.g., for flowage, public recreation, shoreline control, or protection of environmental resources). If the boundary is on land covered by a public land survey, ties must be shown on the map at sufficient points to permit accurate plotting of the position of the boundary relative to the lines of the public land survey. If the lands are not covered by a public land survey the best available legal description of the position of the boundary must be provided, including distances and directions from fixed monuments or physical features. The boundary must be described as follows:

(i) Impoundments. (A) The boundary around a project impoundment may be described by any of the following:

(1) contour lines, including the contour elevation (preferred method);

(2) specified courses and distances (metes and bounds);

(3) if the project lands are covered by a public land survey, lines upon or parallel to the lines of the survey; or

(4) any combination of the above methods.

(B) The boundary must be located no more than 200 feet (horizontal measurement) from the exterior margin of the reservoir, defined by the normal maximum surface elevation, except where deviations may be necessary in describing the boundary according to the above methods, or where additional lands are necessary for project purposes, such as public recreation, shoreline control, or protection of environmental resources.

(ii) Continuous features. The boundary around linear ("continuous") project features such as access roads, transmission lines, and conduits may be described by specified distances from center lines or offset lines of survey. The width of such corridors must not exceed 200 feet, unless good cause is shown for a greater width. Several sections of a continuous feature may be shown on a single sheet, with information showing the sequence of contiguous sections.

(iii) Noncontinuous features. (A) The boundary around noncontinuous project works such as dams, spillways, and powerhouses may be described by:

(1) contour lines;

(2) specified courses and distances;

(3) if the project lands are covered by a public land survey, lines upon or parallel to the lines of the survey; or

(4) any combination of the above methods.

(B) The boundary must enclose only those lands that are necessary for safe and efficient operation and maintenance of the project, or for other specified project purposes, such as public recreation or protection of environmental resources.

(3) Federal lands. Any public lands and reservations of the United States [see 16 U.S.C. §796(1) and (2)] ("Federal lands") that are within the project boundary e.g., lands administered by the U.S. Forest Service, Bureau of Land Management, National Park Service, or Indian tribal lands, and the boundaries of those Federal lands, must be identified on the map:

(i) by legal subdivisions of a public land survey of the affected area (a protraction of identified township and section lines is sufficient for this purpose);

(ii) by the Federal agency, identified by symbol or legend if desired, that maintains or manages each identified subdivision of the public land survey within the project boundary; and

(iii) in the absence of a public land survey, by the location of the Federal lands according to the distances and directions from fixed monuments or physical features. When a Federal survey monument or a Federal bench mark will be destroyed or rendered unusable by the construction of project works, at least two permanent, marked, witness monuments or bench marks must be established at accessible points. The maps must show the location (and elevation, for bench marks) of the survey monument or bench mark which will be destroyed or rendered unusable, as well as of the witness monuments or bench marks. Connecting courses and distances from the witness monuments or bench marks to the original must also be shown.

(4) Non-Federal lands. For those lands within the project boundary not identified under paragraph (b)(3) of this section, the map must identify by legal subdivision:

(i) lands owned in fee by the applicant and lands that the applicant plans to acquire in fee; and

(ii) lands over which the applicant has acquired or plans to acquire rights to occupancy and use other than fee title, including rights acquired or to be required by easement or lease.



ATTACHMENT NO. 5

U.S. ARMY CORPS OF ENGINEERS

DREDGE AND FILL PERMIT



**APPLICATION FOR A DEPARTMENT OF THE ARMY PERMIT**

For use of this form, see EP 1145-2-1

The Department of the Army permit program is authorized by Section 10 of the River and Harbor Act of 1899, Section 404 of P. L. 92-500 and Section 103 of P. L. 92-532. These laws require permits authorizing structures and work in or affecting navigable waters of the United States, the discharge of dredged or fill material into waters of the United States, and the transportation of dredged material for the purpose of dumping it into ocean waters. Information provided in ENG Form 4345 will be used in evaluating the application for a permit. Information in the application is made a matter of public record through issuance of a public notice. Disclosure of the information requested is voluntary; however, the data requested are necessary in order to communicate with the applicant and to evaluate the permit application. If necessary information is not provided, the permit application cannot be processed nor can a permit be issued.

One set of original drawings or good reproducible copies which show the location and character of the proposed activity must be attached to this application (see sample drawings and checklist) and be submitted to the District Engineer having jurisdiction over the location of the proposed activity. An application that is not completed in full will be returned.

|   |                                  |                        |
|---|----------------------------------|------------------------|
| 1. Application number (To be assigned by Corps) | 2. Date<br><br>Day    Mo.    Yr. | 3. For Corps use only. |
|---|----------------------------------|------------------------|

|   |   |
|---|---|
| 4. Name and address of applicant.<br><br><br>Telephone no. during business hours:<br>A/C (    ) _____<br>A/C (    ) _____ | 5. Name, address and title of authorized agent.<br><br><br>Telephone no. during business hours:<br>A/C (    ) _____<br>A/C (    ) _____ |
|---|---|

6. Describe in detail the proposed activity, its purpose and intended use (private, public, commercial or other) including description of the type of structures, if any to be erected on fills, or pile or float-supported platforms, the type, composition and quantity of materials to be discharged or dumped and means of conveyance, and the source of discharge or fill material. If additional space is needed, use Block 14.

7. Names, addresses and telephone numbers of adjoining property owners, lessees, etc., whose property also adjoins the waterway.

8. Location where proposed activity exists or will occur.

|   |  |
|---|--|
| Address:  | Tax Assessors Description: (if known)                            |
| Street, road or other descriptive location _____                        | Map No.                  Subdiv. No.                  Lot No.    |
| In or near city or town _____   | Sec.                          Twp.                          Rge. |
| County                          State                          Zip Code |  |

9. Name of waterway at location of the activity.

10. Date activity is proposed to commence. \_\_\_\_\_

Date activity is expected to be completed \_\_\_\_\_

11. Is any portion of the activity for which authorization is sought now complete?  YES  NO

If answer is "Yes" give reasons in the remark section. Month and year the activity was completed \_\_\_\_\_ . Indicate the existing work on the drawings.

12. List all approvals or certifications required by other federal, interstate, state or local agencies for any structures, construction, discharges, deposits or other activities described in this application.

| <u>Issuing Agency</u> | <u>Type Approval</u> | <u>Identification No.</u> | <u>Date of Application</u> | <u>Date of Approval</u> |
|-----------------------|----------------------|---------------------------|----------------------------|-------------------------|
|-----------------------|----------------------|---------------------------|----------------------------|-------------------------|

13. Has any agency denied approval for the activity described herein or for any activity directly related to the activity described herein?

Yes  No (If "Yes" explain in remarks)

14. Remarks (Checklist, Appendix H for additional information required for certain activities).

15. Application is hereby made for a permit or permits to authorize the activities described herein. I certify that I am familiar with the information contained in this application, and that to the best of my knowledge and belief such information is true, complete, and accurate. I further certify that I possess the authority to undertake the proposed activities.

\_\_\_\_\_  
Signature of Applicant or Authorized Agent

The application must be signed by the applicant; however, it may be signed by a duly authorized agent (named in Item 5) if this form is accompanied by a statement by the applicant designating the agent and agreeing to furnish upon request, supplemental information in support of the application.

18 U. S. C. Section 1001 provides that: Whoever, in any manner within the jurisdiction of any department or agency of The United States knowingly and willfully falsifies, conceals, or covers up by any trick, scheme, or device a material fact or makes any false, fictitious or fraudulent statements or representations or makes or uses any false writing or document knowing same to contain any false, fictitious or fraudulent statement or entry, shall be fined not more than \$10,000 or imprisoned not more than five years, or both. Do not send a permit processing fee with this application. The appropriate fee will be assessed when a permit is issued.





PETITION FOR CHANGE IN PURPOSE OF USE

Application \_\_\_\_\_ Permit \_\_\_\_\_ License \_\_\_\_\_

State Water Resources Control Board  
Division of Water Rights  
77 Cadillac Drive  
Sacramento, CA 95825

I request permission to change the purpose of use described in this permit or license as follows:

\_\_\_\_\_  
(State all purposes for which water is to be used)

Give reason for proposed change: \_\_\_\_\_

Does this change involve any place of use not described in the permit or license? \_\_\_\_\_. If answer is yes, give legal description:  
(yes or no)

THIS CHANGE DOES NOT INVOLVE AN INCREASE IN THE AMOUNT OF THE APPROPRIATION OR SEASON OF USE.

Give names and addresses of persons known to you who may be affected by the proposed change:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
I declare under penalty of perjury that the above is true and correct to the best of my knowledge and belief.  
Dated: \_\_\_\_\_, 19\_\_\_\_, at \_\_\_\_\_, California.

Section 1547 of the Water Code requires a \$10 filing fee with petitions for changes.

PETITION FOR CHANGE  OF POINT OF DIVERSION  
 BY ADDITION OF POINT OF REDIVERSION  
 OF PLACE OF USE

Application \_\_\_\_\_ Permit \_\_\_\_\_ License \_\_\_\_\_

State Water Resources Control Board  
Division of Water Rights  
77 Cadillac Drive  
Sacramento, CA 95825  
(916) 920-6151

I hereby petition for changes noted above and shown on the accompanying map and described as follows:

\_\_\_\_\_  
(Give tie by bearing and distance or by coordinate distances from some  
\_\_\_\_\_  
government corner and the 40-acre subdivisions in which the new point  
\_\_\_\_\_  
of diversion lies or acreage to be irrigated within each 40-acre tract.)

GIVE REASON FOR PROPOSED CHANGE: \_\_\_\_\_

\_\_\_\_\_  
WILL OLD POINT OF DIVERSION OR PLACE OF USE BE ABANDONED? \_\_\_\_\_  
(yes or no)

WATER WILL BE USED FOR \_\_\_\_\_ PURPOSES.

I have access to the proposed new point of diversion or control the place of use proposed by virtue of

\_\_\_\_\_  
(ownership, lease, verbal, or written agreement)

\_\_\_\_\_  
(If by lease or agreement, state name and address of party or parties from whom access has been obtained.)

Are there any persons taking water from the stream between the old point of diversion and the new point of diversion? \_\_\_\_\_  
(yes or no)

Give names and addresses, if answered yes, as well as other persons known to you who may be affected by the proposed change.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
THIS CHANGE DOES NOT INVOLVE AN INCREASE IN THE AMOUNT OF THE APPROPRIATION OR SEASON OF USE.

I declare under penalty of perjury that the above is true and correct to the best of my knowledge and belief.

Dated: \_\_\_\_\_, 19\_\_\_\_, at \_\_\_\_\_ California.

\_\_\_\_\_  
Note: Section 1547 of the Water Code requires a \$10 filing fee with petitions for changes.



## 5. JUSTIFICATION OF AMOUNT

- a. IRRIGATION: Maximum acreage to be irrigated in any one year will be \_\_\_\_\_ acres.

| CROP | ACRES | METHOD OF IRRIGATION<br>(Sprinklers, flooding, etc.) | ACRE-FEET<br>Annually | NORMAL SEASON  |             |
|------|-------|--|-----------------------|----------------|-------------|
|      |       |  |                       | Beginning Date | Ending Date |
|      |       |  |                       |                |             |
|      |       |  |                       |                |             |

- b. DOMESTIC: The number of residences to be served \_\_\_\_\_ . Separately owned: YES  NO   
 The total number of people to be served \_\_\_\_\_ . Estimated daily use per person \_\_\_\_\_ (gallons per day)  
 The total area of domestic lawns and gardens \_\_\_\_\_ (square feet)

Miscellaneous domestic uses \_\_\_\_\_ (Dust control area, Number and kind of domestic animals, etc.)

- c. STOCKWATERING: Kind of stock \_\_\_\_\_ . Maximum Number \_\_\_\_\_ . Describe type of operation (feedlot, dairy, range, etc.) \_\_\_\_\_

- d. RECREATIONAL: Type of recreation \_\_\_\_\_  
 Private \_\_\_\_\_ . Open to public without charge \_\_\_\_\_ . Open to public admission charged \_\_\_\_\_

(Submit "Supplement to Application", form SWRCB 1-1, for justification of amount for uses not listed above.)

## 6. DIVERSION WORKS

- a. Diversion will be by pumping from \_\_\_\_\_ Pump discharge \_\_\_\_\_ . Horsepower \_\_\_\_\_ (sumo, offset well, channel, reservoir, etc.)

- b. Diversion will be by gravity by means of \_\_\_\_\_ (pipe in unconstructed channel, pipe through dam, siphon, gate, etc.)

- c. Main conduit from diversion point to first lateral or offstream storage reservoir:

| CONDUIT<br>(Pipe or channel) | MATERIAL<br>(Kind of Pipe or channel lining) | CROSS SECTIONAL DIMENSION<br>(Pipe diameter or ditch depth and top and bottom width) | LENGTH<br>(feet) | TOTAL LIFT OR FALL<br>(feet) |          | CAPACITY<br>(estimated) |
|------------------------------|--|--|------------------|------------------------------|----------|-------------------------|
|                              |  |  |                  |                              | (+ or -) |                         |
|                              |  |  |                  |                              |          |                         |
|                              |  |  |                  |                              |          |                         |

- d. The following applies to storage reservoirs: (For reservoirs having a capacity of 25 acre-feet or more, complete supplemental form SWRCB 1-11.)

| Name or number of reservoir, if any | DAM   |                          |                  | RESERVOIR                                      |  |                                  |                  |
|-------------------------------------|---|--------------------------|------------------|--|--|----------------------------------|------------------|
|                                     | Height of dam from streambed to soilway level (ft.) | Material of construction | Dam Length (ft.) | Freeboard Dam height above soilway crest (ft.) | Approximate surface area when full (acres) | Approximate capacity (acre-feet) | Max. water depth |
|                                     |   |                          |                  |  |  |                                  |                  |
|                                     |   |                          |                  |  |  |                                  |                  |

- e. Estimated total cost of the diversion works proposed is \_\_\_\_\_ (Give only cost of intake, or headworks, pumps, storage reservoirs, and main conduits.)

## 7. PLACE OF USE

- a. Applicant owns the land where the water will be used: YES  NO  . Land is in joint ownership: YES  NO  .

All joint owners should include their names as applicants and sign the application. If applicant does not own land where the water will be used, give name and address of owner and state what arrangements have been made with the owner.

- b.

| USE IS WITHIN<br>40-acre Sub-division | SECTION | TOWNSHIP | RANGE | BASE AND MERIDIAN | IF IRRIGATION         |                                  |
|---------------------------------------|---------|----------|-------|-------------------|-----------------------|----------------------------------|
|                                       |         |          |       |                   | State Number of Acres | Presently cultivated (Yes or No) |
| 1/2 of 1/2                            | 1/2     |          |       |                   |                       |                                  |
| 1/2 of 1/2                            | 1/2     |          |       |                   |                       |                                  |
| 1/2 of 1/2                            | 1/2     |          |       |                   |                       |                                  |
| 1/2 of 1/2                            | 1/2     |          |       |                   |                       |                                  |
| 1/2 of 1/2                            | 1/2     |          |       |                   |                       |                                  |

If area is unsurveyed, show the location as if lines of the public land survey were projected. If space does not permit listing all 40-acre tracts, include one section sheet or state sections, townships and ranges, and show detail on map. For public districts or other extremely large areas, see Page 16 of instruction booklet "How to File an Application to Appropriate Unappropriated Water in California".

## 8. COMPLETION SCHEDULE

- a. Proposed date of project commencement: \_\_\_\_\_ . b. Estimated date of Project completion: \_\_\_\_\_ .  
 c. Estimated date of complete application of water to proposed use: \_\_\_\_\_ . d. If complete, date of completion: \_\_\_\_\_ .

## 9. GENERAL

- a. What is the name of the post office most used by those living near the proposed point of diversion? \_\_\_\_\_
- b. Does any part of the place of use comprise a subdivision on file with the State Department of Real Estate? YES  NO . If Yes, state name of subdivision \_\_\_\_\_. If No, is subdivision of these lands contemplated? YES  NO .
- Is it planned to individually meter each service connection? YES  NO . If Yes, when? \_\_\_\_\_
- c. Have you consulted the California Department of Fish and Game concerning this proposed project? YES  NO . If Yes, state the Department's opinion concerning the potential effects of your proposed project on fish and other wildlife and state measures required for mitigation \_\_\_\_\_

If No, state the effects on fish and other wildlife you foresee as potentially arising from your proposed project. \_\_\_\_\_

- d. Please name other public agencies, if any, from which you have obtained or are required to obtain approvals regarding this project: \_\_\_\_\_
- e. Is reclaimed water available or do you expect such to be available in the near future which could be used in lieu of the water sought under this application? YES  NO  If Yes, explain: \_\_\_\_\_
- f. Is it practical to reduce the amount applied for by reusing or reclaiming a portion of the water appropriated? YES  NO
- g. What are the names and addresses of diverters of water from the source of supply downstream from the proposed point of diversion? \_\_\_\_\_

## 10. EXISTING WATER RIGHT

Check the appropriate box below:

- A.  Applicant does not claim an existing right for the use of water sought by this application.
- B.  Applicant claims an existing right for use of water sought by this application but agrees NOT to exercise said right so long as a permit or license for such use remains in effect.
- C.  The water sought by this application is for additional water over that claimed under an existing right.

Complete Table below if B or C is checked:

| Nature of Rights<br>(irrigation, appropriative,<br>purchased water, etc.) | Year of<br>First Use | Use made in recent years<br>including amount, if known | Season<br>of Use | Source | Location of<br>Point of Diversion |
|---|----------------------|--|------------------|--------|-----------------------------------|
|   |                      |  |                  |        |                                   |
|   |                      |  |                  |        |                                   |

## 11. AUTHORIZED AGENT (Optional)

With respect to:  All matters concerning this water right application,  those matters designated as follows: \_\_\_\_\_

Name \_\_\_\_\_ Address \_\_\_\_\_  
Zip Code: \_\_\_\_\_ (Telephone No. of agent between 8 a.m. and 5 p.m.)

is authorized to act on my behalf as my agent.

## 12. SIGNATURE OF APPLICANT

I (we) declare under penalty of perjury that the above is true and correct to the best of my (our) knowledge and belief.

Dated \_\_\_\_\_ 19 \_\_\_\_\_, at \_\_\_\_\_, California

Ms. M.

Miss, Mrs.

(Signature of applicant) (Refer to Section 671 of the Board's regulations)

If applicants are members of the same family

(i.e., husband, wife, mother, father, son, brother, sister, etc.) or reside at the same address, please indicate the relationship:

Ms. M.

Miss, Mrs.

(Signature of applicant) (Refer to Section 671 of the Board's regulations)

Additional information needed for preparation of this application may be found in the booklet entitled "HOW TO FILE AN APPLICATION TO APPROPRIATE UNAPPROPRIATED WATER IN CALIFORNIA". If there is insufficient space for answers in this form, attach extra sheets.

Please cross reference all remarks to the numbered paragraph to which they may refer. Send application in duplicate to the STATE WATER RESOURCES CONTROL BOARD, DIVISION OF WATER RIGHTS, 77 Cadillac Drive, Sacramento, CA 95825, with \$10 minimum filing fee.



## SUPPLEMENT TO APPLICATION

(This supplement is required for uses other than irrigation, domestic, stockwatering, and recreation and for surface storage of 25 acre-feet or more.)

## 5. JUSTIFICATION of AMOUNT

e. MUNICIPAL: Estimated projected use:

| POPULATION                            |      | MAXIMUM MONTH                       |                         | ANNUAL USE                          |                      |                 |
|---------------------------------------|------|-------------------------------------|-------------------------|-------------------------------------|----------------------|-----------------|
| 5-year periods until use is completed |      | Average daily use per capita (gal.) | Rate of Diversion (cfs) | Average daily use (gal. per capita) | Acre-foot per capita | Total Acre-feet |
| PERIOD                                | POP. |                                     |                         |                                     |                      |                 |
| Present                               |      |                                     |                         |                                     |                      |                 |
| 19                                    |      |                                     |                         |                                     |                      |                 |
| 19                                    |      |                                     |                         |                                     |                      |                 |
| 19                                    |      |                                     |                         |                                     |                      |                 |
| 19                                    |      |                                     |                         |                                     |                      |                 |

Month of maximum use during year \_\_\_\_\_ . Month of minimum use during year \_\_\_\_\_ .

Is it planned to individually meter each service connection? YES  NO  . If so, when? \_\_\_\_\_

f. HEAT CONTROL: The total area of heat protection is \_\_\_\_\_ acres. Type of crop protected \_\_\_\_\_ (net acreage)

Rate at which water is applied to use: \_\_\_\_\_ (gpm) (cfs) (circle one)

The heat protection season will begin about \_\_\_\_\_ (beginning date) and end about \_\_\_\_\_ (ending date)

g. FROST PROTECTION: The total area of frost protection is \_\_\_\_\_ acres. Type of crop protected \_\_\_\_\_ (net acreage)

Rate at which water is applied to use: \_\_\_\_\_ (gpm) (cfs) (circle one)

The frost protection season will begin about \_\_\_\_\_ (beginning date) and end about \_\_\_\_\_ (ending date)

h. INDUSTRIAL USE: Type of industry \_\_\_\_\_

Basis of determination of amount of water needed \_\_\_\_\_

i. MINING: The name of the mine is \_\_\_\_\_ (name of claim) Patented  or Unpatented  .

The nature of the mine is \_\_\_\_\_ . Mineral to be mined is \_\_\_\_\_

Type of milling or processing \_\_\_\_\_

After use, the water will be discharged into \_\_\_\_\_ (name of stream)

in \_\_\_\_\_ of Sec. \_\_\_\_\_, T \_\_\_\_\_, R \_\_\_\_\_, \_\_\_\_\_ B.&amp;M. (state 40-acre subdivision)

j. POWER USE: The total fall to be utilized is \_\_\_\_\_ feet. The maximum amount of water to be used through the penstock is \_\_\_\_\_ cubic feet per second. The maximum theoretical horsepower capable of being generated by the works is \_\_\_\_\_ (cubic feet per second x fall ÷ 8.8)

The use to which power is to be applied is \_\_\_\_\_ . The nature of the works by means of which power is to be developed is \_\_\_\_\_ (for distribution and sale or private use, etc.)

The size of the nozzle to be used is \_\_\_\_\_ inches. (Turbine, Pelton wheel, etc.)

After use, the water will be discharged into \_\_\_\_\_ in \_\_\_\_\_ of (name of stream) (state 40-acre subdivision)

Sec. \_\_\_\_\_, T \_\_\_\_\_, R \_\_\_\_\_, \_\_\_\_\_ B.&amp;M.

k. OTHER: Describe use: \_\_\_\_\_ . Basis of determination of amount of water needed: \_\_\_\_\_

## 6. DIVERSION WORKS (Storage Reservoirs)

The following applies to storage reservoirs having a capacity of 25 acre-feet or more:

| Diameter of outlet pipe (inches) | Length of outlet pipe (feet) | Vertical distance between entrance and exit of outlet pipe (feet) Fall | Vertical distance from spillway to outlet pipe in reservoir (feet) Head | Estimated storage below outlet pipe entrance (Dead storage) |
|----------------------------------|------------------------------|--|---|---|
|                                  |                              |  |   |   |
|                                  |                              |  |   |   |
|                                  |                              |  |   |   |

State Water Resources Control Board  
DIVISION OF WATER RIGHTS  
ENVIRONMENTAL INFORMATION

## COUNTY INFORMATION

1. What is (are) the County Tax Assessor's parcel number(s) for the project site? \_\_\_\_\_
2. What is the County zoning designation for the project site? \_\_\_\_\_
3. Is the proposed project consistent with the current County zoning designation?  YES  NO
4. Which of the following best describes the type(s) of land use(s) generally occurring on other land adjacent to the project?  
 agricultural     residential     industrial     other (describe): \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_
5. Does the project involve grading or other disturbance of the soil surface?  YES  NO If no, explain: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

If yes, which of the following measures do you intend to use during construction and operation of the project in order to prevent erosion of soil into surface waters?

- construction only during dry season.     immediate reseeded of disturbed areas,     contour plowing in areas of use
- other (explain): \_\_\_\_\_  
 \_\_\_\_\_
- none (explain): \_\_\_\_\_  
 \_\_\_\_\_
6. Will the County require issuance of any of the following?
    - a. grading permit:  YES  NO
    - b. watercourse obstruction permit:  YES  NO
    - c. change of zoning or variance:  YES  NO
    - d. use permit:  YES  NO
    - e. other permit/approval:  YES  NO If yes, explain: \_\_\_\_\_  
 \_\_\_\_\_

If the answer to any of the above is yes, will the County prepare an environmental assessment of the project and become lead agency pursuant to the California Environmental Quality Act?  YES  NO

7. Sewage wastes shall be disposed of by which of the following means?
  - County approved septic tank(s) under permit number(s): \_\_\_\_\_
  - community sewer
  - other (explain): \_\_\_\_\_  
 \_\_\_\_\_
  - no sewage will be generated by the project

## FISH AND WILDLIFE INFORMATION

8. Which of the following best describes the general vegetative habitat in the project area?
  - grassland     oak woodland     brush/chaparral     pine forest     hardwood forest     marsh
  - cultivated land (describe): \_\_\_\_\_
  - other (describe): \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_
9. Does the project involve removal or flooding (such as in a reservoir) of any grassland, brush, trees, or riparian (streamside) vegetation?
  - YES  NO If yes, explain and indicate number of acres involved: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

ATTACH ADDITIONAL SHEETS, IF NEEDED

10/6/91

10. Which of the following types of fisheries exist in the source? (Note: this information is available from the California Department of Fish and Game - see attached regional office listings.)

MIGRATORY

- salmon  
 steelhead trout  
 sturgeon  
 striped bass  
 shad  
 none

NONMIGRATORY

- trout  
 bluegill  
 black bass  
 catfish  
 none

other (explain): \_\_\_\_\_

Who is the source of information for the above?

Name: \_\_\_\_\_ Telephone: ( ) \_\_\_\_\_

11. Does a California Department of Fish and Game representative expect that the proposed project would substantially reduce the habitat of a fish or wildlife species or cause a fish or wildlife population to drop below self-sustaining levels?  YES  NO

Who did you contact regarding the above?

Name: \_\_\_\_\_ Telephone: ( ) \_\_\_\_\_

WATER QUALITY INFORMATION

12. Will construction or operation of the project involve the discharge of any of the following materials into groundwater or surface waters?

- a. pesticides, herbicides, or fungicides  YES  NO  
b. fertilizers  YES  NO  
c. metallic wastes  YES  NO  
d. industrial chemicals  YES  NO  
e. decomposable organic materials  YES  NO  
f. soil  YES  NO

13. If you answered yes to any of the above in question No. 12, will the appropriate Regional Water Quality Control Board (see attached regional office listings) require issuance of a permit to discharge wastes?  YES  NO Explain: \_\_\_\_\_

Who is the source of information for the above?

Name: \_\_\_\_\_ Telephone: ( ) \_\_\_\_\_

14. Will the project divert all of the existing flow in the source at any time?  YES  NO If yes, during what months will this normally occur? \_\_\_\_\_

ARCHAEOLOGICAL AND HISTORICAL INFORMATION

15. Are there any sites of known archaeological or historical value located within the general project area?  YES  NO

If yes, will construction or operation of the project disturb any artifacts or structures of archaeological or historical value?  YES  NO

Explain: \_\_\_\_\_

PHOTOGRAPHS

16. Enclose labeled colored photographs of each point of diversion and each place of use described in this application (Polaroid snapshots will be accepted.)

I (we) declare under penalty of perjury that the above is true and correct to the best of my (our) knowledge and belief.

Dated: \_\_\_\_\_ 19\_\_\_\_, at \_\_\_\_\_, California.

Ms. Mr. \_\_\_\_\_

Miss, Mrs. \_\_\_\_\_

Ms. Mr. \_\_\_\_\_

Miss, Mrs. \_\_\_\_\_

(ATTACH ADDITIONAL SHEETS, IF NEEDED)



ATTACHMENT NO. 7

DEPARTMENT OF WATER RESOURCES  
(DIVISION OF SAFETY OF DAMS)

APPLICATION FOR APPROVAL OF PLANS  
AND SPECIFICATIONS FOR THE REPAIR  
OR ALTERATION OF A DAM AND RESERVOIR



[ For full information concerning the filling out and filing of this form send for Statutes and Regulations Pertaining to Supervision of Dams and Reservoirs. ]

STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES  
DIVISION OF SAFETY OF DAMS

Dam No. \_\_\_\_\_ Application Filed \_\_\_\_\_  
Applicant must not fill in the above blanks.

APPLICATION FOR  
APPROVAL OF PLANS AND SPECIFICATIONS FOR THE  
REPAIR OR ALTERATION OF A DAM AND RESERVOIR

[ This application involves in no way the right to appropriate water ]  
To secure the right to appropriate water, application should be made to the State Water Resources Control Board on forms which will be furnished upon request.

I, \_\_\_\_\_ of \_\_\_\_\_  
Name of individual signing application Address  
County of \_\_\_\_\_ State of \_\_\_\_\_, hereby make application for the approval of  
plans and specifications for the <sup>repair</sup> <sub>alteration</sub> of \_\_\_\_\_ dam and reservoir.  
(Strike out one) Name of dam and reservoir  
The owner of the dam and reservoir is \_\_\_\_\_  
Name of owner  
of \_\_\_\_\_ County of \_\_\_\_\_ State of \_\_\_\_\_  
Address  
If the owner is a corporation, give name and address of president and secretary—

The applicant is acting for the owner in the capacity of \_\_\_\_\_  
Agent, Lessee, Trustee, Engineer, etc.

Location of Dam

1. The dam is in \_\_\_\_\_ County, in the \_\_\_\_\_ 1/4, Sec. \_\_\_\_\_, Tp. \_\_\_\_\_, R. \_\_\_\_\_, B. & M. \_\_\_\_\_  
and is located on \_\_\_\_\_ tributary to \_\_\_\_\_  
Creek, river or watershed Creek or river

Description of Proposed Work

2. Type of dam \_\_\_\_\_  
Concrete arch or gravity, earth, rockfill, etc.  
3. Description of work contemplated \_\_\_\_\_  
Use cross sections or exhibits if necessary

4. Work will result in \_\_\_\_\_ the maximum storage level.  
"No change at" or "lowering"  
This form is not to be used if the alteration will increase the water storage elevation of the reservoir as previously operated.  
5. Work is to commence by \_\_\_\_\_ and to be completed by \_\_\_\_\_  
6. Engineer \_\_\_\_\_ 7. Contractor \_\_\_\_\_

SIGN ALL  
COPIES [signed]

Applicant



ATTACHMENT NO. 8

DEPARTMENT OF WATER RESOURCES  
(DIVISION OF SAFETY OF DAMS)

APPLICATION FOR APPROVAL OF PLANS  
AND SPECIFICATIONS FOR THE  
CONSTRUCTION OR ENLARGEMENT OF  
A DAM AND RESERVOIR



For full information concerning the filling out and filing of this form send for Statistics and Regulations Pertaining to Supervision of Dams and Reservoirs.

STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES  
DIVISION OF SAFETY OF DAMS

Application No. \_\_\_\_\_ Filed \_\_\_\_\_  
Applicant must not fill in the above blanks

APPLICATION FOR APPROVAL OF PLANS AND  
SPECIFICATIONS FOR THE CONSTRUCTION  
OR ENLARGEMENT OF A DAM AND RESERVOIR

[ This application involves in no way the right to appropriate water  
To secure the right to appropriate water, application should be made to the State  
Water Resources Control Board on forms which will be furnished upon request. ]

I, \_\_\_\_\_ of \_\_\_\_\_  
Name of individual signing application Address  
County of \_\_\_\_\_ State of \_\_\_\_\_, hereby make application for the approval of  
the plans and specifications for the construction or enlargement of \_\_\_\_\_ dam.  
Strike out one Name of dam  
The owner of the dam and reservoir is \_\_\_\_\_  
Name of owner  
of \_\_\_\_\_ County of \_\_\_\_\_ State of \_\_\_\_\_  
Address  
Is the owner a Public Utility? \_\_\_\_\_  
Yes or No  
If the owner is a corporation, give name and address of president and secretary

The applicant is acting for the owner in the legal capacity of \_\_\_\_\_  
Agent, Lessee, Trustee, etc.

Location of Dam

1. The dam is in \_\_\_\_\_ County, in the \_\_\_\_\_ 4. Sec. \_\_\_\_\_ Tp. \_\_\_\_\_ R. \_\_\_\_\_ B. & M.  
and is located on \_\_\_\_\_ tributary to \_\_\_\_\_  
Creek, river or watershed Creek or river

Description of Dam and Reservoir  
(If for an enlargement, the data given below are for the enlarged dam)

2. Type of dam \_\_\_\_\_ 3. Length of crest \_\_\_\_\_ ft.  
Concrete arch or gravity, earth, rockfill, etc.  
4. Height lowest outside limit of barrier to M.S.E.\* \_\_\_\_\_ ft.  
5. Freeboard \_\_\_\_\_ ft. 6. Thickness at top \_\_\_\_\_ ft. 7. Spillway crest elevation \_\_\_\_\_ ft.  
MSE\* to top  
8. Slope upstream\* \* \_\_\_\_\_ 9. Slope downstream\* \* \_\_\_\_\_  
\*\*This information to be supplied for earth or rockfill dams.  
10. Amount of material in dam \_\_\_\_\_ cu. yds. 11. Estimated cost \$ \_\_\_\_\_  
Fee will be based on this figure  
12. Spillway data \_\_\_\_\_  
Type, capacity, etc.  
13. Outlet data \_\_\_\_\_  
Type, capacity, etc.  
14. Elevation of crest of dam \_\_\_\_\_ above \_\_\_\_\_ datum  
Approximate elevation to be given if true elevation not available  
15. Area of reservoir at M.S.E.\* \_\_\_\_\_ acres. 16. Capacity of reservoir at M.S.E.\* \_\_\_\_\_ ac. ft.  
17. Drainage area \_\_\_\_\_ sq. mi.  
\*Maximum Storage Elevation \_\_\_\_\_ ft.  
To spillway crest, top of flashboards or top of spillway gates whichever is greatest

Form DWR 3

18. State what provisions will be made to divert flood flows during construction \_\_\_\_\_

It necessary to clarify this feature, drawings showing the temporary diversion works will be required

### Precipitation, Flood or Inflow Data

19. Rainfall. If records of rainfall other than those published by the U.S. Weather Bureau are available, state the location and names of the stations and the maximum intensity of rainfall for 1, 12, 24 and 48 hours. (Use extra sheets or exhibits if necessary.)

20. State the estimated maximum rainfall on watershed \_\_\_\_\_ inches of rain in \_\_\_\_\_ hours.

21. Flood or Inflow data. If records of flood flow other than those published by the U.S.G.S. are available state: location and dates of measurements; maximum flow in cubic feet per second; duration in hours of crest flow and of the flood. State the estimated maximum flood flow in cubic feet per second and the duration of flood and of crest flow in hours. State maximum inflow if flow data are not applicable. (Use extra sheets or exhibits if necessary.)

### General Information

22. State the purpose of the dam and reservoir \_\_\_\_\_  
Diversion only; storage only; storage and diversion; debris storage, etc.

23. State the use that is to be made of water \_\_\_\_\_  
Municipal, domestic, irrigation, power, sailing or recreation

24. Engineers \_\_\_\_\_ : \_\_\_\_\_  
Chief Engineer Resident Engineer  
Consulting Engineer

25. If the proposed dam and reservoir is to be built under federal license or permit, state what department has jurisdiction \_\_\_\_\_

26. The maps, plans and specifications and filing fee of \$ \_\_\_\_\_ accompanying this application are a part thereof.

[Signed] \_\_\_\_\_  
(ORIGINAL SIGNATURE REQUIRED ON ALL COPIES) this \_\_\_\_\_ day of \_\_\_\_\_ 19 \_\_\_\_\_  
Applicant

### APPROVAL OF APPLICATION NO. \_\_\_\_\_, INCLUDING THE PLANS AND SPECIFICATIONS

This is to certify that Application No. \_\_\_\_\_, including the plans and specifications for the \_\_\_\_\_ dam and reservoir has been examined and the same is hereby \_\_\_\_\_ approved, subject to the following terms and limitations:

1. Construction work shall be started within one year from date.
2. No foundations or abutments shall be covered by the material of the dam until the department has been given an opportunity to inspect and approve the same.

Witness my hand and the seal of the Department of Water Resources of the State of California

this \_\_\_\_\_ day of \_\_\_\_\_ 19 \_\_\_\_\_

Division Engineer

ATTACHMENT NO. 9

DEPARTMENT OF WATER RESOURCES  
(THE RECLAMATION BOARD)

APPLICATION FOR APPROVAL OF PLANS  
AND/OR ENCROACHMENT PERMIT



For Office Use

Application No. 

## APPLICATION FOR APPROVAL OF PLANS AND/OR ENCROACHMENT PERMIT

1 Application to the State Reclamation Board for approval to \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_2. Section \_\_\_\_\_ Township <sup>N</sup> <sub>S</sub> Range <sup>E</sup> <sub>W</sub> County \_\_\_\_\_

3. Please check exhibits accompanying application.

- a.  Location or vicinity map, to scale, showing location of proposed work in relation to known topographic features, to permit visitation and/or inspection of the work.
- b.  A complete plan of the proposed work to scale, showing dimensions, materials of construction, and relationship of the proposed work to adjacent or affected project features.
- c.  A cross section of the levee, berm and stream area with dimensions and elevations of the levee crown, levee toes, flood plane, low water level, etc., with reference to the U.S. Geological Survey, U.S. Corps of Engineers, or other datum generally used within the locale.
- d.  Profiles of existing or proposed levees, fills, or other obstructions in the stream or overflow area with reference to U.S. Geological Survey, U.S. Corps of Engineers, or other datum generally used within the locale.

4. Please Print:

Name of ApplicantAddress-Zip CodeTelephone Number

Signature \_\_\_\_\_ Date \_\_\_\_\_

5. Endorsement:

We, the Trustee of \_\_\_\_\_  
(DISTRICT NAME AND NUMBER)

hereby approve and give consent to the execution of the above plan subject to the following conditions:

 Conditions listed on back of this form No conditions

Date \_\_\_\_\_

Signatures of Trustees:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

6. Has any agency made an environmental review of your proposed project under the provisions of the California Environmental Quality Act of 1970? If Yes, check . Please furnish copy. If Pending, check .

Reviewing Agency name: \_\_\_\_\_

\_\_\_\_\_ State Clearing House SCH. No. \_\_\_\_\_

7. Name and address of owners of adjacent land parcels sharing a length or point of common boundary with the land upon which the contents of this application apply.

| <u>Name</u> | <u>Address</u> | <u>Zip Code</u> |
|-------------|----------------|-----------------|
| _____       | _____          | _____           |
| _____       | _____          | _____           |
| _____       | _____          | _____           |
| _____       | _____          | _____           |
| _____       | _____          | _____           |
| _____       | _____          | _____           |

8. Applicant's Statement of Water Rights:

If the proposed work under this application is for the purpose of diverting water from a public watercourse, submit the following information:

- a. Water right permit or license number.
- b. Statement of water diversion and use number  
\* (if riparian or pre-1914, give appropriation number).
- c. Will there be a change in point or rate of diversion if Reclamation Board permit is granted, and
- d. Has a petition for change of point or rate of diversion been filed with the State Water Resources Control Board?

\* NOTE - Application is not complete without this information.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

ATTACHMENT NO. 10

STATE LANDS COMMISSION

APPLICATION FOR DREDGING PERMIT OR LEASE  
OF STATE LANDS



APPLICATION REQUIREMENTS CHECKLIST  
State of California - State Lands Commission

The following is the list of requirements for application for State Lands Commission action. The forms and data below are necessary for the projects indicated.

The staff of the Commission has attempted to enclose all of the information requirements necessary for your project application as it has been described to the staff. However, the applicant is advised that any of the information listed below may be required during the processing of the application.

- General Data, Form 54.2
- Leases and Permits for Tideland and/or Submerged Lands, Form 54.4
- Leases and Permits for Non-tide and/or submerged Lands, Form 54.5
- Environmental Data Form 54.3  EIF Form 59.2  EIF Form 69.3
- Proposed Pipelines—Offshore State Lands, Form 52.1(a)
- Proposed Pipelines—Inland Waterways, Form 52.1(b)
- Existing Pipelines—Offshore State Lands, Form 52.1(c)
- Existing Pipelines—Inland Waterways, Form 52.1(d)
- Purchase of State school lands, Forms 60.6 and 63.1
- Recreational Piers (PRC #6503)  Form 51.4(a)  Form 51.4(b)
- Highway uses, plats required per Commission Form 52.6. Evidence that the reasonable value of the State Lands and/or materials used is deposited in the General Fund and credited to the Resources Protection Account will be required.
- Railroad Right of Way, plats required per Commission Form 52.7
- Boundary Determination and/or Exchange Agreement, Commission Form 52.8
- Salvage Permit, Commission Form 69.5 and the requirements in 2 California Administrative Code, Article 2.5
- Sublease on Granted Lands, including the information outlined in 2 California Administrative Code, Article 9.
- Fair market rental - if this application will require the staff of the Commission to determine the fair market rental value of the lands to be leased, the applicant shall be required to submit data sufficient for Commission staff to make such evaluation. The information required may include but is not necessarily limited to, financial statements, option agreements, comparable sales/lease data, and/or other information necessary in order to make the fair rental determination.
- Oil and Gas Compensatory Agreement, Form 33.32
- Oil and Gas (Negotiated), Form 33.33
- Geothermal Prospecting Permit, Form 33.42
- Geothermal Lease (Preferential), Form 33.39
- Mineral Prospecting Permit, Form 33.44
- Mineral Lease (Preferential), Form 33.34
- Oil and Gas, Geothermal, and Other Mineral Lease (Competitive), Form 33.40
- Dredging Permits (Public Resources Code #6303), Form 33.41
- Modification of Right of Surface Entry (PRC 6401), Form 33.43
- Resumption of Drilling Operations, Form 33.36
- Ocean Floor Well Proposals, Form 33.37
- Well Proposals (New, redrill, repair, recompletion, abandonment, etc.), Form 33.35
- Alteration of Facilities, Form 33.38
- Signature and Certification Page, Form 54.2

Failure of an applicant to provide the information outlined in this form within the time limits prescribed by staff of the State Lands Commission may result in significant delays in determining that an application is complete; or, cancellation of the application.

In those instances where Commission costs and expenses are chargeable to the applicant, the applicant shall deposit with the Commission, the applicable expense deposit. If the deposits are not received within twenty-one (21) days of request, the application may be cancelled. Processing costs and environmental fees are calculated based on actual or estimated costs plus proportional overhead. If the estimated cost or fee is less than the actual cost, the applicant will be required to submit these additional costs within the allowable time period.

The preceding information is necessary in order to process your application for lease of State-owned land. You have the right to review files maintained about you by the State Lands Commission, except as provided for by law. The Commission Records Coordinator, State Lands Commission, 1807 - 13th Street, Sacramento, CA 95814, telephone (916) 445-9742, is responsible for maintenance of the information which is collected by the Commission.

The conduct of the State Lands Commission is governed by Public Resources Code Sections 6000, et seq. and 2 California Administrative Code Sections 1900, et seq. These provisions, by reference, are included herein.

Your application has been assigned the number indicated in the top right corner of this sheet. Please refer to it whenever communicating with this office.



G. IDENTIFY, (IF KNOWN), OTHER PUBLIC AGENCIES HAVING APPROVAL AUTHORITY OVER YOUR PROPOSED PROJECT. (e.g., Corps of Engineers, Local Planning Agency, etc.).

ANY OF THE ABOVE APPROVALS OBTAINED MUST BE SUBMITTED WITH THE APPLICATION.

H. PROJECT DESCRIPTION:

The applicant shall provide a narrative description of the project with references to maps, plot plans, financial analysis, and other graphics as may be appropriate. The project should be defined in sufficient detail so that Commission staff can analyze and evaluate the project. Sufficient data should be supplied which will:

1. Show how the proposed project will be carried out, including initial construction equipment, techniques, time schedules and operational requirements.
2. Show the project's future phases or extensions, if any.
3. Detail other proposed projects that will be dependent upon this project or will be directly influenced by this project.
4. Describe existing development in the vicinity which will directly (or indirectly) influence or be influenced by this project.
5. Enable the Commission to determine if the project:
  - a. is in the best interest of the State;
  - b. conflicts with the various trusts under which State lands are held;
  - c. is a viable use of State lands.

I. FEES:

1. A non-refundable filing fee of \$25.00 is required of all applicants.
2. An environmental processing fee may be required.
3. Applicants for the following leases or permits which do not provide for monetary consideration, or for any of the following actions which do not result in any increase in monetary consideration, shall submit, in addition to any filing fee required by law, the fees specified below:

| TRANSACTION   | MINIMUM NON-REFUNDABLE EXPENSE DEPOSIT |
|---|--|
| a. Right of way   | \$350                                  |
| b. Public agency lease or permit  | \$450                                  |
| c. Assignment/sublease of a lease   | \$300                                  |
| d. Amendment of a lease to accommodate lessee and which does not increase the rental  | \$500                                  |
| e. Most other types of transactions not listed herein   | \$300                                  |
| 4. Extractive Development Fees:   |  |
| a. For mineral prospecting permits and leases; competitive bid leases; geothermal prospecting permits and leases; oil and gas leases; compensatory agreements   | \$100                                  |
| b. Dredging permits unless for the public benefit   | \$300                                  |
| 5. The above listed fees are necessary to reimburse the Commission for the cost to process typical, uncomplicated transactions. If the amount proves to be insufficient due to unusual complexities or for other reasons, additional funds will be requested. |  |

Signature and Certification

All statements contained above on the attached application form and related exhibits are true and correct to the best of my knowledge and belief and are submitted under penalty of perjury.

Applicant: \_\_\_\_\_ Applicant: \_\_\_\_\_

BY: \_\_\_\_\_ TITLE: \_\_\_\_\_  
(If Agent)

DATE: \_\_\_\_\_

## ENVIRONMENTAL DATA

All leases, licenses, permits, land sales or other entitlements for use of State lands under the jurisdiction of the State Lands Commission shall be authorized only after compliance with California Environmental Quality Act (CEQA) has been achieved. Depending upon the nature and size of your project, and its status in the permitting process, the environmental data requirements may vary. Answers to the following questions will dictate the level and quantity of data required.

1. Is there any existing environmental document regarding the proposed project? If so, please attach a copy and your environmental data requirements may be satisfied.
2. If your answer to No. 1 above is negative, has a "lead agency" been designated for the project? If so, please identify, and your environmental data requirements may be satisfied.
3. If your answers to the above questions are negative, and your project is designated below by the Commission as typically requiring an environmental impact report, provide the information on State Lands Commission E.I.F. Form 59.2 attached. The following projects are those which typically require an environmental impact report: Oil and gas lease; geothermal prospecting permit or lease; mineral prospecting permit or lease; resumption of drilling; major industrial, commercial, or right of way construction; public works projects; salvage lease or permit; or a project which may have a significant impact on Class A significant lands identified in the Inventory of Unconveyed State School Lands and Tide and Submerged Lands Possessing Significant Environmental Values, dated December 1, 1975.
4. If your project does not fit within the confines of Nos. 1, 2, or 3, provide the information listed in State Lands Commission E.I.F. Form 69.3.
5. If it is determined that an environmental document (environmental impact report or negative declaration) need be prepared for the project, the applicant agrees, as a part of the application, to enter into a contract with the State Lands Commission for payment of all costs encountered in the preparation of the appropriate document.
6. Applicant is further advised that the determination of what type of environmental document is necessary is the responsibility of the State Lands Commission.

## ENVIRONMENTAL INFORMATION FORM (E.I.F.)

This form describes the data that must be furnished the State Lands Commission as part of an application for Commission action.

- 1. Project and Its Location.** Give the name of the project and its location. Generally, two maps or drawings should be submitted. One should show the general vicinity of the proposed project; i.e., nearby landmarks, roads and other features that would make clear its relation to the general vicinity. The other, preferably topographic, should show the project in detail; i.e., the location of buildings, fills, dredge areas, dikes, public access areas, etc.
- 2. Statement of the Objectives Sought by the Proposed Project.** Briefly describe what the project is intended to achieve (e.g., new piers for shipping, new park for recreation, shoreline development for public health and safety, oil and gas development).
- 3. General Description of the Project.** Describe the project's technical, economic and environmental characteristics, considering the principal engineering proposals and supporting public service facilities. Include in this description the principal features of the project (e.g., well locations, exact size of proposed fills, exact scope of proposed dredging, extent of proposed shoreline public access, etc.). The purpose is to provide a clear, concise overall description of the project.
- 4. (a) Description of the Environmental Setting.** Describe the environment in the vicinity of the project, as it exists before commencement of the project, from both a local and regional perspective. Knowledge of the regional setting is critical to the assessment of environmental impacts. Special emphasis should be placed on environmental resources that are rare or unique to that region. Specific reference to related projects, both public and private, both existent and planned, in the region should also be included, for purposes of examining the possible cumulative impact of such projects. List the flora and fauna found in the project area (common and scientific names).  
**(b) Water Quality Aspects.** Describe in the environmental setting section, and other sections where applicable, water quality aspects of the proposed project which have been previously certified by the appropriate state or interstate organization as being in substantial compliance with applicable water quality standards.
- 5. Assessment of Impact.** All phases of a project must be considered when evaluating its impact on the environment: Planning, acquisition, development and operation. The following subjects shall be discussed, preferably in separate sections or paragraphs. If they are not discussed separately, the E.I.F. should include a table showing where each of the subjects is discussed.
- 6. Significant Environmental Effects Project.** Describe the direct and indirect impacts of the project on the environment, giving due consideration to both the short-term and long-term effects. It should include specifics of the area, the resources involved, physical changes, alterations to ecological systems and changes induced in population distribution, population concentration, the human use of the land (including commercial and residential development) and other aspects of the resource base such as water, scenic quality and public services. Cumulative effects shall also be discussed when found to be significant.
- 7. Any Significant Environmental Effects Which Cannot Be Avoided If The Proposal Is Implemented.** Describe any significant impacts, including those which can be reduced to an insignificant level but not eliminated. Where there are impacts that cannot be alleviated, without imposing an alternative design, their implications and the reasons why the project is being proposed, notwithstanding their effect, should be described. Describe impacts on any aesthetically valuable surroundings, or on human health.
- 8. Mitigation Measures Proposed to Minimize the Significant Environmental Effects.** Describe significant avoidable adverse impacts, including inefficient and unnecessary consumption of energy, and the measures proposed to minimize these impacts. This discussion shall include an

identification of the acceptable levels to which such impacts will be reduced, and the basis upon which such levels were identified. Where alternative measures are available to mitigate an impact, each should be discussed and the basis for selecting one alternative should be identified. Energy conservation measures, as well as other appropriate mitigation measures, shall be discussed. Examples of energy conservation measures are provided in the Appendix.

9. **Alternatives to the Proposed Action.** Describe all reasonable alternatives to the project, or to the location of the project, which could feasibly attain the basic objectives of the project, and why they were rejected in favor of the ultimate choice. The specific alternative of "no project" must also always be evaluated, along with the impact. Describe alternatives capable of substantially reducing or eliminating any environmentally adverse impacts, even if these alternatives substantially impede the attainment of the project objectives, and are more costly.
10. **The Relationship Between Local Short-Term Uses of Man's Environment and the Maintenance and Enhancement of Long-Term Productivity.** Describe the cumulative and long-term effects of the proposed project which adversely affect the state of the environment. Special attention should be given to impacts which narrow the range of beneficial uses of the environment or pose long-term risks to health or safety. In addition, the reasons why the proposed project is believed by the sponsor to be justified now, rather than reserving an option for further alternatives, should be explained (only required if action is adoption of plan, policy or ordinance of the State Lands Commission, or if project will be subject in NEPA).
11. **Any Significant Irreversible Environmental Changes Which Would Be Involved in the Proposed Action Should it be implemented.** Uses of nonrenewable resources during the initial and continued phases of the project may be irreversible since a large commitment of such resources makes removal or nonuse thereafter unlikely. Primary impacts and, particularly, secondary impacts (such as a highway improvement which provides access to a nonaccessible area) generally commit future generations to similar uses. Also, irreversible damage can result from environmental accidents associated with the project. Irrecoverable commitments of resources should be evaluated to assure that such current consumption is justified (only required if action is adoption of plan, policy or ordinance of the State Lands Commission, or if project will be subject in NEPA).
12. **The Growth-Inducing Impact of the Proposed Action.** Discuss the ways in which the proposed project could foster economic or population growth, either directly or indirectly, in the surrounding environment. Included in this are projects which would remove obstacles to population growth (a major expansion of a wastewater treatment plant might, for example, allow for more construction in service areas). Increases in the population may further tax existing community service facilities so consideration must be given to this impact. Also discuss the characteristic of some projects which may encourage and facilitate other activities that could significantly affect the environment, either individually or cumulatively. It must not be assumed that growth in any area is necessarily beneficial, detrimental, or of little significance to the environment.
13. **Energy Conservation.** Energy conservation measures including both the available alternatives and those incorporated into the design and operation of the proposed project should be addressed in the E.I.F..
14. **Organizations and Persons Consulted.** The identity of all federal, state or local agencies, other organizations and private individuals consulted in preparing the E.I.F. should be specified.
15. The data and degree of specificity required in your Environmental Information Form must correspond with the data and degree of specificity involved in the underlying activity. Typically, the larger the project, the greater the degree of specificity and data; conversely, the smaller the project, the less specificity and data required.

ATTACHMENT NO. 11

DEPARTMENT OF FISH AND GAME

NOTIFICATION OF REMOVAL OF MATERIALS  
AND/OR ALTERATION OF LAKE, RIVER, OR  
STREAMBED BOTTOM, OR MARGIN



The department has 30 days from date of receipt in which to make its recommendations.

T.H.P. No. \_\_\_\_\_

Notification No. \_\_\_\_\_ Received \_\_\_\_\_

STATE OF CALIFORNIA  
RESOURCES AGENCY  
DEPARTMENT OF FISH AND GAME  
NOTIFICATION OF REMOVAL OF MATERIALS AND/OR ALTERATION  
OF LAKE, RIVER, OR STREAMBED BOTTOM, OR MARGIN

A. APPLICANT Pursuant to Sections 1601-1606 of the California Fish and Game Code

I, \_\_\_\_\_ of \_\_\_\_\_  
Name of Applicant Mailing Address

Representing \_\_\_\_\_  
Name of Agency, Company, etc.

Hereby notify the California Department of Fish and Game of operations to be carried out by me, or the organization I represent, from \_\_\_\_\_ to \_\_\_\_\_  
Date Date

\_\_\_\_\_ of \_\_\_\_\_ County, tributary to \_\_\_\_\_ in the \_\_\_\_\_  
Name of Stream, River, or Lake NE, NW, SE, or SW

Section \_\_\_\_\_ Township \_\_\_\_\_ Range \_\_\_\_\_ U.S.G.S. Map \_\_\_\_\_

Co. Assessor's Parcel No. \_\_\_\_\_ Property Owner \_\_\_\_\_  
whose address is \_\_\_\_\_

\_\_\_\_\_ is responsible for operations at the site.  
Name of Person to Be Contacted at Site During Operations

He can be reached at \_\_\_\_\_  
Mailing Address Telephone

B. Description of operation 1. The nature of said operations will be as follows:

Check all squares which apply.

- Soil, sand, gravel, and/or boulder removal or displacement  Logging  
 Water diversion or impoundment  Temporary, recreational or irrigation dam  
 Mining—other than aggregate removal  Other—Describe below  
 Road or bridge construction  
 Levee or channel construction

2. Type of material removed, displaced or added  Soil  Sand  Gravel  Boulders  
Volume \_\_\_\_\_

3. Equipment to be used in the described site \_\_\_\_\_

4. Use of water (i.e., domestic, irrigation, gravel, washing, etc.) \_\_\_\_\_ Quantity \_\_\_\_\_

5. Describe type and density of vegetation to be affected, and estimate area involved.  
\_\_\_\_\_

6. What actions are proposed to protect fish and wildlife resources and/or mitigate for project impacts?  
\_\_\_\_\_  
\_\_\_\_\_

7. Please attach and send to the Department any available project environmental documents.

8. Briefly describe proposed construction methods. Diagram or sketch below the location of your operation to clearly indicate the stream or other water and access from named public road. Indicate locked gates with an "X". Show existing features with a solid line (————) and proposed features with a broken line (-----). Show compass direction. Attach larger scale map if necessary.



APPENDIX G

Utility Purchase Prices for  
Hydroelectric Generation



APPENDIX G

Utility Purchase Prices for  
Hydroelectric Generation

- G-1A. Pacific Gas and Electric Company's Energy Purchase Prices for Small Power Producers and Cogenerators
- G-1B. Pacific Gas and Electric Company's Proposed Policy for Power Purchases from Hydroelectric Facilities Greater than 100 kW
- G-2. Southern California Edison Company's Proposed Policy for Power Purchases from Hydroelectric Facilities
- G-3A. San Diego Gas and Electric Company's Energy Purchase Prices for Small Power Producers and Cogenerators for Installations of 100 kW or less
- G-3B. San Diego Gas and Electric Company's Energy Purchase Prices for Small Power Producers and Cogenerators for Installation of Greater than 100 kW



## SECTION G-1A

Pacific Gas and Electric Company's Energy Purchase Prices for Small Power Producers and Cogenerators

A power sales agreement was published by Pacific Gas and Electric Company (PGandE) in February 1980. It contains the terms under which the utility will make individual offers to purchase power from qualified facilities using cogeneration, or generation with fuels derived from biomass, wood waste, or refuse. The agreement includes the current schedule of prices for energy and capacity delivered to PGandE, and the conditions pertaining to interconnection, protective devices, metering, and operational procedures.

The PGandE agreement provides for both capacity and energy payments under two options, and for a combined capacity and energy payment under a third option. The owners or operators are free to select whichever option they prefer.

Energy Rate. The energy rate is based on PGandE's average quarterly cost of incremental fuel. It is published by PGandE as required by the California Public Utilities Commission's (CPUC) Order Instituting Investigation No. 26, Decision No. 91109 of December 19, 1979. The energy rate is established for a three-month period following the quarter during which the fuel cost is calculated and is applied as follows:

| <u>Cost-Quarter Used</u> | <u>Months to Which Energy Rate Applies</u> |
|--------------------------|--|
| January to March         | May to July                                |
| April to June            | August to October                          |
| July to September        | November to January                        |
| October to December      | February to April                          |

The rolling three-month energy rate enables reasonably close-tracking of actual oil prices, which have been changing at unpredictable intervals since 1978. The energy rate is divided into three parts, based on three time-of-day energy generation costs, and on two seasons.

The highest energy payment is during on-peak hours on weekdays. More of these hours occur during the peak-load summer season of May 1 to September 30; they are 6 hours daily on Monday through Friday, from 12:30 pm to 6:30 pm, except on holidays. On-peak hours during the winter season of October 1 to April 30 are 4 hours daily on Monday through Friday, from 4:30 pm to 8:30 pm, except on holidays.

The lowest energy rate is during off-peak hours, which are 10 hours daily from 10:30 pm to 8:30 am Monday through Saturday, except on holidays. Off-peak rates are also in effect 24 hours a day on Sunday and holidays. These off-peak hours are the same all year regardless of the season. The utility specifies eight holidays when off-peak rates would apply: New Year's Day, Washington's Birthday, Memorial Day, Independence Day, Labor Day, Veterans' Day, Thanksgiving Day, and Christmas Day as set forth in Public Law 90-363. The intermediate, or partial-peak rate, is in effect during all other hours not designated as either on-peak or off-peak hours.

Based on PGandE's quarterly average energy cost for January through March 1980, the energy rates to be applied to generation purchased by PGandE for May through July 1980 are:

|                    |                |
|--------------------|----------------|
| On-peak hours      | 5.675¢ per kWh |
| Partial-peak hours | 5.459¢ per kWh |
| Off-peak hours     | 4.700¢ per kWh |

The weighted average energy rate calculated by combining the above rates and hours is about 5.1¢ per kWh. This mid-1980 weighted average is used to estimate future energy rates based on projected oil prices.

Capacity Rate. In addition to the energy rate, PGandE will pay a capacity rate if the seller has made contract capacity available to PGandE and meets certain minimum requirements:

- (1) The maximum amount of capacity used for making a capacity payment is the minimum amount the power facility can produce during the peak months of June, July, and August.
- (2) The minimum amount of capacity during the peak months of June, July, and August must be available for all on-peak hours subject to an allowance of 20 percent of those hours for forced outages. (Being available means either actually delivered to PGandE or callable for operation at PGandE's request.)
- (3) Scheduled outages must be performed between November and April unless otherwise agreed upon.

The seller has three options for calculating of capacity payments. Option 1 is payment in twelve equal monthly installments. To qualify for this option, the seller must have the minimum capacity (discussed above) to deliver power as requested by PGandE's dispatcher.

Option 2 payments vary each month according to the capacity actually delivered to PGandE. The payment in any month cannot exceed the capacity rate times the minimum capacity available during June, July, and August (contract capacity), and is calculated by a formula related to hours of generation:

Monthly delivered capacity = Monthly Factor x Seasonal Factor  
where:

$$\text{Monthly Factor} = \frac{A}{C \times (B-S) \times (1-F)} \times \left(1 - \frac{M}{D}\right)$$

Seasonal Factor = 0.1172 for May through September; and  
0.0588 for October through April.

where:

A = Energy delivered on-peak and partial-peak hours in kWh;

B = Number of on-peak and partial peak hours during  
the month;

C = Contract capacity in kW;

D = Number of days in the month;

F = The fraction of on-peak and partial-peak hours  
allowed for forced outage (amounting to 20%);

M = The number of days during the month that the  
facility is out of service on scheduled  
maintenance; and

S = On-peak and partial-peak hours that the facility  
is out of service on scheduled maintenance.

The seasonal allocation factors are subject to change by PGandE based on PGandE's marginal-capacity cost allocation.

Option 3 offers payment based on energy deliveries to PGandE during on-peak, partial-peak, and off-peak hours with the payment varying each month according to those energy deliveries and the seasonal value of power. The payment in any month cannot exceed the maximum payment under Option 2, assuming delivery of the full contract capacity. The payment is calculated by multiplying the capacity rate by the following energy allocation factors:

| <u>Time-of-day Period</u> | <u>May<br/>through<br/>September</u> | <u>October<br/>through<br/>April</u> |
|---------------------------|--------------------------------------|--------------------------------------|
| On-peak hours             | 0.03357                              | 0.02022                              |
| Partial-peak hours        | 0.02323                              | 0.00893                              |
| Off-peak hours            | 0.00553                              | 0.00476                              |

The option selected by the owner or operator of a small power facility will depend on the size of the facility and its generation characteristics.

The capacity rate that would apply to Options 1 and 2 will be adjusted upward to the highest capacity price for the scheduled operation date. The power sales agreement will also be adjusted to the date that the small power facility begins operation. The capacity rate is in terms of dollars per kilowatt of capacity per year which are levelized for the term of the agreed-upon sale to PGandE. The capacity rate varies from \$60 to \$103 per kilowatt depending on the initial year of operation and the term of the power sales contract. The published capacity rate, dated February 4, 1980, is shown in Table 9, Chapter II.

Sample Computation. For a 20-year power sales contract with PGandE starting in the second quarter of 1980, the prices that PGandE would pay for cogeneration capacity and energy delivered to it can be shown by the following example:

Assume 1 kW of capacity is sold under a 20-year contract (Option 1 selected for capacity payment) with delivery starting in May 1980, and that the generation in May was 595 kWh.

Capacity payment = 1 kW x \$73 per kW x 1/12  
= \$6.08 per 595 kWh  
= 1.0¢ per kWh

(The assumed capacity factor is 595/744 or 0.80. The price in cents per kWh will vary by a capacity factor.)

The combined capacity and energy prices for this sample computation for cogeneration capacity and energy delivered to PGandE at mid-1980 is estimated as follows:

|                           |        |
|---------------------------|--------|
| Capacity                  | = 1.0¢ |
| Energy (weighted average) | = 5.1¢ |
| Total per kWh             | = 6.1¢ |

#### Policy For Power Installations of 100 kW or less

In July 1980, PGandE made a form of power sales agreement available for cogeneration, renewable resources (including water, wind, and solar energy), and waste or biomass for installations of 100 kW or less. The energy rate is the same as the prices for the cogeneration agreement discussed above, but the capacity rate is significantly less than for the cogeneration agreement.

The capacity rate is proposed as an installation incentive and a performance incentive. The installation incentive amounts to 75¢ per kW per month (\$9 per kW annually) and will be paid for any month in which the generating facility produces sufficient energy to equal at least the product of 5 percent of the total hours in the month times the kilowatt output rating of the facility. An additional 75¢ per kW per month will be paid for any month that the generating facility produces sufficient energy to equal at least the product of 35 percent of the hours in the month times the kilowatt output rating of the facility. The hours in the month used

for these incentive calculations is actually based on the meter-reading schedule which varies from 27 to 33 days.

While the time-of-delivery prices (on-peak, partial-peak, and off-peak) are the same as for the cogeneration agreement, an optional standard weighted-average price is available. For the period May 1 through July 31, 1980, the standard weighted-average price was 4.994¢ per kWh.

The combined capacity and energy price for a small hydroelectric installation operating at an 80 percent capacity factor with the output delivered to PGandE is estimated as

|                                       |      |
|---------------------------------------|------|
| Capacity = \$1.50/kW x 1 kW/595 kWh = | 0.2¢ |
| Energy (weighted average) =           | 5.0¢ |
| Total per kWh =                       | 5.2¢ |



SECTION G-1B

Pacific Gas and Electric Company's Proposed Policy for Power Purchases from  
Hydroelectric Facilities Greater than 100 kW

In August 1980, PGandE filed a proposed form of agreement with the CPUC for the purchase of hydroelectric generation from installations with capacities greater than 100 kW. This proposed agreement is significantly different from PGandE's cogeneration agreement in terms of the amount of capacity that would be paid for, and the addition of discount factors for potential recurring dry water years and for transformer and transmission losses to the "load center." The discount factors are applied to the capacity and energy rates established by PGandE for the cogeneration agreement.

The amount of capacity paid for would be the calculated theoretical monthly capacity for the hydroelectric plant assuming the driest water year of record. The driest year was 1977 which was the second year of the 1976-77 drought. The amounts of capacity and energy that could be produced under theoretical 1977 water conditions must be documented by a theoretical study of water and power operations acceptable to PGandE.

Two discount factors are applied to the energy rate. The first discount factor (F1) accounts for year-to-year swings in power production that cause PGandE to experience changes in its thermal costs and in its fuel inventory. It is necessary to prepare a long-term theoretical study of water and power operations in order to calculate factor F1. A typical period of time for the operation study would be 50 years. Factor F1 can be approximated using the formula:

$$F1 = \frac{0.25 \text{ (average energy of 28\% of the driest years)} + 0.75}{\text{(long-term average energy)}}$$

A long-term study of water and power operations would cover a period of 50 years or more and would estimate the average generation for each year. The long-term average energy is the sum of the annual energy for all the years of the operations study divided by the number of years of the study. The average energy of the 28 percent of the driest years for a 50-year study would include the "dust bowl" years of 1929 through 1934, plus 1937, 1944, 1947, 1949, 1960, 1961, and the most severe drought years of 1976 and 1977.

The second energy discount factor (F2) accounts for the remote location of potential hydroelectric projects, whereas no discount is applied to cogeneration facilities regardless of location. The transmission loss factor for energy (part of factor F2) varies from 0.91 to 0.93 in very remote areas like Shasta County to 1.0 in the Bay Area plus 1 percent to 3 percent for transformer losses (the remaining part of factor F2). The total potential discount is about 10 percent on energy output from small hydroelectric projects located in remote areas.

Similarly, the total potential discount on capacity (factor F3) is 13 to 15 percent for hydroelectric projects located in areas remote from the Bay Area or the San Joaquin Valley. Again, no capacity discount is applied to cogeneration facilities regardless of location.

For many irrigation districts, the 1977 driest-year criterion means that a potential hydroelectric project would receive no capacity credit, and the transmission and transformer discount would reduce the value of hydroelectric energy generation by an average of about 12 percent compared with equivalent cogeneration installations. In addition, the water year factor (F1) could further reduce the payments for hydroelectric energy generation compared with equivalent cogeneration installations.

The calculation of payments for hydroelectric generation under PGandE's proposed form of purchase agreement will be subject to the historical water conditions and location of a particular hydroelectric site. However, a range of values can be estimated as in the following example:

Assume 1 kW of capacity is installed and sold to PGandE under a 20-year contract starting in May 1980, and that the generation in May was 595 kWh.

Discount Factors:

$$\begin{aligned} F1 &= (0.25 \times 1.0) + 0.75 = 1.00 \text{ (best)} \\ &= (0.25 \times 0) + 0.75 = 0.75 \text{ (worst)} \\ F2 &= 0.93 \times 0.97 = 0.90 \\ F3 &= 0.90 \times 0.97 = 0.87 \end{aligned}$$

Depending on theoretical 1977 water conditions, the amount of the 1 kW of installed capacity that would be considered available could vary from zero to 1 kW.

|                          |   |
|--------------------------|---|
| Maximum capacity payment | = 0.87 x 1 kW x \$73 per kW x<br>1/12x1/595 = 0.89¢/kWh |
| Minimum capacity payment | = none  |
| Maximum energy payment   | = 1.0 x 0.90 x 5.1¢ per kWh =<br>4.59¢ per kWh          |
| Minimum energy payment   | = 0.75 x 0.90 x 5.1¢ per kWh =<br>3.44¢ per kWh         |

The combined capacity and energy prices for this sample computation for hydroelectric capacity and energy delivered to PGandE at mid-1980 can be estimated:

|                           | <u>Maximum</u> | <u>Minimum</u> |
|---------------------------|----------------|----------------|
| Capacity                  | 0.9¢           | 0.0¢           |
| Energy (Weighted average) | 4.6¢           | 3.4¢           |
| Total per kWh             | 5.5¢           | 3.4¢           |

It is unlikely that a theoretical water and power operation study will result in either the maximum or minimum payment for hydroelectric generation at a particular site. For the purposes of making a preliminary feasibility study of a potential hydroelectric site, unless specific site conditions are known to be different, a reasonable anticipated price for an average-water year can be estimated

|               |                              |        |
|---------------|------------------------------|--------|
| Capacity      | = 0.89¢ per kWh x 0.25       | = 0.2¢ |
| Fl            | = (0.25 x 0.50) + 0.75       | = 0.88 |
| Energy        | = 0.88 x 0.90 x 5.1¢ per kWh | = 4.0¢ |
| Total per kWh |                              | = 4.2¢ |



Southern California Edison Company's Proposed Policy for  
Power Purchases from Hydroelectric Facilities

On May 15, 1980, the Southern California Edison Company (SCE) published its avoided-cost information entitled "Interim Proposed Policy for Cogeneration and Small Power Production." The pricing schedules attached to SCE's policy statement are provided to form the basis for an offer to purchase all energy and capacity from cogeneration and small power producers who meet minimum qualifications.

Energy Rate. The energy rate is based on SCE's recorded fuel purchase costs and will be revised quarterly to reflect the avoided cost of generated energy. The rate is divided into six parts, relating to time-of-day generation costs and winter and summer seasons. The highest energy value occurs during on-peak hours on weekdays. Although the same number of on-peak hours are specified during both winter and summer seasons, the time-of-day is different, and the energy rate is different for the two seasons. On-peak hours during the summer season (May 1 to October 31) are 6 hours daily on Monday through Friday, from Noon to 6 pm, except on holidays. On-peak hours during the winter season (November 1 through April 30) are 5 hours daily on Monday through Friday, from 5 pm to 10 pm, except on holidays.

The lowest energy rate is during off-peak hours, which are 10 hours daily from 10 pm to 8 am Monday through Friday, and 24 hours daily on Saturday, Sunday, and holidays. The nine holidays when off-peak rates would apply are New Year's Day, Washington's Birthday, Memorial Day, Independence Day, Labor Day, Veterans' Day, Thanksgiving Day, and Christmas.

The intermediate or mid-peak rate is in effect during all hours that are not designated as either on-peak or off-peak hours.

The SCE energy rate for the quarter ending July 31, 1980 was 4.7¢ per kWh for on-peak and mid-peak hours, and 4.6¢ per kWh for off-peak hours.

Capacity Rate. In addition to the energy rate for generation delivered to SCE, the utility will make a capacity payment based on contracted kilowatts, capacity factor (CF), a factor related to time-of-day and season (termed "Factor 1" by SCE), and the ability to meet minimum emergency availability criteria. The capacity factor, which cannot exceed 1.0, is calculated as the kilowatt-hours delivered to SCE divided by the product of contracted kilowatts times the hours in the period during which the energy was produced. The capacity payments will vary each month according to the amount of energy delivered to SCE during on-peak, mid-peak, and off-peak hours. The amount of capacity delivered to SCE can be expressed as:

Monthly capacity delivered = Contracted kW x CF x Factor 1  
 where:

$$CF = \frac{\text{kWh delivered}}{\text{Contract kW} \times \text{hours in month}}$$

(Note: CF cannot exceed 1.0)

| and                                       |                           |                                |                                 |
|---|---------------------------|--------------------------------|---------------------------------|
| <u>Summer</u><br><u>May 1 to Oct. 31</u>  | <u>Factor</u><br><u>1</u> | <u>Average</u><br><u>Hours</u> | <u>Time(PST)</u>                |
| On-peak                                   | 0.07333                   | 129.00                         | Noon to 6 pm                    |
| Mid-peak                                  | 0.01000                   | 172.00                         | 8 am to Noon &<br>6 pm to 10 pm |
| Off-peak                                  | 0.00833                   | 435.00                         | All other hours                 |
| <u>Winter</u><br><u>Nov. 1 to Apr. 30</u> | <u>Factor</u><br><u>1</u> | <u>Average</u><br><u>Hours</u> | <u>Time(PST)</u>                |
| On-peak                                   | 0.05500                   | 104.17                         | 5 pm to 10 pm                   |
| Mid-peak                                  | 0.01000                   | 187.50                         | 8 am to 5 pm                    |
| Off-peak                                  | 0.01000                   | 436.33                         | All other hours                 |

The policy proposed by SCE describes the minimum criteria to be addressed in the contract agreement concerning emergency availability and monthly availability. Full capacity payments will be made for those qualifying facilities that meet the minimum criteria. A qualifying facility not meeting the minimum criteria may still be eligible for a payment proportionate to the value of its capacity to SCE. However, the payments for total output should be at least equal to the avoided cost of energy. (SCE does not propose to apply energy discount factors for water-year conditions or transmission, as proposed by PGandE. See the discussion of PGandE's proposed policy for hydroelectric installations greater than 100 kW in the preceeding section.)

The utility does not specifically address capacity payments for run-of-the-stream hydroelectric installations in its proposed policy, but suggests that a 50 percent reduction of the capacity value is a reasonable approximation in lieu of a case-by-case determination. There would be an additional 50 percent reduction for a hydroelectric installation that could not attain a monthly capacity factor of 51 percent or greater by time period.

The payment for capacity in any particular month is equal to the capacity rate (shown in Table 9 of Chapter II) times the monthly capacity delivered as determined by the preceding formula, and reduced for availability and reliability criteria as necessary. While the method and the formula appear initially to be fairly complex, its application is quite straightforward as shown by the following example:

Assume 1 kW of capacity is sold under a 20-year contract with delivery starting in May 1980, and that the generation in May was 595 kWh. The capacity factor is 595 kWh/(1 kW x 744 hours) or 80 percent

For the summer on-peak period, the capacity payment is equal to Factor 1 x CF x Annual capacity payment or  $0.07333 \times 0.80 \times 1 \text{ kW} \times \$82 \text{ per kW}$  or \$4.81

Since there is an average of 129 on-peak hours in each month of the summer season, the capacity payment expressed in terms of energy generation is  $\$4.81 / (0.80 \times 129 \text{ hours})$  or 4.66¢ per kWh. Reducing the capacity payment by 50 percent for emergency availability results in a payment of 2.33¢ per kWh.

In terms of energy generation, the price for capacity in the above example will always be 4.66¢ or 2.33¢ per kWh, regardless of the capacity factor, unless SCE changes Factor 1 and/or the \$82 per kW-year rate, for energy generated up to a calculated capacity factor of 100 percent. Since the capacity factor is calculated using the contract capacity, which may be less than the installed capacity, the calculated capacity factor in a very wet month might be greater than 100 percent. In the event that the actual capacity factor were greater than 100 percent, the average price for the capacity would be less than 4.66¢ per kWh because in terms of cents-per-kilowatthour the capacity payment would be averaged over all kilowatthours generated.

For a 20-year power sales contract with SCE starting in May 1980, the estimated prices that SCE would pay for generation delivered to it during May, June, and July, 1980 are shown in Table G-1.

Table G-1. Prices SCE Would Pay for Generation Under a 20-year power sales contract starting in May 1980 (in cents per kWh)

| Season  | Time     | Capacity | Energy | Total |
|---------|----------|----------|--------|-------|
| Summer: | On-peak  | 2.33     | 4.70   | 7.03  |
|         | Mid-peak | 0.24     | 4.70   | 4.94  |
|         | Off-peak | 0.08     | 4.60   | 4.68  |
| Winter: | On-peak  | 2.16     | 4.70   | 6.86  |
|         | Mid-peak | 0.22     | 4.70   | 4.92  |
|         | Off-peak | 0.10     | 4.60   | 4.70  |

The weighted-average rates for mid-1980 generation, calculated by combining the rates of 0.5¢ per kWh for capacity and 4.6¢ for energy or a total of 5.1¢ per kWh.

Since a 30- to 36-month lead time is expected for hydroelectric projects initiated in 1981, probably most of the of facilities in the preliminary feasibility study stage now will not be operating until late 1983 or 1984. The estimated prices that SCE would pay for power capacity and energy delivered to it for a 30-year power sales contract starting in 1984 are shown in Table G-1.

Table G-1. Prices SCE Would Pay for Generation  
(30-year power-sales contract starting in 1984,  
in cents per kWh)

| Season  | Time     | Capacity | Energy | Total |
|---------|----------|----------|--------|-------|
| Summer: | On-peak  | 4.50     | 10.21  | 14.71 |
|         | Mid-peak | 0.46     | 10.21  | 10.67 |
|         | Off-peak | 0.15     | 9.99   | 10.14 |
| Winter: | On-peak  | 4.20     | 10.21  | 14.41 |
|         | Mid-peak | 0.42     | 10.21  | 10.63 |
|         | Off-peak | 0.19     | 9.99   | 10.18 |

The estimated weighted-average rates for 1984 generation, calculated by combining the rates of 0.8¢ per kWh for capacity and 10.1¢ for energy or a total of 10.9¢ per kWh.

SECTION G-3A

San Diego Gas and Electric Company's Energy Purchase  
Prices for Small Power Producers and Cogenerators for  
Installations of 100 kW or Less

On August 22, 1980, San Diego Gas and Electric Company (SDG&E) published its interim proposed policy for purchasing power from cogeneration and small power production facilities including hydroelectric installations. The proposed policy included an energy price available under two options plus an incentive payment for capacity. One of the options is a weighted-average price applied to all energy delivered to SDG&E; the second option is a time-of-delivery price--special metering equipment determines the hours when energy is delivered to SDG&E.

Energy Rate. The energy rate is divided into six parts relating to the Time-of-day and two seasons. The highest energy value occurs during on-peak hours on weekdays and includes a greater number of hours during the peak-load summer season. The on-peak hours during the May 1 to September 30 summer season are 7 hours daily between 10 am and 5 pm, except on holidays. The on-peak hours during the rest of the year are 4 hours daily between 5 pm and 9 pm, except on holidays.

The lowest energy value occurs during off-peak hours: 13 hours on weekdays between 9 pm and 10 am and 24 hours on weekdays and holidays. The holidays are New Year's Day, Washington's Birthday, Memorial Day, Independence Day, Labor Day, Veterans' Day, Thanksgiving Day, and Christmas. A semi-peak rate is in effect during all hours that are not designated as being either on-peak or off-peak hours.

The energy rates for a three-month period are based on the average incremental price that SDG&E paid for fuel during the preceeding three-month period. For the period May 1 through July 31, 1980, the energy prices paid by SDG&E for the time-of-day optional rate were

|                 |                |
|-----------------|----------------|
| On-peak hours   | 6.537¢ per kWh |
| Semi-peak hours | 6.005¢ per kWh |
| Off-peak hours  | 5.004¢ per kWh |

The price paid under the optional weighted-average rate was 5.420¢ per kWh.

Capacity Rate. In addition to the energy price, SDG&E will make an incentive payment based on the calculated capacity factor of energy delivered. The capacity factor is calculated monthly as the ratio of the kilowatthour generated during the month divided by the multiplication of the highest average kilowatt during any 15-minute period times the total number of hours in the month. The capacity incentive payment schedule is:

| <u>Capacity<br/>Factor</u> | <u>Incentive<br/>Payment</u> |
|----------------------------|------------------------------|
| 0%-14%                     | \$0.00 per kW                |
| 15%-49%                    | 0.70 per kW                  |
| 50%-85%                    | 1.30 per kW                  |
| over 85%                   | 2.00 per kW                  |

The combined capacity and energy price for a small hydroelectric installation operating at an 80% capacity factor with the output delivered to SDG&E is estimated as:

|   |                |
|---|----------------|
| Capacity price = \$1.30/kW x 1 kW/595 kWh | = 0.2¢ per kWh |
| Energy price (weighted average)           | = 5.4¢ per kWh |
| Total                                     | = 5.6¢ per kWh |

## SECTION G-3B

San Diego Gas and Electric Company's Energy Purchase Prices  
for Small Power Producers and Cogenerators for  
Installations of Greater than 100 kW

On August 22, 1980, SDG&E also published its interim proposed policy for purchasing power from cogeneration and hydroelectric facilities with capacities greater than 100 kW. The energy price paid by SDG&E is the same as the time-of-day rates specified for installations with capacities less than 100 kW. A capacity payment would be made under one of two options selected by a seller of the hydroelectric generation who meets certain minimum provisions.

Under one option for capacity payment, the generating facility must be fully dispatchable by SDG&E. The rate for capacity payments is shown in Table 9 of Chapter II and the minimum provisions are:

- ° Capacity must be available for all on-peak and semi-peak hours with forced outages not to exceed 15% of those hours each month and scheduled outages not to exceed 30 days per year.
- ° All scheduled outages must be scheduled and performed during periods agreed to by SDG&E.
- ° SDG&E must be notified 24 hours in advance of any anticipated increases or decreases in generator output and notified quarterly of the estimated output and scheduled maintenance for the next 4 months.
- ° SDG&E may derate the generating capacity, based on tests, studies, or prior performance.

Under the second option for capacity payment, the rate for payment is based on the amount of capacity actually delivered to SDG&E and is calculated as:

$$\text{Monthly payment} = \text{contract capacity} \times \text{monthly factor} \times \text{seasonal factor} \times \text{contract payment rate (Table 9, Chapter II)}$$

where

$$\text{Monthly factor} = \frac{Q}{C \times (H - S) \times 0.85}$$

$$\text{Seasonal factor (May through September)} = 0.1147$$

$$\text{(October through April)} = 0.0609$$

and

Q = kilowatts delivered during on-peak and semi-peak hours

C = Contract capacity in kilowatts

H = Number of on-peak and semi-peak hours

S = Number of hours that output is unavailable during on-peak and semi-peak hours because of scheduled maintenance

The monthly factor cannot exceed 1.0, and if less than 0.5, no capacity payment will be made. If S exceeds 75% of H, the monthly factor will be the same as that for the previous month.

The same minimum provisions apply to the monthly-delivered capacity payment option as for the fully-dispatchable option. For hydroelectric installations at existing dams or hydraulic structures, where water is released for other purposes and cannot be dispatched by SDG&E, the monthly delivered-capacity option would be applicable in most cases.

The payment for capacity under the SDG&E rate can vary significantly from month-to-month and from season-to-season with the rate heavily weighted toward the summer season as shown by the following example:

Assume 1 kW of capacity is sold under a 20-year contract with delivery starting in May 1980, and that the generation in May was 595 kWh with 231 kWh being generated during on-peak and semi-peak hours.

On-peak hours = 7 hr per day x 21 = 147 hr

Semi-peak hours = 4 hr per day x 21 = 84 hr

Off-peak hours = (13x21) + (24x10) = 513 hr

Total 744 hr

Assume generation is available during all on-peak and semi-peak hours, and

$$\text{Monthly factor} = \frac{231 \text{ kWh}}{1 \text{ kW} \times 231 \text{ hr} \times 0.85} = 1.18$$

However, since the monthly factor cannot exceed 1.0,

$$\text{Payment in a summer month} = \$35 \times 1.0 \times (0.1147/595) = 0.67¢ \text{ per kWh}$$

$$\text{Payment in a winter month} = \$35 \times 1.0 \times (0.0609/595) = 0.36¢ \text{ per kWh}$$

The average payment for capacity over a year period with the generating unit out of service for scheduled maintenance 15% of the time and output available during all other on-peak and semi-peak hours would be about 0.5 cents per kWh. The weighted-average price for small hydroelectric generation at mid-1980, as estimated from the published SDG&E rates, is

|                                 |   |      |
|---------------------------------|---|------|
| Capacity price                  | = | 0.5¢ |
| Energy price (weighted-average) | = | 5.4¢ |
| Total per kWh                   | = | 5.9¢ |

Since a 30- to 36-month lead time is expected for hydroelectric projects initiated in 1981, it is likely that most of the sites presently in the preliminary feasibility stage will not be available for operation until late 1983 or early 1984. For a 25-year power sales contract starting in 1984, the estimated price that SDG&E would pay for capacity and delivered to it in 1984 is

|                                 |   |       |
|---------------------------------|---|-------|
| Capacity price                  | = | 1.3¢  |
| Energy price (weighted-average) | = | 11.7¢ |
| Total per kWh                   | = | 13.0¢ |

2 1

1 0 1

APPENDIX H

Financing Small Hydroelectric Projects



## APPENDIX H

### Financing Small Hydroelectric Projects

Historically, hydroelectric projects have usually been large developments undertaken by local public bodies, state and federal agencies, or investor-owned electric utilities. Public entities generally finance such developments by issuing general obligation or revenue bonds; private utilities generally use a combination of debt and equity financing. These sources of funds are best suited to large projects which require capital in amounts greater than \$5 million and where the cost of financing can be spread over a significant amount of investment funds.

Most small hydroelectric projects only require an investment of \$1 million to 5 million. Recently, new sources of funds and new financing methods have become available to encourage the development of small hydroelectric projects. These include: (1) State and federal grants for feasibility studies; (2) Federal loans for feasibility studies and license applications; and (3) Federal loans and grants under a number of federal programs that were originally established for purposes other than hydroelectric projects.

#### Federal Funding

U.S. Department of Energy Grants. In early 1978, the U.S. Department of Energy (DOE) solicited proposals for feasibility studies of low-head hydroelectric generation in order to add hydroelectric generation to existing dams with capacities between 50 kW and 15 000 kW, and heads of 20 m (66 ft) or less. A total of 54 grants were awarded by DOE for such studies. Three owners received money to study 15 sites in California (Table H-1).

Table H-1: Projects in California Receiving DOE Grant for Feasibility Study

| Owner                       | Project  |
|-----------------------------|--|
| City of Redding             | Lake Redding   |
| Modesto Irrigation District | Modesto Reservoir<br>Stone Drop  |
| Turlock Irrigation District | Drop No. 1<br>Drop No. 2<br>Drop No. 6<br>Drop No. 7<br>Drop No. 9<br>Main Canal<br>Canal Creek<br>Fairfield Drop<br>Escaladian Headworks<br>Woodward Dam<br>Frankenheimer Drop<br>Goodwin Dam |

In 1978, DOE also solicited proposals for grants of 25 percent of the cost of installing hydroelectric plants with installed capacities of up to 15 MW at existing dams where feasibility studies had been completed, and technical feasibility and economic viability was indicated. The DOE awarded grants for the construction of low-head hydroelectric projects. One grant was awarded in California to the Turlock Irrigation District for a power plant at Drop No. 1.

In 1979, DOE solicited proposals for grants of 15 percent of the construction costs for hydroelectric developments of up to 25 MW at existing dams where feasibility studies had been completed. This solicitation coincided with the completion of feasibility studies funded by DOE's 1977 feasibility grants. Of the 15 grants awarded by DOE for the construction of low-head hydroelectric projects in this second round, one grant was offered to the United Water Conservation District for the Lake Piru site in California. However, the District did not accept the grant.

At this time, DOE does not plan to make further grants for feasibility studies or for the construction of small hydroelectric projects, but it is encouraging potential site developers to use the DOE loan program under Title IV of PURPA.

U.S. Department of Energy Loans. Title IV of the Public Utility Regulatory Policies Act of 1978 (PURPA) authorized the Secretary of Energy to make loans for conducting feasibility studies and for preparing applications for licenses or any other government approvals for small hydroelectric projects at existing dams. The loan program established by DOE provides up to 90 percent of the cost of a feasibility study and a license application at a low-interest rate of about 7.25 percent.

Currently, this loan program is the best source of study and approval funds. The maximum amounts are loans of \$50,000 each for a feasibility study and license application. The term of the loans are 10 years and repayment is unnecessary during the first 4 years. If a feasibility study indicates that a project is not technically or economically viable, DOE may forgive repayment of the loan.

Title IV also authorizes loans for building small hydroelectric projects, but at this time, Congress has not appropriated funds for these loans.

The DOE loan application is quite involved. A developer must have a preliminary assessment of the potential site before the application can be adequately completed. The developer must also have a Preliminary Permit or a License Exemption from FERC to be eligible. Currently, it takes about 6 weeks to process a loan application, and 6 to 9 months to obtain a Preliminary Permit.

An application for a DOE loan requires the following information:

Introductory Material:

Abstract of the Proposed Project  
Table of Contents

Technical Data:

Project Data  
  Definition of Key Tasks  
  Schedule of Key Tasks  
Personnel and Organization Experience  
  Related Job Experience  
  Resumes  
Access to or Possession of Site  
Federal Energy Regulatory Commission Status

Business Data:

Applicant Organization Information  
  Description  
  Financial Data: Income and Expense Statement  
                  Balance Sheet  
Project Cost Information  
  Budget Summary  
  Amount of Loan and Percentage of Project Cost  
  Description of Other Financial Assistance  
  Pending Litigation Against Applicant

Applicants must also provide supplemental information depending on the type of loan requested, i.e. feasibility study or licensing. All applications must have a cover letter and a completed copy of Standard Form 424, Federal Assistance. Inquiries and requests for applications should be directed to:

U.S. Department of Energy  
333 Market Street  
San Francisco, CA 94105  
(415) 764-7084

Other Potential Sources of Federal Funding

A small hydroelectric project might also be eligible for financial assistance from a number of other federal funding programs.

Urban Development Action Grants (UDAG). These grants are authorized under Title I of the Housing and Community Development Act of 1974 and were extended in 1977. The UDAG program is administered by the U.S. Department of Housing and Urban Development (HUD). It was designed to assist severely distressed cities and urban counties through economic development and neighborhood revitalization. The program seeks to create a partnership between local government, the community, and private industry by allowing qualifying communities to use federal funds to stimulate or increase private investment. Under the program, HUD can make a grant to a community which can then loan the funds to a private developer at 5 percent interest. The developer repays the loan to the community over a specified term and the community uses the loan payments for local improvements to alleviate physical and economic deterioration. The UDAG program could provide up to 25 percent of the construction costs of a hydroelectric project located in

a severely distressed community. Further information can be obtained from the HUD regional office:

U.S. Department of Housing and Urban Development  
450 Golden Gate Avenue, Room 8460  
San Francisco, CA 94102  
(415) 556-4752

Resource Conservation and Development (RCD) Loans. These loans are authorized under the Bankhead-Jones Farm Tenant Act of 1937 which is administered by the Farmers Home Administration (FmHA) of the U.S. Department of Agriculture. The purpose of the program is to assist rural public agencies to develop water resource and to increase local economic opportunities. The program promotes preserving natural resources, developing and protecting recreational facilities, preventing impairment of dams and reservoirs, and protecting public lands. An RCD loan could provide up to \$250,000--at 5 percent interest--for the construction of a small hydroelectric project located in an authorized RCD area. Further information can be obtained from the regional Soil Conservation Service office:

Soil Conservation Service  
2828 Chiles Road  
Davis, CA 95616  
(916) 758-2200

Community Facilities Loans (CFL). This program was authorized in 1961 as a part of Public Law 87-128. The program is administered by FmHA to assist rural areas with 10,000 or fewer residents to conserve, develop, use, and control water, and to install and improve drainage and recreation facilities. Since hydroelectric development uses and controls water, it can be partially financed under the CFL program. The loans, at 5 percent interest, are available to public agencies or nonprofit corporations. Further information can be obtained from the state FmHA office:

Farmers Home Administration  
459 Cleveland Street  
Woodland, CA 95695  
(916) 666-3382

Business and Industrial Loans (BIL). This program was also authorized in 1961 as a part of Public Law 87-128 and is administered by FmHA. The purpose of the BIL program is to assist rural areas with populations in excess of 50,000 located near a city having a population density exceeding 100 persons per square mile. It promotes rural industrialization to improve business, industry, and employment. The loans--at 5 percent interest--are available to public, private, or cooperative entities for up to 50 percent of a project's development costs. Further information can be obtained from the state FmHA office listed above.

Watershed Protection and Flood Prevention Loans. These loans are available to local entities for sharing the costs of improving designated watersheds by flood prevention, water quality management, sedimentation control, fish and wildlife development, and water storage. The total amount available

for any particular watershed is \$5 million. This loan program is not particularly suitable for hydroelectric development at existing hydraulic structures because such facilities generally use existing streamflows or releases and would not alter that existing regimen. Further information can be obtained from the state FmHA office listed above.

Rural Electrification Loans. These loans are authorized by the Rural Electrification Act of 1936 which is administered by the Rural Electrification Administration (REA). Loans are available to rural electric cooperatives, public utility districts, power companies, municipalities, and other qualified power suppliers for the purpose of providing central station electric service in rural areas. Rural areas are defined as any area not included within the boundaries of a city, village, or borough having a population in excess of 1500. In general, loans are available only to REA cooperatives, although loan guarantees may be available if the net result of the financing is to provide or improve electric service to rural areas. Further information can be obtained from the REA:

Office of Information and Public Affairs  
Rural Electrification Administration  
U.S. Department of Agriculture  
Washington, DC 20250  
(202) 447-5606

Business Development Assistance Loans. This program of providing and guaranteeing loans was authorized by Public Law 89-136 and is administered by the Economic Development Administration (EDA). The purpose of the loans is to encourage industrial and commercial expansion in designated areas by assisting businesses which will create new permanent jobs, or will expand or establish plants in redevelopment areas. The only projects eligible for loans are those that have been unable to receive funding through banks or other private lending institutions. Long term loans of up to 65 percent of a project's development costs are available to individuals, private or public corporations, and Indian tribes. This program may be useful to businesses related to a local hydroelectric project. Further information can be obtained from the regional EDA office:

Economic Development Administration  
Lake Union Building  
1700 Westlake Avenue North  
Seattle, WA 98109  
(206) 442-4740

Small Reclamation Projects Program. The Small Reclamation Projects Act of 1956 provided loans and/or grants under Public Law 84-984. It is administered by the Water and Power Resources Service (WPRS; formerly the Bureau of Reclamation) of the U.S. Department of the Interior. The WPRS is responsible for irrigation or drainage projects including those with multiple-purpose uses such as municipal and industrial water supplies, flood control, fish and wildlife, recreation, and hydroelectric power. Hydroelectric development can be funded if it can be accomplished as an addition to the other water supply functions of the project. Several irrigation dams and reservoirs in California have been funded under Public

Law 87-984 including Virginia Ranch Dam, Indian Valley Dam, and Jackson Valley Dam, which are among the 28 preliminary feasibility studies discussed in Appendix C. Further information regarding loans for hydroelectric projects can be obtained from the WPRS regional office:

Northern California

U.S. Water and Power  
Resources Service  
2800 Cottage Way  
Sacramento, CA 95825  
(916) 484-4228

Southern California

U.S. Water and Power  
Resources Service  
P.O. Box 427  
Nevada Highway & Park Street  
Boulder City, NV 89005  
(702) 293-2161

Community Services Administration Grants. These grants are available for coordinating efforts to get project development funds. Planning assistance, provided through the International Science and Technology Institute, is available and is aimed at (1) completing applications for financial assistance, (2) planning steps to be taken to retrofit a dam, and (3) developing a plan for use of hydropower output. For further information contact:

Community Services Administration  
1200 19th Street NW, Room 334  
Washington, DC 20506  
(202) 632-6503

Comprehensive Employment and Training Act (CETA) Funds. Project funding may be available from CETA through state, regional, or local government agencies. Funding is mainly for wages, fringe benefits, and training. For further information contact:

Proaction Institute  
206 Urban Planning Building  
Michigan State University  
East Lansing, Michigan 48824  
(517) 353-9361

Miscellaneous Federal Programs. Further federal funding is anticipated from the U.S. Department of Agriculture (USDA). The USDA has proposed a rule which would make loans available to communities with populations of up to 10,000 for the construction or modification of hydroelectric facilities.

If the rule is finalized in its present form the Farmers Home Administration Community Loan Program would make funds available for small-scale hydroelectric projects not eligible for assistance from the USDA's Rural Electrification Administration, which can loan only to communities with populations less than 1500. According to USDA, potential loan applicants would be public bodies and would include municipalities, counties, districts, or other political subdivisions of a state.

Eligible loan proposals would include the restoration of deactivated dams and hydroelectric generators, enlargement of existing plants, and construction of new facilities. Loans could also be used to finance the

building of transmission lines from generating sites to distribution systems.

#### State Funding

California Energy Commission Feasibility Grants. In 1979 and 1980 the California Energy Commission (CEC) cofunded 18 feasibility studies for potential small hydroelectric sites at existing dams and aqueducts. The CEC funded up to 50 percent of the cost of these studies. Inquiries regarding the availability of future funding for small hydroelectric feasibility studies should be directed to:

California Energy Commission  
1111 Howe Avenue  
Sacramento, CA 95825  
(916) 920-6106

#### Other Potential Sources of State Funding

Funding for small hydroelectric development received significant attention from the Legislature. Recently chartered bills which provide funding for small hydroelectric development include:

Chapter 1358, Statutes of 1980 (AB 74). This bill permits cities and counties to issue industrial development bonds to finance, among other projects, private energy development projects including small hydroelectric projects. Up to \$200,000,000 in bonds may be sold statewide. A participating city or county must establish a local industrial development authority to administer the program, and employment, conservation, and consumer benefits must be shown before a project is eligible for this type of financing. For further information on the program contact:

Office of the State Treasurer  
915 Capitol Mall  
Sacramento, CA 95814  
Attention: Jim Sargeant  
(916) 322-5471

Chapter 908, Statutes of 1980 (AB 2324). This bill creates a California Alternative Energy Source Financing Authority which is authorized to issue up to \$200,000,000 in revenue bonds to finance the construction of facilities using alternative energy sources. Hydroelectric projects under 25 megawatts developed by private individuals or organizations are eligible for financing by means of these bonds if they are selected by the Authority. Criteria for selection include technological feasibility, financial soundness, and likelihood of reducing reliance on fossil fuels. Special emphasis is given to financing small (under \$1,000,000 or one megawatt) projects. For more information on the program contact:

Office of State Treasurer  
915 Capitol Mall  
Sacramento, CA 95814  
(916) 445-8968

Chapter 1327, Statutes of 1980 (AB 2893). This bill allows for rapid amortization of alternative energy production equipment for state income tax purposes. Hydroelectric generating equipment installed before January 1, 1986 with an installed capacity of less than 25 MW is eligible for this deduction. For equipment with a life of over 15 years (hydroelectric projects typically have useful lives of 50 years), only a proportionate amount of the value of the asset is eligible for this amortization method. For more information contact:

Franchise Tax Board  
Sacramento, CA 95867  
(916) 355-0370  
From Southern California: (800) 852-5711  
From Northern California: (800) 852-7050

Chapter 899, Statutes of 1980 (AB 2973). This bill creates a \$120,000,000 Energy and Resources Fund in the State Treasury and provides for yearly appropriations to maintain the fund at this amount. The Fund consists of an Energy Account and a Resources Account with the amounts allocated to each to be determined by the annual budget Bill. No money may be transferred to the Energy Account after December 31, 1981, unless a Department of Energy has been created or the California Energy Commission has been reorganized. Projects to be funded from the Energy Account must be short-term projects, not on-going programs. Criteria for selection are: potential for reducing use of oil and natural gas; potential for widespread use throughout the State by 1990, and feasibility. All appropriations will be made by the annual Budget Bill, and will be for state-administered programs. The bill creating the Energy and Resources fund does not provide any direct funding of small hydroelectric projects.

Chapter 733, Statutes of 1980 (AB 3048). This bill establishes a program, to be managed by the Department of Food and Agriculture in cooperation with the California Energy Commission, to demonstrate the effectiveness and economic feasibility of energy conservation and renewable resource energy technologies in agriculture. The program will include financial assistance in the form of loans, guarantees, leases and participating agreements to encourage energy conservation and renewable resource use in agriculture. Among the projects eligible for assistance are small hydroelectric generators of less than 100 kW at existing facilities associated with agricultural water use. Individuals, businesses and public agencies are all eligible to apply for assistance. For further information contact:

Department of Food and Agriculture  
1220 N Street, Room 104  
Sacramento, CA 94814  
Attention: Steve Shaffer  
(916) 322-5227

Chapter 819, Statutes of 1980 (SB 16). This bill creates a nonprofit corporation to provide financing assistance for qualified small businesses in the alternative energy industry. The corporation (BIDCO) has a \$2.5 million line of credit with the state and will leverage this money with other government loan programs. Firms will not be eligible for

assistance unless they have applied for a loan at one or more California banks and have been denied such a loan. For more information contact:

SAF BIDCO  
Department of Economic and Business Development  
1120 N Street  
Sacramento, CA 95814  
(916) 322-9725

#### Bond Financing

Bonds sold by public entities generally fall into two categories: general obligation bonds and revenue bonds. Payment of the principal and interest of a general obligation bond is backed by the taxing power of the entity issuing the bond. In contrast, revenue bonds restrict the source of payment to the revenues from the project financed by the bonds.

Interest on bonds issued by the State of California or a local government in the State is exempted by the State Constitution from California income tax. Revenue bonds sold by a public entity to finance hydroelectric development are tax-exempt under both State and Federal law provided the power is used by or sold to a public agency. However, so-called "industrial development bonds" issued by public entities may be subject to federal income tax. As set forth in Internal Revenue Code (IRC) Section 103(b) a revenue bond sold by a public entity is an industrial development bond if more than 25 percent of the output of the financed project is sold to a private entity over the term of the bond, and certain other conditions are met.

Several special provisions of the IRC allow public entities to issue tax-exempt industrial development bonds (IDB). Section 103(b)(4)(E) permits a public entity to issue tax-exempt bonds and sell project output to a private entity if the generation is used by the general populace within two local contiguous counties.

Section 103(b)(6)(A),(D) allows tax-exempt financing under certain circumstances for hydroelectric facilities by both public and private entities (where state statutes provide for industrial development bond financing in general and for hydroelectric facilities in particular) for small projects costing less than \$10 million. Section 103(b)(4)(H), added to the IRC by the Windfall Profit Tax Act of 1980 (P.L. 96-223), permits the use of tax-exempt IDB's for financing hydroelectric projects with an installed capacity of up to 125 megawatts at existing dams and hydraulic structures that were completed before October 18, 1979, that are owned by a governmental body, and where no changes are made to water releases or streamflow regimen. The entire facility may be financed with tax-exempt IDB's where the installed capacity does not exceed 25 megawatts. A formula is provided to determine what fraction of the costs of a 26-125 megawatt facility may be financed by tax-exempt IDB's. Provided these conditions are met, a public agency can now finance all or a part of its small hydro development with tax-exempt IDB's even if all the project's generation is sold to a utility such as PG&E or SCE under PURPA as discussed in Chapter II.

The interest rates for tax-exempt revenue bonds at mid-1980 ranged between 9 and 10 percent.

Taxable revenue bonds can be issued by both public and private entities to finance the development of small hydroelectric projects. Such bonds would be free of the power sale restrictions placed on tax-exempt bonds, and project generation could be sold under PURPA as discussed in Chapter II. The interest rates for taxable bonds at mid-1980 ranged between 12 and 14 percent.

A number of financial institutions arrange for the issuance of all types of bonds and provide investment banking services such as underwriting, assisting with bond rating agencies, placing bonds, and maintaining a secondary market for trading of bonds through local offices throughout the Nation. Further information can be obtained from any investment banking house. The issuance of bonds is a complex activity and the prospective developer may desire the services of a financial advisor specializing in the sale of bonds. In addition, because of the complexity of the tax and other laws governing the issuance of bonds, legal counsel specializing in bond sales should be consulted.

#### Private Financing

The Windfall Profits Tax Act of 1979 provides that the owner of a small hydroelectric project is entitled to an additional 11 percent nonrefundable tax credit, making the total of such credits about 21 percent of project cost. The additional investment tax credit is to encourage the private development of small hydroelectric projects. However, the additional 11 percent credit cannot be taken on that part of a project that is financed with tax-exempt bonds. Private developers can use a variety of financing methods limited only by their imaginations and the willingness of lending institutions to make development funds available. A rule-of-thumb proportion of equity investment (or its equivalent) is in the range of 25 to 30 percent with the balance being long-term debt.

#### Combination Financing

Since there are a number of federal loan and grant programs for partial funding of small hydroelectric developments, combination financing is possible. With the high current interest rates for bonds and mortgage loans, partial funding of hydroelectric development by federal grants or low interest loans may make the difference between economic feasibility and infeasibility. Funding for each potential project must be pursued on a case-by-case basis since grant or loan eligibility is very restrictive.

An example of combination financing for a private development might be a UDAG loan for 25 percent of project costs at 5 percent interest, an IDB for 50 percent of project costs at 9 percent interest, and an equity or a mortgage loan for the remaining 25 percent of project costs at 14 percent interest. The weighted average net cost of money would be about 9.25 percent without allowance for investment tax credits.

At mid-1980, the prospects for federal grants or loans to assist in financing small hydroelectric projects are unclear. While such grants and

loans might be authorized by law, Congress must appropriate the funds for most loans and grants and make them available. Certain programs, such as the DOE loan program for feasibility studies and licensing, were funded for specific amounts when enacted. The DOE loan program under Title IV of PURPA authorized \$10 million in loans for each fiscal year 1978 through 1980 with any balance to remain available until expended. For other federal programs, approval of a grant or loan may not necessarily mean that funds have been appropriated.

### Costs of Financing

Fixed Cost. The fixed cost of financing a small hydroelectric project by issuing bonds includes the cost of money represented by the interest rate on the bonds issued, net interest during construction, bond underwriting and sales expenses, and repayment of the debt. A revenue bond issue would also include a reserve fund, usually equal to one year's principal and interest payments. The reserve fund, which provides a measure of security to the bondholder in the event of a default, is invested in short-term securities and earns interest which is credited toward principal and interest payments. The net interest during construction consists of capitalized interest, funded from the bond issue itself, less interest earnings on unexpended bond proceeds during the construction period. For a small hydroelectric project, the actual construction period (after receipt of construction authorizations and permits) is about 12 months. The bond underwriting and sales expenses will vary from about 3.5 to 5 percent of the bond issue with the lesser percentages needed for larger bond issues. Assuming a tax-exempt bond issue with 9 percent interest for 35 years (i.e., level debt service), the annual fixed cost of financing can be calculated as follows:

|                              |                           |
|------------------------------|---------------------------|
| Interest During Construction | 4.5% of Project Cost      |
| Bond Reserve Fund            | 9.464% of Bond Issue      |
| Interest Earnings            | 7.0% of Bond Reserve Fund |
| Financing Costs (average)    | 4.0% of Bond Issue        |

$$\begin{aligned} \text{Bond Issue} &= \frac{1.045}{1-(0.04 + 0.09464)} \times \text{Project Cost} \\ &= 1.21 \times \text{Project Cost} \end{aligned}$$

Annual Fixed Cost:

|                   |                                    |                         |
|-------------------|------------------------------------|-------------------------|
| Net Fixed Cost    | = Debt Service - Interest Earnings |                         |
| Debt Service      | = 1.21 x 0.09464                   | = 0.1143                |
| Interest Earnings | = 0.07 x 0.1143                    | = 0.0080 (credit)       |
| Net Fixed Cost    | = 0.1143 - 0.0080                  | = 0.1063 x Project Cost |

There has been some indication at mid-1980, that uncertain economic conditions may make buyers reluctant to purchase bonds with terms longer than 20 years. If the term of the tax-exempt bond issue with a 9 percent interest rate was 20 years rather than 35 years, the annual fixed cost of financing would be 12.5 percent, calculated as follows:

|                              |                           |
|------------------------------|---------------------------|
| Interest During Construction | 4.5% of Project Cost      |
| Bond Reserve Fund            | 10.955% of Bond Issue     |
| Interest Earnings            | 7.0% of Bond Reserve Fund |
| Financing Costs (average)    | 4.0% of Bond Issue        |

$$\text{Bond Issue} = \frac{1.045}{1-(0.04 + 0.10955)} \times \text{Project Cost}$$

$$= 1.23 \times \text{Project Cost}$$

Annual Fixed Cost:

|                   |   |
|-------------------|---|
| Debt Service      | = 1.23 x 0.10955 = 0.1346               |
| Interest Earnings | = 0.07 x 0.1346 = 0.0099 (credit)       |
| Net Fixed Cost    | = 0.1346-0.0099 = 0.1252 x Project Cost |

Similarly, the annual fixed cost of financing a 35-year taxable bond issue with an interest rate of 12 percent would be 14.4 percent of the project costs. If the term of the bonds was 20 years, the annual fixed costs would be 16.0 percent of project costs.

Financing small hydroelectric projects by issuing revenue bonds would probably be 100-percent debt financing. For private financing, the project would likely be financed by some combination of debt and equity financing with a minimum of 20 percent equity. The return on equity could vary over a wide range as determined by time and by the investor(s) financial status. For example, during the early years of a project an investor might be willing to accept a zero or negative return on his investment in return for investment tax credits and potential long term benefits. However, the upper range of allowable interest rates for debt financing is likely to be 15 percent for small hydroelectric projects because beyond that point a prospective investor would probably seek some alternative investment opportunity. At 15 percent interest, the fixed annual cost for economic analyses could be as high as 17.8 percent of the project costs for 20-year debt financing calculated as follows:

|                              |                      |
|------------------------------|----------------------|
| Interest During Construction | 7.5% of Project Cost |
| Equity                       | 20% of Investment    |
| Long-term Debt               | 80% of Investment    |
| Financing Costs              | 5% of Investment     |

$$\text{Investment} = 1.075 \times 1.05 \times \text{Project Cost}$$

Annual Fixed Cost:

|                  |   |
|------------------|---|
| Debt Service     | = 0.80 x 1.05 x 1.075 x 0.1598 = 0.1443 |
| Return on Equity | = 0.20 x 1.05 x 1.075 x 0.15 = 0.0339   |
| Net Fixed Cost   | = 0.1346-0.0099 = 0.1782 x Project Cost |

Similarly, the annual fixed cost of financing for 35-year debt and a 15 percent interest rate would be about 16.2 percent of project cost.

In summary, there would be range of annual fixed costs for small hydroelectric plants depending on the interest rates and the period of financing (Table H-2).

Table H-2. Annual Fixed Cost Rates Shown  
as Percentage of Total

| Term of Debt | Interest Rate |      |      |
|--------------|---------------|------|------|
|              | 9%            | 12%  | 15%  |
| 20 years     | 12.5          | 16.0 | 17.8 |
| 35 years     | 10.6          | 14.4 | 16.2 |

Operating Costs. In addition to the annual fixed cost of ownership, a developer must consider the cost of operating a project. This includes insurance on equipment, a provision for interim replacements, labor and materials for operation and maintenance, and where applicable, local property taxes.

The principal construction-cost components of a small hydroelectric project located at an existing hydraulic structure are the civil and structural works (FERC accounts 331 and 332) and the mechanical and electrical equipment (FERC accounts 333 and 334). Unless the developer elects to be self-insured, a large public body such as an irrigation district, might, insurance is needed to protect the developer in the event of damage to major equipment. Annual premiums for such insurance have increased significantly during the past year and currently are about 8.5 percent of the insured value with a 25 percent deductible provision. As more small hydroelectric projects are placed in operation and additional operating experience is obtained, and additional insurance companies enter the field, it is possible that insurance premiums in the future may be significantly less than current levels.

With proper maintenance, hydraulic turbines and electric generators have a useful life well in excess of the 20-year to 35-year economic life of a long-term debt. It is not uncommon for a turbine/generator to operate for 50 years before a major repair is necessary. Rewinding the electric generator and perhaps replacing the bearings will begin another 50-year operating cycle. Since some accessory mechanical and electrical equipment will have useful lives shorter than the financing period, it is desirable to provide a contingency fund for such interim replacements. As a part of the annual operating costs, an allowance of 0.3 percent of the total cost of the mechanical and electrical equipment provides a sinking fund for interim replacements.


The cost of labor and materials for operating and maintaining a small hydroelectric plant will vary widely from site to site. At one site where hydroelectric generation is a by-product of irrigation releases, the operating cost may be negligible since an operator must operate a valve to control the releases with or without a hydroelectric plant at the site. At another site where hydroelectric generation is a by-product of flood control releases, it may be necessary to have a full time operator on call for hydroelectric operation (or an agreement with the operator of the flood control dam). In any event, operation and maintenance costs are small components of the overall annual cost of a hydroelectric facility.

Local property taxes, when applicable, could be a potential deterrent to developing small hydroelectric projects because of the high capital-intensive nature of the facility. About 70 to 80 percent of the annual costs of owning and operating a small hydroelectric facility are fixed by the amount of capital investment required for construction; about 20 to 30 percent represent annual operating costs. Of that 20 to 30 percent, the variable portion related to hours of operation is almost negligible. If property taxes are assessed on 100 percent of actual investment, the annual fixed costs could be increased by as much as 25 percent. In some areas of the U.S., tax stabilization can be negotiated and property taxes can be paid on the value of generation rather than on the investment in property.


APPENDIX I

Hydroelectric Equipment


# Figure I-1 Types of Turbines




FRANCIS TURBINE




PROPELLER OR KAPLAN TURBINE




TUBE-TYPE TURBINE




BULB TURBINE




RIM GENERATOR



IMPULSE TURBINE



CROSS - FLOW IMPULSE TURBINE



THE SCHNEIDER LIFT TRANSLATOR

## APPENDIX I

### Hydroelectric Equipment

The principal pieces of equipment in a small hydroelectric plant are the inlet valve, turbine, electric generator, control and protection equipment, circuit breaker, transformer, and transmission connection. Miscellaneous equipment includes a crane (unless access is provided for use of a mobile crane), station lighting and power systems, a fire protection system, heating and ventilation equipment, and sanitary facilities. Except for the turbine and generator all of the equipment is standard industrial equipment which need not be discussed here.


The capacity of a specific hydroelectric site is determined by water flow and the available head. Selection of the type of turbine needed to drive an electric generator is based primarily on the head. Table I gives the range of operational heads for several types of turbines. Propeller turbines with adjustable-pitch blades -- also know as Kaplan turbines -- are useful where flows vary widely. Several manufacturers have developed other small turbines, such as rim-types and crossflow-types, which have special characteristics that might be preferred for some projects. The most common types of turbines are shown in Figure I-1. Typical performance curves for various types of hydraulic turbines are shown in Figure I-2.

Table I. Types of Turbines Used for Various Heads

| Turbine                                  | Operational Head                                   |
|--|--|
| Lift Translator                          | Low: less than 0.5 m to 15 m<br>(1.5 ft to 50 ft.) |
| Tube-type                                | Low: less than 16 m (50 ft)                        |
| Impulse- or Pelton-type                  | High: greater than 60 m (200 ft)                   |
| Vertical Propeller-type                  | Low to Medium: 4.6 m to 60 m<br>(15 ft to 200 ft)  |
| Francis-type<br>(horizontal or vertical) | Low to High: 9.4 m to 300 m<br>(30 ft to 980 ft)   |

The generator can be either a synchronous-type or induction-type. A synchronous generator is brought to operating speed by the turbine, synchronized to the electric system voltage and frequency, and then connected to the electric system. Once connected, the turbine-generator unit continues to operate at its synchronous speed. An induction generator

Figure I-2 Typical Performance Curves  
for Various Types of Hydraulic Turbines



is an electric motor that is operated as a generator. It is generally started as a motor without water flowing through the turbine. When the unit is up to speed the valves or gates are opened and it begins to operate as a generator. The type of generator used depends on the characteristics of the transmission system and the distance to other electrical power sources. Generally, a synchronous generator is more suitable for small hydroelectric projects because the sites are usually located some distance from other generating facilities. The efficiency of small generators ranges between 92 and 96 percent, and changes very little with variations in the head and flow. With a transformer efficiency of 98 percent this gives a plant an overall efficiency of about 85 percent of its rated capacity.

Francis Turbines. A Francis turbine has fixed vanes. Water enters the turbine in a radial direction on a plane perpendicular to the turbine-generator shaft, then changes direction 90 degrees, and is discharged in an axial direction, parallel to the shaft. The principal components of the turbine are a water spiral supply case to carry water to the runner, the runner itself, wicket gates to control the amount of water reaching the runner and to distribute it equally around the runner, and a draft tube to carry the water away from the turbine. The turbine can be mounted either vertically or horizontally depending on by site conditions.

The Francis turbine can operate over a range of about 30 to 110 percent of its design flow and about 60 to 150 percent of its design head. The peak efficiency of about 88 to 92 percent usually occurs is at about 90 to 95 percent of its rated capacity. Below 90 percent of its rated capacity, the turbine's efficiency drops fairly rapidly to about 75 percent at 50 percent of its rated capacity.

Propeller Turbines. A propeller-type turbine has a runner with three to six blades. The water passes through the runner in an axial direction parallel to the shaft. The principal components of the propeller turbine are similar to those of a Francis turbine. The pitch of the blades can be either fixed or adjustable; adjustable blades permit the turbine to operate with greater efficiency over a wider range of water flows.

Propeller turbines can be mounted either vertically or horizontally. One American manufacturer developed a standardized design for a horizontally-mounted propeller turbine with an S-shaped tubular water-supply case. This variation of the propeller turbine is discussed below as a tube turbine. Other variations of the horizontal propeller turbine include bulb and rim configurations also discussed below. The vertical propeller turbine has been the most-commonly used turbine in the past.

Vertical propeller turbines are available for heads ranging from 4.6 m to 61 m (15 ft to 200 ft). Propeller turbines can be operated over a range of about 30 to 100 percent of their design flow if provided with adjustable blades, and 40 to 140 percent of design head. Peak efficiency occurs at 90 to 95 percent of the rated capacity and, for a fixed blade propeller, will be about the same or slightly less than the Francis turbine at 88 to 92 percent. Below 90 percent of the rated capacity, turbine efficiency will drop off more rapidly than with the Francis turbine to about 70 percent at 50 percent of the rated capacity (Figure I-2).

Tube type Turbines. Tube-type turbines are horizontal or slant-mounted propeller runners with the electric generator located outside the water-supply case. This arrangement is accomplished using an S-type water passageway that includes the intake valve or gate, turbine, and draft tube as a single unit with the turbine-generator shaft extending out of the tube at the top bend of the S-shape. Tube-type turbines can have either fixed or adjustable blades. The performance characteristics for a tube-type turbine are similar to those for propeller turbines. The operating range with adjustable blades is greater than for a fixed-blade propeller turbine but less than for a Kaplan (vertical adjustable-blade propeller) turbine.

Tube-type turbines can be connected to the generator either directly or through a speed increaser gear box. The speed increaser lowers the plant's efficiency but allows the generator to be physically smaller with a corresponding reduction in manufacturing cost. The choice of direct or speed-increaser coupling is an economic decision. The advantages of using a speed increaser gear box is greater with lower heads.

Standardized tube-type turbines are available from one American manufacturer in ten sizes ranging up to a 5000 kW capacity and for heads of 1.8 m to 15 m (6 ft to 50 ft). At least one standardized tube-type turbine is operating successfully at about a 65-foot head after appropriate modification of the runner. The use of a tube-type turbine is generally limited to a maximum head of 15 m to 18 m (50 ft to 60 ft).

Bulb Turbines. A bulb turbine is a horizontal propeller-type unit whose generator is contained in a bulb immersed in the flow of water within the water-supply case. The bulb, held in place by structural supports, is provided with access shafts for maintenance. The performance characteristics and operating ranges of bulb turbines are similar to those of tube-type turbines with about a one percent improved efficiency since the flow of water is in a straight line rather than changed in direction by the S-shape.

The bulb turbine's compact design reduces the size of the powerhouse needed but introduces the need for additional structural supports to position the bulb within the water-supply case. Access to the generating unit for maintenance is more difficult than with other types of turbines.

The bulb turbine is available from foreign manufacturers and has been used successfully in low-head hydroelectric installations in Europe.

Rim Turbines. The rim-type turbine is similar to the bulb turbine except that the generator rotor is mounted on the periphery of the turbine runner blades. The concept was developed by a Swiss manufacturer 40 years ago and given the name "Straflo." About 75 units presently in service have capacities ranging from 1000 kW to 1900 kW at heads of 7.9 to 9.1 metres (26 to 30 feet). The rim design requires a water sealing arrangement between the water-supply case and the rotating outer rim; this limits this type of installation to fixed-blade runners under 2000 kW in size and under 9.8 m (32 ft) of head. The manufacturer is seeking to develop a new sealing design for use with higher heads and increased capacities.

The performance characteristics of the rim-type turbine are similar to those of the bulb turbine. The rim-type design is simple and compact requires less civil works and a smaller power house than other types of turbine/generators.

Impulse Turbines. An impulse turbine (also known as a pelton wheel) uses one or more nozzles to direct water at the buckets of a runner in a nonpressurized space. Impulse turbines are used for installations with heads above about 45.7 m (150 ft). Unless the head is greater than several hundred feet, other types of turbines are likely to result in a lower-cost installation. The design and installation of an impulse turbine for high-head hydropower is relatively simple with lower maintenance than for other types of turbines. The unit consists of one or more nozzles, each with a needle valve, a one-piece cast runner and a direct-connected electric generator. No draft tube is required.

Impulse turbines have very flat efficiency curves and may be operated down to loads of 20 percent of their rated capacity (Figure I-2).

Cross-flow Turbines. The cross-flow turbine is a variation of the impulse turbine. It was developed by a West German manufacturer and given the name "Ossberger Turbine." The cross-flow turbine has a cylindrical runner with adjustable inlet-guide vanes to direct the flow of water and a conical draft tube. The draft tube creates a pressure below one atmosphere in the runner chamber thereby using the head between the runner centerline and the centerline and the tailrace water level. This head is lost in impulse turbine installations.

The performance characteristics of the cross-flow turbine are similar to those of an impulse turbine; it has a very flat efficiency curve over a wide range of flow conditions. However, the peak efficiency of the cross-flow turbine is 83 to 85 percent as compared with an 88 to 92 percent efficiency with other types of turbines.

Schneider Lift Translator. Conventional turbine technology remains static, but one new device has been developed that may be applicable to certain low-head projects. The Schneider Lift Translator is still in the research and development stage, but several prototypes are being manufactured for trial installation as a part of a U. S. Department of Energy (DOE) grant. Basically, the Schneider device resembles a series of venetian blinds mounted in a somewhat oval shape. It has the potential to produce power under very low-head conditions. The trial installations will attempt to use it in existing conduits. A lift translator was recently installed on an irrigation canal in Richvale (Butte County), California.

The basic lift translator design operates with heads between 0.5 m and 15.2 m (1.5 ft) and (50 ft) and has a capacity of 1 kW to 50 kW. Other units are available for higher heads and higher capacities of up to 5000 kW.



APPENDIX J

Manufacturers of Small Hydroelectric Equipment



## APPENDIX J

## Manufacturers of Small Hydroelectric Equipment

United States

Alexis Pastuhov  
P. O. Box 62  
Harvard, MA 01451  
(617) 456-8834

Allis-Chalmers  
Hydro-Turbine Division  
East Berlin Road  
P. O. Box 712  
York, PA 17405  
(717) 792-3511

American Ligurian Company  
15 Ralsey Road South  
P. O. Box 1005  
Stanford, CT 06902  
(203) 324-7351

Arbanas Industries  
24 Hill Street  
Xenia, OH 45385  
(513) 372-1884

Axel Johnson Corporation  
Spear Street Tower  
1 Market Plaza  
San Francisco, CA 94105  
(415) 777-3800

Beckwith Electric Company, Inc.  
11811 62nd Street North  
Largo, FL 33543  
(813) 535-3408

Boeing Engineering and Construction  
P. O. Box 3707  
M.S. 8C-12  
Seattle, WA 98124  
(206) 773-8891

Border Electric Company  
Route 1  
Blaine, WA 98230  
(206) 322-5545

Brown Boveri Corporation  
1460 Livingston Avenue  
North Brunswick, NJ 08902  
(201) 932-6000

Canyon Industries  
5342 Mosquito Lake Road  
Deming, WA 98244  
(206) 592-5552

Cascade Patterns  
1309 Glenwood Drive  
Mount Vernon, CA 98273  
(206) 856-6608

Charmilles  
EURO-USA Company  
779 Barbara Avenue  
Solana Beach, CA 92075  
(714) 775-7974

Control Devices Pacific  
P. O. Box 1485  
Burlingame, CA 94610  
(415) 347-3773

Electric Machinery Manufacturing Company  
A Division of Turbodyne Corp.  
800 Central Avenue  
Minneapolis, MN 55413  
(612) 378-8000

Essex Turbine  
Kettle Cove Industrial Park  
Magnolia, MA 01930  
(617) 525-3523

Fuji Electric Ltd.  
Nissho-Iwai  
Suite 1900  
700 South Flower Street  
Los Angeles, CA 90017

General Electric Company  
One River Road  
Schenectady, NY 12345  
(518) 385-5444

Hannon Electric Company  
1605 Waynesburg Drive S. E.  
Canton, OH 44707  
(216) 456-4728

Hydro Energy Systems, Inc.  
Two World Trade Center  
New York, NY 10048  
(212) 466-1404

Hydrotool Corporation  
2640 Industry Way  
Lynwood, CA 90262  
(213) 639-4402

Hydrowest  
38 Tam O'Shanter Road  
Alamo, CA 94507  
(415) 837-7679

Independent Power Developers  
P. O. Box 1467  
Noxon, MT 59853  
(406) 847-2315  
or  
P. O. Box 285  
Sandpoint, ID 83864  
(208) 263-2166

The James Leffel and Company  
426 East Street  
Springfield, OH 45501  
(513) 323-6431

Kvaerner-Moss, Inc.  
800 Third Avenue, 31st Floor  
New York, NY 10022  
(212) 752-7310

Lima Electric Company  
200 East Chapman Road  
P. O. Box 918  
Lima, OH 45802  
(419) 227-7327

National Tank and Pipe Company  
P. O. Box 7  
10037 S. F. Mather Road  
Clackamas, OR 97105  
(503) 656-1991

Nissho Iwai American Corporation  
700 South Flower Street, Suite 1900  
Los Angeles, CA 90017  
(213) 688-0600

Oriental Engineering & Supply Company  
1485 Bayshore Boulevard, Suite 368  
San Francisco, CA 94124  
(415) 467-8616 or (415) 325-0925  
or  
670 Newell Road  
Palo Alto, CA 94303  
(415) 325-0925

Pullman Incorporated  
200 South Michigan Avenue  
Chicago, IL 60604  
(312) 322-7167

Pumps, Pipes and Power  
Kingston Village  
Austin, NV 89310  
(702) 964-2483

Rand Corporation  
1700 Main Street  
Santa Monica, CA 90406  
(213) 393-0411

Short Stoppers Electric  
Route 4, Box 247  
Coos Bay, OR 97420  
(503) 267-3559

Siemens-Allis, Inc.  
6400 Westminster Avenue, Suite 219  
Westminster, CA 92683  
(714) 894-7509

or  
Box 2168  
Milwaukee, WI 53241  
(415) 325-0925

Small Hydroelectric Systems  
and Equipment  
P. O. Box 124  
Custer, CA 98240  
(206) 366-7696

Sulzer Brothers, Inc.  
1255 Post Street  
San Francisco, CA 94109  
(415) 441-7230

Toshiba International Corporation  
465 California Street, Suite 430  
San Francisco, CA 94104  
(415) 434-2340

Trident Engineering  
Box 11232 Piedmont Station  
Oakland, CA 94611  
(415) 986-6558

Westinghouse Electric Corp.  
700 Braddock Avenue  
East Pittsburgh, PA 15112  
(412) 255-3800

Wind and Water Power  
P. O. Box 49  
Harrisville, NH 03450  
(603) 827-3367

## Canadian

Barber Hydraulic Turbine, Ltd.  
Barber Point, Box 340  
Port Colborne, Ontario L3K 5W1  
Canada  
(416) 363-4929

Dominion Engineering Works, Ltd.  
P. O. Box 220  
Montreal, Quebec H3C 2S5  
Canada  
Telex 05-25168

F. W. E. Stapenhorst Inc.  
285 Labrosse Avenue  
Point Clair, Quebec H9R 1A3  
Canada  
(514) 695-2044

Niagara Water Wheels, Ltd.  
706 E. Main Street  
Welland, Ontario L3B 3Y4  
Canada

## Foreign

A. B. Bofors-Nohab  
S-46101  
Trollhattan  
Sweden

Alsthom  
38 Avenue Kle'ber  
75784 Cedex 16  
Paris  
France

Ateliers des Charmilles SA,  
109 Rue De Lyon  
CH-1211 Geneva 13  
Switzerland

Balaju Yantra Shala (P) Ltd.  
Balaju, Katmandu  
Nepal

Barata Metal Works and Engineering PT  
J. L. Ngagel (109)  
Surabaya  
Indonesia

Boving and Company, Ltd.  
Villiers House, 41-47 Strand  
London, WC2N 5LB  
England

Briau SA  
BP 43  
37009  
Cedex  
Tourse  
France

Drees and Company GMBH  
Postfach 42  
4760 Werl/West  
West Germany

Elektro GMBH  
St. Gallerstrasse 27  
Winter Thur  
Switzerland

Escher-Wyss, Ltd.  
Hardstrasse 319  
CH-005 Zurich  
Switzerland

Fuji Electric Company, Ltd.  
12-1 Yurakucho, 1-Chome  
Chiyoda-ku  
Tokyo  
Japan

Gilbert, Gilkes and Gordon, Ltd.  
Westmoreland, LA9 7BZ  
England

Hitachi Ltd.  
New Marie Building  
Maranouchi  
Chiyoda-ku  
Tokyo  
Japan

J. M. Voith GMBH  
Postfach 1940  
D-7920 Heidenheim  
West Germany

Jyoti, Ltd.  
Industrial Area  
P. O. Chemical Industries  
Barodo 390 033  
India

Karlstads Mekaniska Werkstad  
Fack S-681 01  
Kristinehamn  
Sweden

KMW  
AN Warlstads Mekauiska Werkstad  
S-681-01  
Kristinehamn 1  
Sweden

Kvaerner Brug A/S  
Box 3610  
Oslo  
Norway

Land and Leisure Services  
Priory Land  
St. Thomas Launceston  
Cornwall  
England 8400

LMX (Lemingrad Metal Works)  
KTEP (Karkov Metal Works)  
V/O Energomach Exprot 35  
Mosfilmovskaya  
Moscow V-330  
USSR

Maschinenfabrik B. Maier  
Postfach 320  
Brockhagner Strasse 14/20  
4812 Brackwede  
West Germany

Maschinenfabrik Kossler GMBH  
A-3151 St. Polten  
St. Georgen  
Austria

Mitsubishi Heavy Industries Ltd.  
5-1 Maranouchi, 2-Chome  
Chiyoda-ku  
Tokyo 100  
Japan

Neyrpic Department Turbines  
75, Rue General Margin  
38100 Genboble  
France

Officiene Buehler  
Canton Ticino  
Switzerland

Ossberger  
Postfach 425  
D-8832 Weissenburg/Bayern  
West Germany

OY Tampella AB  
P. O. Box 267  
33101 Tampere 10,  
Finland

Riva Calzoni Sp A  
Via Standhal 34  
20144 Milan  
Italy

Tokyo Shibaura Electric Co., Ltd.  
(Toshiba)  
Producer Goods Export Division  
Uchisalwaichom, 1-Chome  
Chiyoda-ku  
Tokyo 100  
Japan

Voest-Alpine Mortan AG  
Muldenstrasse 5,  
A-4020 Linz  
Austria

Westward Mouldings, Ltd.  
Greenhill Works  
Delaware Road  
Gunnislake, Cornwall  
England













JUL 24

NOV 21 '81

JUN 18 1982

NOV 16 '82  
APR 5 '84

JUL 18 '84

THIS BOOK IS DUE ON THE LAST DATE  
STAMPED BELOW

BOOKS REQUESTED BY ANOTHER BORROWER  
ARE SUBJECT TO IMMEDIATE RECALL

RECEIVED

JUN 14 1982

PHYS SCI LIBRARY

JUL 23 1982

RECEIVED

AUG 5 1982

PHYS SCI LIBRARY  
JAN 5 1984

RECEIVED

DEC 16 1983

PHYS SCI LIBRARY

LIBRARY, UNIVERSITY OF CALIFORNIA, DAVIS

Book Slip-Series 45R

## CONVERSION FACTORS

| Quantity                | To Convert from Metric Unit                      | To Customary Unit                          | Multiply Metric Unit By | To Convert to Metric Unit Multiply Customary Unit By |
|-------------------------|--|--|-------------------------|--|
| Length                  | millimetres (mm)                                 | inches (in)                                | 0.03937                 | 25.4   |
|                         | centimetres (cm) for snow depth                  | inches (in)                                | 0.3937                  | 2.54   |
|                         | metres (m)                                       | feet (ft)                                  | 3.2808                  | 0.3048   |
|                         | kilometres (km)                                  | miles (mi)                                 | 0.62139                 | 1.6093   |
| Area                    | square millimetres (mm <sup>2</sup> )            | square inches (in <sup>2</sup> )           | 0.00155                 | 645.16   |
|                         | square metres (m <sup>2</sup> )                  | square feet (ft <sup>2</sup> )             | 10.764                  | 0.092903   |
|                         | hectares (ha)                                    | acres (ac)                                 | 2.4710                  | 0.40469  |
|                         | square kilometres (km <sup>2</sup> )             | square miles (mi <sup>2</sup> )            | 0.3861                  | 2.590  |
| Volume                  | litres (L)                                       | gallons (gal)                              | 0.26417                 | 3.7854   |
|                         | megalitres                                       | million gallons (10 <sup>6</sup> gal)      | 0.26417                 | 3.7854   |
|                         | cubic metres (m <sup>3</sup> )                   | cubic feet (ft <sup>3</sup> )              | 35.315                  | 0.028317   |
|                         | cubic metres (m <sup>3</sup> )                   | cubic yards (yd <sup>3</sup> )             | 1.308                   | 0.76455  |
|                         | cubic dekametres (dam <sup>3</sup> )             | acre-feet (ac-ft)                          | 0.8107                  | 1.2335   |
| Flow                    | cubic metres per second (m <sup>3</sup> /s)      | cubic feet per second (ft <sup>3</sup> /s) | 35.315                  | 0.028317   |
|                         | litres per minute (L/min)                        | gallons per minute (gal/min)               | 0.26417                 | 3.7854   |
|                         | litres per day (L/day)                           | gallons per day (gal/day)                  | 0.26417                 | 3.7854   |
|                         | megalitres per day (ML/day)                      | million gallons per day (mgd)              | 0.26417                 | 3.7854   |
|                         | cubic dekametres per day (dam <sup>3</sup> /day) | acre-feet per day (ac-ft/day)              | 0.8107                  | 1.2335   |
| Mass                    | kilograms (kg)                                   | pounds (lb)                                | 2.2046                  | 0.45359  |
|                         | megagrams (Mg)                                   | tons (short, 2,000 lb)                     | 1.1023                  | 0.90718  |
| Velocity                | metres per second (m/s)                          | feet per second (ft/s)                     | 3.2808                  | 0.3048   |
| Power                   | kilowatts (kW)                                   | horsepower (hp)                            | 1.3405                  | 0.746  |
| Pressure                | kilopascals (kPa)                                | pounds per square inch (psi)               | 0.14505                 | 6.8948   |
|                         | kilopascals (kPa)                                | feet head of water                         | 0.33456                 | 2.989  |
| Specific Capacity       | litres per minute per metre drawdown             | gallons per minute per foot drawdown       | 0.08052                 | 12.419   |
| Concentration           | milligrams per litre (mg/L)                      | parts per million (ppm)                    | 1.0                     | 1.0  |
| Electrical Conductivity | microsiemens per centimetre (µS/cm)              | micromhos per centimetre                   | 1.0                     | 1.0  |
| Temperature             | degrees Celsius (°C)                             | degrees Fahrenheit (°F)                    | (1.8 × °C) + 32         | (°F - 32) / 1.8                                      |

State of California—Resources Agency  
Department of Water Resources  
P.O. Box 388  
Sacramento  
95802

